

ADDRESS . : 632 RUTH CIR
CONTRACTOR : HAMPTON CUSTOM BUILDERS INC
OWNER . . : HAMPTON CUSTOM BUILDERS #69
PARCEL . . : 08-0654-01- -0292- -13-
APPL NUMBER: 06-50015275 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N TO BALLARD TAKE RIGHT NO TO
BALLARD RD TAKE A RIGHT ONTO RUTH CIR.
LOT 69 JB

STRUCTURE: 000 000 47X60 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/01/06 8/31/06	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001266667
B101 02	9/05/06 <u>9-5-06</u>	TI <u>ABS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001267186

COMMENTS AND NOTES

ADDRESS : 632 RUTH CIR SUBDIV: BALLARD WOODS
CONTRACTOR : HAMPTON CUSTOM BUILDERS INC PHONE : (919) 524-2915
OWNER : HAMPTON CUSTOM BUILDERS #69 PHONE : (919) 524-2915
PARCEL : 08-0654-01- -0292- -13-
APPL NUMBER: 06-50015275 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N TO BALLARD TAKE RIGHT NO TO
BALLARD RD TAKE A RIGHT ONTO RUTH CIR.
LOT 69 JB

STRUCTURE: 000 000 47X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/01/06 8/31/06	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001266667
B101 02	9/05/06 9/05/06	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001267186
A814 01	9/15/06 9/14/06	TI AP	ADDRESS CONFIRMATION VRU #: 001273580 632 RUTH CIR LOT 69
B103 01	9/15/06 9/14/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001273598
B103 02	9/18/06 9/18/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001274059
B103 03	9/20/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001275551

9-20-06 APRS

COMMENTS AND NOTES

ADDRESS . : 632 RUTH CIR SUBDIV: BALLARD WOODS
CONTRACTOR : HAMPTON CUSTOM BUILDERS INC PHONE : (919) 524-2915
OWNER . . : HAMPTON CUSTOM BUILDERS #69 PHONE : (919) 524-2915
PARCEL . . : 08-0654-01- -0292- -13-
APPL NUMBER: 06-50015275 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N TO BALLARD TAKE RIGHT NO TO
BALLARD RD TAKE A RIGHT ONTO RUTH CIR.
LOT 69 JB

STRUCTURE: 000 000 47X60 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/01/06 8/31/06	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001266667
B101 02	9/05/06 9/05/06	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001267186
A814 01	9/15/06 9/14/06	TI AP	ADDRESS CONFIRMATION VRU #: 001273580 632 RUTH CIR LOT 69
B103 01	9/15/06 9/14/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001273598
B103 02	9/18/06 9/18/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001274059
B103 03	9/20/06 9/20/06	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001275551
B105 01	9/27/06 <u>9-27-06</u>	TI <u>APB</u>	R*OPEN FLOOR VRU #: 001279827

----- COMMENTS AND NOTES -----

ADDRESS : 632 RUTH CIR SUBDIV: BALLARD WOODS
CONTRACTOR : HAMPTON CUSTOM BUILDERS INC PHONE : (919) 524-2915
OWNER : HAMPTON CUSTOM BUILDERS #69 PHONE : (919) 524-2915
PARCEL : 08-0654-01- -0292- -13-
APPL NUMBER: 06-50015275 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 N TO BALLARD TAKE RIGHT NO TO
BALLARD RD TAKE A RIGHT QNTO RUTH CIR.
LOT 69 JB

STRUCTURE: 000 000 47X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/01/06 8/31/06	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001266667
B101 02	9/05/06 9/05/06	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001267186
A814 01	9/15/06 9/14/06	TI AP	ADDRESS CONFIRMATION VRU #: 001273580 632 RUTH CIR LOT 69
B103 01	9/15/06 9/14/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001273598
B103 02	9/18/06 9/18/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001274059
B103 03	9/20/06 9/20/06	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001275551
B105 01	9/27/06 9/27/06	BS AP	R*OPEN FLOOR VRU #: 001279827
R425 01	11/02/06	TI	FOUR TRADE ROUGH IN VRU #: 001302066

11-2-06 DAB

COMMENTS AND NOTES

06-500 15914

Open Floor Temple

ADDRESS : 632 RUTH CIR
 CONTRACTOR : HAMPTON CUSTOM BUILDERS INC
 OWNER : HAMPTON CUSTOM BUILDERS #69
 PARCEL : 08-0654-01- -0292- -13-
 APPL NUMBER: 06-50015275 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 401 N TO BALLARD TAKE RIGHT NO TO
 BALLARD RD TAKE A RIGHT ONTO RUTH CIR.
 LOT 69 JB

SUBDIV: BALLARD WOODS
 PHONE : (919) 524-2915
 PHONE : (919) 524-2915

STRUCTURE: 000 000 47X60 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/01/06 8/31/06	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001266667
B101 02	9/05/06 9/05/06	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001267186
A814 01	9/15/06 9/14/06	TI AP	ADDRESS CONFIRMATION VRU #: 001273580 632 RUTH CIR LOT 69
B103 01	9/15/06 9/14/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001273598
B103 02	9/18/06 9/18/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001274059
B103 03	9/20/06 9/20/06	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001275551
B105 01	9/27/06 9/27/06	BS AP	R*OPEN FLOOR VRU #: 001279827
R425 01	11/02/06 11/02/06	BS DA	FOUR TRADE ROUGH IN VRU #: 001302066 1. repair top plate upstairs cut in two. 2. Repair joists cut for plumbing properly. 3. Nail plates used for plumbing at load bearing walls must be long nail plates and must have 3-16 nails each side. 4. Plywood garage walls. ok to side/insulate
I129 01	11/06/06 <u>11-16-06</u>	TI <u>DABS</u>	R*INSULATION INSPECTION VRU #: 001303593
R425 02	11/06/06 <u>11-16-06</u>	TI <u>DABS</u>	FOUR TRADE ROUGH IN VRU #: 001303585

COMMENTS AND NOTES

ADDRESS . : 632 RUTH CIR SUBDIV: BALLARD WOODS
 CONTRACTOR : HAMPTON CUSTOM BUILDERS INC PHONE : (919) 524-2915
 OWNER . . : HAMPTON CUSTOM BUILDERS #69 PHONE : (919) 524-2915
 PARCEL . . : 08-0654-01- -0292- -13-
 APPL NUMBER: 06-50015275 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 401 N TO BALLARD TAKE RIGHT NO TO
 BALLARD RD TAKE A RIGHT ONTO RUTH CIR.
 LOT 69 JB

STRUCTURE: 000 000 47X60 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/01/06 8/31/06	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001266667
B101 02	9/05/06 9/05/06	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001267186
A814 01	9/15/06 9/14/06	TI AP	ADDRESS CONFIRMATION VRU #: 001273580 632 RUTH CIR LOT 69
B103 01	9/15/06 9/14/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001273598
B103 02	9/18/06 9/18/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001274059
B103 03	9/20/06 9/20/06	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001275551
B105 01	9/27/06 9/27/06	BS AP	R*OPEN FLOOR VRU #: 001279827
R425 01	11/02/06 11/02/06	BS DA	FOUR TRADE ROUGH IN VRU #: 001302066 1. repair top plate upstairs cut in two. 2. Repair joists cut for plumbing properly. 3. Nail plates used for plumbing at load bearing walls must be long nail plates and must have 3-16 nails each side. 4. Plywood garage walls. ok to side/insulate
I129 01	11/06/06 11/06/06	BS DA	R*INSULATION INSPECTION VRU #: 001303593
R425 02	11/06/06 11/06/06	BS DP	FOUR TRADE ROUGH IN VRU #: 001303585 Nail plates at garage load wall and half bath must be long plates. 2. Cannot notch repair plywood on floor joists at 3 5/8 inch holes. repair correctly or supply engineering. \$50.00 re fee DO NOT SHEETROCK
I129 02	11/07/06 <u>11-7-06</u>	TI <u>DABS</u>	R*INSULATION INSPECTION VRU #: 001304740
R425 03	11/07/06 <u>11-07-06</u>	TI <u>DABS</u>	FOUR TRADE ROUGH IN VRU #: 001304732

COMMENTS AND NOTES

ADDRESS . : 632 RUTH CIR SUBDIV: BALLARD WOODS
 CONTRACTOR : HAMPTON CUSTOM BUILDERS' INC PHONE : (919) 524-2915
 OWNER . . : HAMPTON CUSTOM BUILDERS #69 PHONE : (919) 524-2915
 PARCEL . . : 08-0654-01- -0292- -13-
 APPL NUMBER: 06-50015275 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 401 N TO BALLARD TAKE RIGHT NO TO
 BALLARD RD TAKE A RIGHT ONTO RUTH CIR.
 LOT 69 JB

STRUCTURE: 000 000 47X60 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/01/06 8/31/06	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001266667
B101 02	9/05/06 9/05/06	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001267186
A814 01	9/15/06 9/14/06	TI AP	ADDRESS CONFIRMATION VRU #: 001273580 632 RUTH CIR LOT 69
B103 01	9/15/06 9/14/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001273598
B103 02	9/18/06 9/18/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001274059
B103 03	9/20/06 9/20/06	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001275551
B105 01	9/27/06 9/27/06	BS AP	R*OPEN FLOOR VRU #: 001279827
R425 01	11/02/06 11/02/06	BS DA	FOUR TRADE ROUGH IN VRU #: 001302066 1. repair top plate upstairs cut in two. 2. Repair joists cut for plumbing properly. 3. Nail plates used for plumbing at load bearing walls must be long nail plates and must have 3-16 nails each side. 4. Plywood garage walls. ok to side/insulate
I129 01	11/06/06 11/06/06	BS DA	R*INSULATION INSPECTION VRU #: 001303593
R425 02	11/06/06 11/06/06	BS DP	FOUR TRADE ROUGH IN VRU #: 001303585 Nail plates at garage load wall and half bath must be long plates. 2. Cannot notch repair plywood on floor joists at 3 5/8 inch holes. repair correctly or supply engineering. \$50.00 re fee DO NOT SHEETROCK
I129 02	11/07/06 11/07/06	BS DA	R*INSULATION INSPECTION VRU #: 001304740 joist repair must be per code or engineered
R425 03	11/07/06 11/07/06	BS DA	FOUR TRADE ROUGH IN VRU #: 001304732 joist repair must be per code or engineered
I129 03	11/08/06	TI	R*INSULATION INSPECTION VRU #: 001305473
R425 04	11/08/06	TI	FOUR TRADE ROUGH IN VRU #: 001305465

11-8-06
J *APBS*
J

COMMENTS AND NOTES

ADDRESS : 632 RUTH CIR SUBDIV: BALLARD WOODS
 CONTRACTOR : HAMPTON CUSTOM BUILDERS INC PHONE : (919) 524-2915
 OWNER : HAMPTON CUSTOM BUILDERS #69 PHONE : (919) 524-2915
 PARCEL : 08-0654-01- -0292- -13-
 APPL NUMBER: 06-50015275 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 401 N TO BALLARD TAKE RIGHT NO TO
 BALLARD RD TAKE A RIGHT ONTO RUTH CIR.
 LOT 69 JB

STRUCTURE: 000 000 47X60 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/01/06 8/31/06	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001266667
B101 02	9/05/06 9/05/06	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001267186
A814 01	9/15/06 9/14/06	TI AP	ADDRESS CONFIRMATION VRU #: 001273580 ✓ 632 RUTH CIR LOT 69
B103 01	9/15/06 9/14/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001273598
B103 02	9/18/06 9/18/06	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001274059
B103 03	9/20/06 9/20/06	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001275551
B105 01	9/27/06 9/27/06	BS AP	R*OPEN FLOOR VRU #: 001279827
R425 01	11/02/06 11/02/06	BS DA	FOUR TRADE ROUGH IN VRU #: 001302066 1. repair top plate upstairs cut in two. 2. Repair joists cut for plumbing properly. 3. Nail plates used for plumbing at load bearing walls must be long nail plates and must have 3-16 nails each side. 4. Plywood garage walls. ok to side/insulate
I129 01	11/06/06 11/06/06	BS DA	R*INSULATION INSPECTION VRU #: 001303593
R425 02	11/06/06 11/06/06	BS DP	FOUR TRADE ROUGH IN VRU #: 001303585 Nail plates at garage load wall and half bath must be long plates. 2. Cannot notch repair plywood on floor joists at 3 5/8 inch holes. repair correctly or supply engineering. \$50.00 re fee DO NOT SHEETROCK
I129 02	11/07/06 11/07/06	BS DA	R*INSULATION INSPECTION VRU #: 001304740 joist repair must be per code or engineered
R425 03	11/07/06 11/07/06	BS DA	FOUR TRADE ROUGH IN VRU #: 001304732 joist repair must be per code or engineered
I129 03	11/08/06 11/08/06	BS AP	R*INSULATION INSPECTION VRU #: 001305473
R425 04	11/08/06 11/08/06	BS AP	FOUR TRADE ROUGH IN VRU #: 001305465
H824 01	11/27/06 11/27/06	JM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001314699
R429 01	12/20/06	TI	FOUR TRADE FINAL VRU #: 001326081

12:00a APBS

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>SFD</u>	Conditional Use Permit No.: <u>></u>
Type of Construction: <u>II</u>	Building Permit No.: <u>06-5-15275</u>
Owner of Building: <u>Hampton Custom Bldgs</u>	Electrical Permit No.: <u>06-5-15275</u>
Building Address: <u>632 Ruth cir</u>	Insulation Permit No.: <u>06-5-15275</u>
Zoning District: <u>A1/A</u>	Plumbing Permit No.: <u>06-5-15275</u>
Zoning Permit No.: <u></u>	Mech. Permit No.: <u>06-5-15275</u>
Date: <u>12-20-06</u>	Envir. C.O. No.: <u></u>
<u>Brad Sutter</u> Building Official	<u></u> Zoning Official