
ADDRESS . : 190 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : WOODSHIRE PARTNERS LLC #139 PHONE :
PARCEL . . : 01-0536-04- -0028- -38-
APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
NURSERY RD GO APPROX 5 MILES UTRNL EFT
INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
THEN LEFT ON ADVANCE GO TO WOOD POINT
LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
	9/08/06	AP	
B103 01	9/21/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059

_____ SA-MA

----- COMMENTS AND NOTES -----

ADDRESS . . : 190 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . . : WOODSHIRE PARTNERS LLC #139 PHONE :
PARCEL . . . : 01-0536-04- -0028- -38-
APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
NURSERY RD, GO APPROX 5 MILES UTRNL EFT
INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
THEN LEFT ON ADVANCE GO TO WOOD POINT
LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06 9/08/06	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
B103 01	9/21/06 9/21/06	MR CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059
B103 02	9/25/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001278593

AP.MR

----- COMMENTS AND NOTES -----

ADDRESS : 190 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : WOODSHIRE PARTNERS LLC #139 PHONE :
PARCEL : 01-0536-04- -0028- -38-
APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
NURSERY RD GO APPROX 5 MILES UTRNL EFT
INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
THEN LEFT ON ADVANCE GO TO WOOD POINT
LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06 9/08/06	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
B103 01	9/21/06 9/21/06	MR CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059
B103 02	9/25/06 9/25/06	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001278593
P309 01	10/31/06	TI	R*PLUMB UNDER SLAB VRU #: 001301022

DA MK

COMMENTS AND NOTES

DO NOT REMOVE!

Harnett County Inspection Department

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: Carrness Date: 10-31-06

Address: 190 Wood Point

Lot No.: 139 Permit No.: _____

(Check Box for Violation)

- | | | | | | | | |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg. | <input type="checkbox"/> Elec. | <input type="checkbox"/> Plumb. | <input type="checkbox"/> Mech. | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other | |

Violations Found: _____

1) 3" horizontal Regd
by Plumbing code
as of July 1, 2006

2) No water in Riser

Code Enforcement Official

Signature Mike Rca

Date: _____

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS . : 190 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : WOODSHIRE PARTNERS LLC #139 PHONE :
PARCEL . . : 01-0536-04- -0028- -38-
APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
NURSERY RD GO APPROX 5 MILES UTRNL EFT
INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
THEN LEFT ON ADVANCE GO TO WOOD POINT
LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06 9/08/06	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
B103 01	9/21/06 9/21/06	MR CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059
B103 02	9/25/06 9/25/06	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001278593
P309 01	10/31/06 10/31/06	MR DA	R*PLUMB UNDER SLAB VRU #: 001301022 3" horizontal requird at washer drain
P309 02	11/06/06	TI AP-MR	R*PLUMB UNDER SLAB VRU #: 001303994

----- COMMENTS AND NOTES -----

ADDRESS : 190 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : WOODSHIRE PARTNERS LLC #139 PHONE :
PARCEL : 01-0536-04- -0028- -38-
APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
NURSERY RD GO APPROX 5 MILES UTRNL EFT
INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
THEN LEFT ON ADVANCE GO TO WOOD POINT
LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
	9/08/06	AP	
B103 01	9/21/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059
	9/21/06	CA	
B103 02	9/25/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001278593
	9/25/06	AP	
P309 01	10/31/06	MR	R*PLUMB UNDER SLAB VRU #: 001301022
	10/31/06	DA	3" horizontal requird at washer drain
P309 02	11/06/06	MR	R*PLUMB UNDER SLAB VRU #: 001303994
	11/06/06	AP	
B111 01	11/13/06	TI	R*BLDG SLAB INSP VRU #: 001306517

AP-MR

COMMENTS AND NOTES

ADDRESS : 190 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC #139 PHONE :
 PARCEL : 01-0536-04- -0028- -38-
 APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
 NURSERY RD GO APPROX 5 MILES UTRNL EFT
 INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
 THEN LEFT ON ADVANCE GO TO WOOD POINT
 LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
	9/08/06	AP	
B103 01	9/21/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059
	9/21/06	CA	
B103 02	9/25/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001278593
	9/25/06	AP	
P309 01	10/31/06	MR	R*PLUMB UNDER SLAB VRU #: 001301022
	10/31/06	DA	3" horizontal requird at washer drain
P309 02	11/06/06	MR	R*PLUMB UNDER SLAB VRU #: 001303994
	11/06/06	AP	
B111 01	11/13/06	MR	R*BLDG SLAB INSP VRU #: 001306517
	11/13/06	AP	
B103 03	11/16/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001309177
	11/16/06	CA	already done
H824 01	1/03/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001332238
	1/04/07	AP	
R425 01	1/05/07	MR	FOUR TRADE ROUGH IN VRU #: 001332677
	1/05/07	DA	plumbing pipes not in wall supply floor joist layout and plan floor joists not supported at center by header alk around brickmold and flash all openings siding not nailed on spots sheathing not spaced beath inside of wing walls nail 2nd floor to 1st with 1-16# @ 16"
R425 02	1/09/07	TI	FOUR TRADE ROUGH IN VRU #: 001333701

AP-MR

COMMENTS AND NOTES

ADDRESS : 190 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : WOODSHIRE PARTNERS LLC #139 PHONE :
PARCEL : 01-0536-04- -0028- -38-
APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
NURSERY RD GO APPROX 5 MILES UTRNL EFT
INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
THEN LEFT ON ADVANCE GO TO WOOD POINT
LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
	9/08/06	AP	
B103 01	9/21/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059
	9/21/06	CA	
B103 02	9/25/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001278593
	9/25/06	AP	
P309 01	10/31/06	MR	R*PLUMB UNDER SLAB VRU #: 001301022
	10/31/06	DA	3" horizontal requird at washer drain
P309 02	11/06/06	MR	R*PLUMB UNDER SLAB VRU #: 001303994
	11/06/06	AP	
B111 01	11/13/06	MR	R*BLDG SLAB INSP VRU #: 001306517
	11/13/06	AP	
B103 03	11/16/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001309177
	11/16/06	CA	already done
H824 01	1/03/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001332238
	1/04/07	AP	
R425 01	1/05/07	MR	FOUR TRADE ROUGH IN VRU #: 001332677
	1/05/07	DA	plumbing pipes not in wall supply floor joist layout and plan floor joists not supported at center by header caulk around brickmold and flash all openings siding not nailed on spots sheathing not spaced sheath inside of wing walls nail 2nd floor to 1st with 1-16# @ 16"
R425 02	1/09/07	MR	FOUR TRADE ROUGH IN VRU #: 001333701
	1/09/07	AP	
A814 01	1/12/07	TI	ADDRESS CONFIRMATION VRU #: 001335736
	1/11/07	AP	190 WOOD POINT CT LOT 139
I129 01	1/12/07	TI	R*INSULATION INSPECTION VRU #: 001335744
R425 03	1/12/07	TI	FOUR TRADE ROUGH IN VRU #: 001335718
	1/11/07	CA	

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 190 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC #139 PHONE :
 PARCEL : 01-0536-04- -0028- -38-
 APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
 NURSERY RD GO APPROX 5 MILES UTRNL EFT
 INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
 THEN LEFT ON ADVANCE GO TO WOOD POINT
 LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
	9/08/06	AP	
B103 01	9/21/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059
	9/21/06	CA	
B103 02	9/25/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001278593
	9/25/06	AP	
P309 01	10/31/06	MR	R*PLUMB UNDER SLAB VRU #: 001301022
	10/31/06	DA	3" horizontal requird at washer drain
P309 02	11/06/06	MR	R*PLUMB UNDER SLAB VRU #: 001303994
	11/06/06	AP	
B111 01	11/13/06	MR	R*BLDG SLAB INSP VRU #: 001306517
	11/13/06	AP	
B103 03	11/16/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001309177
	11/16/06	CA	already done
H824 01	1/03/07	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001332238
	1/04/07	AP	
R425 01	1/05/07	MR	FOUR TRADE ROUGH IN VRU #: 001332677
	1/05/07	DA	plumbing pipes not in wall supply floor joist layout and plan floor joists not supported at center by header caulk around brickmold and flash all openings sidinig not nailed on spots sheathing not spaced sheath inside of wing walls nail 2nd floor to 1st with 1-16# @ 16"
R425 02	1/09/07	MR	FOUR TRADE ROUGH IN VRU #: 001333701
	1/09/07	AP	
A814 01	1/12/07	TI	ADDRESS CONFIRMATION VRU #: 001335736
	1/11/07	AP	✓ 190 WOOD POINT CT LOT 139
I129 01	1/12/07	MR	R*INSULATION INSPECTION VRU #: 001335744
	1/12/07	AP	
R425 03	1/12/07	TI	FOUR TRADE ROUGH IN VRU #: 001335718
	1/11/07	CA	
R429 01	4/05/07	TI	FOUR TRADE FINAL VRU #: 001384433

4-5-7 DA-CE

ADDRESS : 190 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC #139 PHONE :
 PARCEL : 01-0536-04- -0028- -38-
 APPL NUMBER: 06-50015320 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 FROM LILLINGOTN TURN LEFT ONTO
 NURSERY RD GO APPROX 5 MILES UTRNL EFT
 INTO WOODSHIRE S/D TURN RIGHT ON DUNBAR
 THEN LEFT ON ADVANCE GO TO WOOD POINT
 LOT 139 JB

STRUCTURE: 000 000 56X46 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/08/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001269674
	9/08/06	AP	
B103 01	9/21/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001277059
	9/21/06	CA	
B103 02	9/25/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001278593
	9/25/06	AP	
P309 01	10/31/06	MR	R*PLUMB UNDER SLAB VRU #: 001301022
	10/31/06	DA	3" horizontal requird at washer drain
P309 02	11/06/06	MR	R*PLUMB UNDER SLAB VRU #: 001303994
	11/06/06	AP	
B111 01	11/13/06	MR	R*BLDG SLAB INSP VRU #: 001306517
	11/13/06	AP	
B103 03	11/16/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001309177
	11/16/06	CA	already done
H824 01	1/03/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001332238
	1/04/07	AP	
R425 01	1/05/07	MR	FOUR TRADE ROUGH IN VRU #: 001332677
	1/05/07	DA	plumbing pipes not in wall supply floor joist layout and plan floor joists not supported at center by header caulk around brickmold and flash all openings sidinig not nailed on spots sheathing not spaced sheath inside of wing walls nail 2nd floor to 1st with 1-16# @ 16"
R425 02	1/09/07	MR	FOUR TRADE ROUGH IN VRU #: 001333701
	1/09/07	AP	
A814 01	1/12/07	TI	ADDRESS CONFIRMATION VRU #: 001335736
	1/11/07	AP	✓190 WOOD POINT CT LOT 139
I129 01	1/12/07	MR	R*INSULATION INSPECTION VRU #: 001335744
	1/12/07	AP	
R425 03	1/12/07	TI	FOUR TRADE ROUGH IN VRU #: 001335718
	1/11/07	CA	
R429 01	4/05/07	CF	FOUR TRADE FINAL VRU #: 001384433
	4/05/07	DA	Finala DA 1) Seal toilets and pedastal sink 2) Seal around water heater cable and secure 3) Seal floor in bonus room at walla 4) Secure smoke detector in up BR 5) Add bracket to stair rail
R429 02	4/13/07	TI	FOUR TRADE FINAL VRU #: 001388732

4-13-7 AP-GE

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>Res. SFD</u>	Conditional Use Permit No.: _____
Type of Construction: <u>—</u>	Building Permit No.: <u>06-50015320</u>
Owner of Building: <u>CAVINESS</u>	Electrical Permit No.: <u>''</u>
Building Address: <u>120 Wood Point Dr.</u>	Insulation Permit No.: <u>''</u>
Zoning District: _____	Plumbing Permit No.: <u>''</u>
Zoning Permit No.: _____	Mech. Permit No.: <u>''</u>
Date: <u>4-13-7</u>	Envir. C.O. No.: _____
<u>C. Edgerly</u> Building Official	_____ Zoning Official