

August 24, 2006

Caviness Land Dev.
2818 Raeford Rd. Suite 200
Fayetteville, NC 28303

Re: Status of Improvement Permit Application #06-5-15411


Dear To Whom It May Concern,

On , 2006, an Environmental Health Specialist from the Harnett County Health Department attempted to evaluate your property for the purpose of issuing an Improvement Permit. This individual was unable to evaluate your property for one or more of the following reasons.

- 1. Property lines/corners not marked or labeled
- 2. House corners not marked or labeled
- 3. Directions not clear to property
- 4. Property needs brush or vegetation removed
- 5. Backhoe pits required
- 6. Other – House must be three bedrooms. Please submit changes to Central Permitting.

When you have completed this, please call 910-893-7527 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Joe West, R. S.
Environmental Health Specialist
Harnett County Department of Public Health

JW/ss

Copy: Central Permitting