
ADDRESS . : 165 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
PARCEL . . : 01-0536-04- -0028- -48-
APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : WOODSHIRE LOT 149
27W TURN L ON NURSERY TURN L ON WOOD
POINT DR
T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	TI <i>AP-mR</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573

----- COMMENTS AND NOTES -----

ADDRESS . . : 165 WOOD POINT DR
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER . . . : CAVINESS LAND DEV #149
 PARCEL . . . : 01-0536-04- -0028- -48-
 APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WOODSHIRE LOT 149
 27W TURN L ON NURSERY TURN L ON WOOD
 POINT DR
 T/S: 07/20/2006 10:18 AM JDAVIS ----

SUBDIV: WOODSHIRE
 PHONE : (919) 481-0503
 PHONE : (910) 481-0503

STRUCTURE: 000 000 49X52 3BR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
	11/07/06	AP	
B103 01	11/17/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067

 DA-Waf

COMMENTS AND NOTES

ADDRESS . : 165 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
PARCEL . . : 01-0536-04- -0028- -48-
APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE LOT 149
27W TURN L ON NURSERY TURN L ON WOOD
POINT DR
T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP, RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06 11/07/06	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
B103 01	11/17/06 11/17/06	MR DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067 foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06 <u>11-21-06</u>	TI <u>AP CE</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806

----- COMMENTS AND NOTES -----

ADDRESS . : 165 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
PARCEL . . : 01-0536-04- -0028- -48-
APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE LOT 149
27W TURN L ON NURSERY TURN L ON WOOD
POINT DR
T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06 11/07/06	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
B103 01	11/17/06 11/17/06	MR DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067 foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06 11/21/06	CE AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806
P309 01	12/19/06	TI	R*PLUMB UNDER SLAB VRU #: 001325621

_____ *AP-MR*

----- COMMENTS AND NOTES -----

ADDRESS . : 165 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
PARCEL . . : 01-0536-04- -0028- -48-
APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE LOT 149
27W TURN L ON NURSERY TURN L ON WOOD
POINT DR
T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
	11/07/06	AP	
B103 01	11/17/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067
	11/17/06	DA	foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806
	11/21/06	AP	
P309 01	12/19/06	MR	R*PLUMB UNDER SLAB VRU #: 001325621
	12/19/06	AP	
B111 01	12/20/06	MR	R*BLDG SLAB INSP VRU #: 001326372
	12/20/06	CA	
B111 02	12/21/06	TI	R*BLDG SLAB INSP VRU #: 001327745

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . : 165 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
PARCEL . . : 01-0536-04- -0028- -48-
APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE LOT 149
27W TURN L ON NURSERY TURN L ON WOOD
POINT DR
T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
	11/07/06	AP	
B103 01	11/17/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067
	11/17/06	DA	foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806
	11/21/06	AP	
P309 01	12/19/06	MR	R*PLUMB UNDER SLAB VRU #: 001325621
	12/19/06	AP	
B111 01	12/20/06	MR	R*BLDG SLAB INSP VRU #: 001326372
	12/20/06	CA	
B111 02	12/21/06	MR	R*BLDG SLAB INSP VRU #: 001327745
	12/21/06	AP	
A814 01	2/22/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358217
	2/26/07	AP	165 Wood Point Dr Lot 149
R425 01	2/27/07	TI	FOUR TRADE ROUGH IN VRU #: 001361699

2-27-07 DA-CE

COMMENTS AND NOTES

- no gas pressure
- low water pressure
- no water in drain test
OK for Siding & ins.

ADDRESS : 165 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
 PARCEL : 01-0536-04- -0028- -48-
 APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : WOODSHIRE LOT 149
 27W TURN L ON NURSERY TURN L ON WOOD
 POINT DR
 T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
	11/07/06	AP	
B103 01	11/17/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067
	11/17/06	DA	foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806
	11/21/06	AP	
P309 01	12/19/06	MR	R*PLUMB UNDER SLAB VRU #: 001325621
	12/19/06	AP	
B111 01	12/20/06	MR	R*BLDG SLAB INSP VRU #: 001326372
	12/20/06	CA	
B111 02	12/21/06	MR	R*BLDG SLAB INSP VRU #: 001327745
	12/21/06	AP	
A814 01	2/22/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358217
	2/26/07	AP	165 Wood Point Dr Lot 149
R425 01	2/27/07	CE	FOUR TRADE ROUGH IN VRU #: 001361699
	2/27/07	DA	1) No gas pressure 2) low water pressure 3) No water in drain test OK for siding and insulation. ce
I129 01	3/01/07	TI	R*INSULATION INSPECTION VRU #: 001363580
	<u>3-1-7</u>	<u>Ap/ce</u>	
R425 02	3/01/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001363613
	<u>3-1-7</u>	<u>Ap/ce</u>	

COMMENTS AND NOTES

ADDRESS . : 165 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
PARCEL . . : 01-0536-04- -0028- -48-
APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE LOT 149
27W TURN L ON NURSERY TURN L ON WOOD
POINT DR
T/S: 07/20/2006 10:18 AM JDAVIS -----

STRUCTURE: 000 000 49X52 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
	11/07/06	AP	
B103 01	11/17/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067
	11/17/06	DA	foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806
	11/21/06	AP	
P309 01	12/19/06	MR	R*PLUMB UNDER SLAB VRU #: 001325621
	12/19/06	AP	
B111 01	12/20/06	MR	R*BLDG SLAB INSP VRU #: 001326372
	12/20/06	CA	
B111 02	12/21/06	MR	R*BLDG SLAB INSP VRU #: 001327745
	12/21/06	AP	
A814 01	2/22/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358217
	2/26/07	AP	✓165 Wood Point Dr Lot 149
R425 01	2/27/07	CE	FOUR TRADE ROUGH IN VRU #: 001361699
	2/27/07	DA	1) No gas pressure 2) low water pressure 3) No water in drain test OK for siding and insulation. ce
I129 01	3/01/07	CE	R*INSULATION INSPECTION VRU #: 001363580
	3/01/07	AP	
R425 02	3/01/07	CE	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001363613
	3/01/07	AP	
H824 01	3/27/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001380161
	3/27/07	AP	
R431 01	4/23/07	TI	FOUR TRADE FINAL >2500 VRU #: 001395011

DA JH

----- COMMENTS AND NOTES -----

ADDRESS : 165 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
 PARCEL : 01-0536-04- -0028- -48-
 APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WOODSHIRE LOT 149
 27W TURN L ON NURSERY TURN L ON WOOD
 POINT DR
 T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
	11/07/06	AP	
B103 01	11/17/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067
	11/17/06	DA	foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806
	11/21/06	AP	
P309 01	12/19/06	MR	R*PLUMB UNDER SLAB VRU #: 001325621
	12/19/06	AP	
B111 01	12/20/06	MR	R*BLDG SLAB INSP VRU #: 001326372
	12/20/06	CA	
B111 02	12/21/06	MR	R*BLDG SLAB INSP VRU #: 001327745
	12/21/06	AP	
A814 01	2/22/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358217
	2/26/07	AP	✓165 Wood Point Dr Lot 149
R425 01	2/27/07	CE	FOUR TRADE ROUGH IN VRU #: 001361699
	2/27/07	DA	1) No gas pressure 2) low water pressure 3) No water in drain test OK for siding and insulation. ce
I129 01	3/01/07	CE	R*INSULATION INSPECTION VRU #: 001363580
	3/01/07	AP	
R425 02	3/01/07	CE	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001363613
	3/01/07	AP	
H824 01	3/27/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001380161
	3/27/07	AP	
R431 01	4/23/07	JH	FOUR TRADE FINAL >2500 VRU #: 001395011
	4/23/07	DA	House not ready.
R431 02	4/24/07	TI	FOUR TRADE FINAL >2500 VRU #: 001395698

DP-HR

COMMENTS AND NOTES

ADDRESS . : 165 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
PARCEL . . : 01-0536-04- -0028- -48-
APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE LOT 149
27W TURN L ON NURSERY TURN L ON WOOD
POINT DR
T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
	11/07/06	AP	
B103 01	11/17/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067
	11/17/06	DA	foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806
	11/21/06	AP	
P309 01	12/19/06	MR	R*PLUMB UNDER SLAB VRU #: 001325621
	12/19/06	AP	
B111 01	12/20/06	MR	R*BLDG SLAB INSP VRU #: 001326372
	12/20/06	CA	
B111 02	12/21/06	MR	R*BLDG SLAB INSP VRU #: 001327745
	12/21/06	AP	
A814 01	2/22/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358217
	2/26/07	AP	✓ 165 Wood Point Dr Lot 149
R425 01	2/27/07	CE	FOUR TRADE ROUGH IN VRU #: 001361699
	2/27/07	DA	1) No gas pressure 2) low water pressure 3) No water in drain test OK for siding and insulation. ce
I129 01	3/01/07	CE	R*INSULATION INSPECTION VRU #: 001363580
	3/01/07	AP	
R425 02	3/01/07	CE	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001363613
	3/01/07	AP	
H824 01	3/27/07	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001380161
	3/27/07	AP	
R431 01	4/23/07	JH	FOUR TRADE FINAL >2500 VRU #: 001395011
	4/23/07	DA	House not ready.
R431 02	4/24/07	MR	FOUR TRADE FINAL >2500 VRU #: 001395698
	4/24/07	DP	1. elevate water heater and protect 2. AHU in attic not finished
R431 03	4/25/07	TI	FOUR TRADE FINAL >2500 VRU #: 001397072
		CA-MR	VOICE MESSAGE LEFT

----- COMMENTS AND NOTES -----

ADDRESS : 165 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : CAVINESS LAND DEV #149 PHONE : (910) 481-0503
 PARCEL : 01-0536-04- -0028- -48-
 APPL NUMBER: 06-50015411 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : WOODSHIRE LOT 149
 27W TURN L ON NURSERY TURN L ON WOOD
 POINT DR
 T/S: 07/20/2006 10:18 AM JDAVIS ----

STRUCTURE: 000 000 49X52 3BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/07/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001304573
	11/07/06	AP	
B103 01	11/17/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310067
	11/17/06	DA	foundation missing footer in several places... must have min. 2" max. 8"
B103 02	11/21/06	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001310806
	11/21/06	AP	
P309 01	12/19/06	MR	R*PLUMB UNDER SLAB VRU #: 001325621
	12/19/06	AP	
B111 01	12/20/06	MR	R*BLDG SLAB INSP VRU #: 001326372
	12/20/06	CA	
B111 02	12/21/06	MR	R*BLDG SLAB INSP VRU #: 001327745
	12/21/06	AP	
A814 01	2/22/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358217
	2/26/07	AP	✓165 Wood Point Dr Lot 149
R425 01	2/27/07	CE	FOUR TRADE ROUGH IN VRU #: 001361699
	2/27/07	DA	1) No gas pressure 2) low water pressure 3) No water in drain test OK for siding and insulation. ce
I129 01	3/01/07	CE	R*INSULATION INSPECTION VRU #: 001363580
	3/01/07	AP	
R425 02	3/01/07	CE	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001363613
	3/01/07	AP	
H824 01	3/27/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001380161
	3/27/07	AP	
R431 01	4/23/07	JH	FOUR TRADE FINAL >2500 VRU #: 001395011
	4/23/07	DA	House not ready.
R431 02	4/24/07	MR	FOUR TRADE FINAL >2500 VRU #: 001395698
	4/24/07	DP	✗elevate water heater and protect 2. AHU in attic not finished
R431 03	4/25/07	MR	FOUR TRADE FINAL >2500 VRU #: 001397072
	4/25/07	CA	VOICE MESSAGE LEFT
R431 04	4/26/07	TI	FOUR TRADE FINAL >2500 VRU #: 001398259

AP JH

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF COMPLIANCE**

This certificate issued pursuant to the requirements of Section 307 of the North Carolina Administration Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: _____

Conditional Use Permit No.: _____

Type of Construction: _____

Building Permit No.: 06-50015411

Owner of Building: Coviness Land Devel.

Electrical Permit No.: _____

Building Address: 165 Wood Point Dr

Insulation Permit No.: _____

Zoning District: _____

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: _____

Date: 4-26-07

Envir. C.O. No.: _____

James T. Hall
Building Official

Zoning Official