## HTE# 06-500 15467 Harriett County Department of Public nealth 23246

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 1108 Regency Homes

REPAIR | EXPANSION | SUBDIVISION YORKININE Plantation LOT # 158 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SFO (58 x 38) 3 BR Proposed Wastewater System Type: 25% Reduction System Projected Daily Flow: 360 GPD Number of Occupants: Number of bedrooms: Basement ☐Yes ☑ No Pump Required: □Yes No ☐ May be required based on final location and elevations of facilities Type of Water Supply: 
Community Public Well Distance from well 50 feet Five years Permit conditions: STUB O-t Phanting shallow - maintain All set Backs ☐ No expiration Authorized State Agent:

Date: 10-16-06

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is Abject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958 and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: 1/28
SUBDIVISION YORKIHIM Plantation LOT # 158 ISSUED TO: Regency Homes Facility Type: SFO (58×38) 3 BR & New 

Expansion 

Repair Basement? 

Yes 

No Basement Fixtures? 

Yes ≥ No Wastewater Flow: 365 GPD Type of Wastewater System\*\* 25% Red. Sytm (Initial) (See note below, if applicable 

) Installation Requirements/Conditions Exact length of each trench / × 153 feet Trench Spacing: 7 Feet on Center Spacing: 6 inches Septic Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: 18 a inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. inches below pipe Aggregate Depth: inches above pipe Conditions: inches total I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. \*\* If applicable: Owner/Legal Representative Signature: \_ This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Construction Authorization Expiration Date: 10-16-2011 Authorized State Agent: \

HTE# 06-500 555

Permit # 23246

## Harnett County Department of Public Health Site Sketch

ISSUED TO: Regency Homes	PROPERTY LOCATO	N: 1108 Yorkshire	Plantation	LOT # 158
Authorized State Agent:		Date:	10-16-0	6 128
STUB Out Plumbing shallow	where	Shown - f	it ground le	vel or higher
Maintain All Set Backs				
14 Lue 75				
37x 1 150' of 25% Reduction	system			

