

November 16, 2006

Matt Lowe
H & H Constructors
2919 Freezewood Avenue
Fayetteville, NC 27303


Dear Mr. Lowe:

Per our conversation, I have reviewed the "Baker" plan to address the construction of the lug footings shown on the monolithic foundation plan.

The grade beams shown on the plan are to be constructed using 16" x 9" thickened slabs per detail 4- DET on washed stone, compacted fill, or undisturbed soil with a minimum bearing capacity rating of 2000 psf.


Please call me if you have any questions.

Sincerely,




J. Scott Thompson, P.E.

JST/jpw



11/16/06

1033 Wade Avenue Suite 104
Raleigh, NC 27606
(919) 789-9915 OFFICE
(919) 789-9921 FAX



ADDRESS . : 120 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER . . : H & H CONSTRUCTOR INC #144 PHONE : (910) 486-4864
PARCEL . . : 01-0536-04- -0028- -43-
APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
144 JB

STRUCTURE: 000 000 42X53 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 11/14/06 | TI | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 |

DA-MR

----- COMMENTS AND NOTES -----

*OK to pour perimeter
but I need letter
on "Lug" area*

ADDRESS : 120 WOOD POINT DR
 CONTRACTOR : H & H CONSTRUCTORS INC
 OWNER : H & H CONSTRUCTOR INC #144
 PARCEL : 01-0536-04- -0028- -43-
 APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
 ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
 144 JB

SUBDIV: WOODSHIRE
 PHONE :
 PHONE : (910) 486-4864

STRUCTURE: 000 000 42X53 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 11/14/06 11/14/06 | MR DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 plan calls for footer... builder says its a lug footer ... must provide letter from plan engineer or install footer to code |
| B101 02 | 11/17/06 11/17/06 | MR AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001310021 |
| B103 01 | 11/20/06 11/20/06 | MR CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001310922 |
| B103 02 | 11/21/06 11/21/06 | TI CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312001 |
| A814 01 | 11/27/06 11/20/06 | TI AP | ADDRESS CONFIRMATION VRU #: 001310977 120 WOOD POINT DR LOT 144 |
| B103 03 | 11/27/06 | TI | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312948 |

AP MR

----- COMMENTS AND NOTES -----

ADDRESS . : 120 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER . . : H & H CONSTRUCTOR INC #144 PHONE : (910) 486-4864
PARCEL . . : 01-0536-04- -0028- -43-
APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
144 JB

STRUCTURE: 000 000 42X53 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 11/14/06 11/14/06 | MR DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 plan calls for footer... builder says its a lug footer ... must provide letter from plan engineer or install footer to code |
| B101 02 | 11/17/06 11/17/06 | MR AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001310021 |
| B103 01 | 11/20/06 11/20/06 | MR CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001310922 |
| B103 02 | 11/21/06 11/21/06 | TI CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312001 |
| A814 01 | 11/27/06 11/20/06 | TI AP | ADDRESS CONFIRMATION VRU #: 001310977 120 WOOD POINT DR LOT 144 |
| B103 03 | 11/27/06 11/27/06 | MR AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312948 |
| P309 01 | 11/29/06 | TI | R*PLUMB UNDER SLAB VRU #: 001314857 |

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 120 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER : H & H CONSTRUCTOR INC #144 PHONE : (910) 486-4864
PARCEL : 01-0536-04- -0028- -43-
APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
144 JB

STRUCTURE: 000 000 42X53 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------------------|----------------|--|
| B101 01 | 11/14/06 11/14/06 | MR DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 plan calls for footer... builder says its a lug footer ... must provide letter from plan engineer or install footer to code |
| B101 02 | 11/17/06 11/17/06 | MR AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001310021 |
| B103 01 | 11/20/06 11/20/06 | MR CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001310922 |
| B103 02 | 11/21/06 11/21/06 | TI CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312001 |
| A814 01 | 11/27/06 11/20/06 | TI AP | ADDRESS CONFIRMATION VRU #: 001310977 120 WOOD POINT DR LOT 144 |
| B103 03 | 11/27/06 11/27/06 | MR AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312948 |
| P309 01 | 11/29/06 11/29/06 | MR AP | R*PLUMB UNDER SLAB VRU #: 001314857 |
| B111 01 | 11/30/06 11/30/06 | MR AP | R*BLDG SLAB INSP VRU #: 001315650 |
| R425 01 | 1/17/07 <u>1-17-07 DA-CE</u> | TI | FOUR TRADE ROUGH IN VRU #: 001338519 |

----- COMMENTS AND NOTES -----

DO NOT REMOVE!

Harnett County Inspection Department

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: H + H Date: 1-17-07

Address: 120 Wood Point

Lot No.: 144 Permit No.: 06-50015613

(Check Box for Violation)

- | | | | | | | | |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg. | <input type="checkbox"/> Elec. | <input type="checkbox"/> Plumb. | <input type="checkbox"/> Mech. | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other | |

Violations Found: MECH AP
ELEC AP

PLUMBING DIA

① No water or drain tests

BUILDING DIA

① Fire caulk blue wires @ trip plate (kitchen)

② Nail plate - front corner LR (green wire)

③ Fire block under stairs above plumbing

④ Fire block duct chase upstairs

OK FOR SIDING

DO NOT INSULATE

Code Enforcement Official
Signature C. Edger

Date: 1-17-07

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS : 120 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER : H & H CONSTRUCTOR INC #144 PHONE : (910) 486-4864
PARCEL : 01-0536-04- -0028- -43-
APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
144 JB

STRUCTURE: 000 000 42X53 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|--------------------|--|
| B101 01 | 11/14/06 11/14/06 | MR DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 plan calls for footer... builder says its a lug footer ... must provide letter from plan engineer or install footer to code |
| B101 02 | 11/17/06 11/17/06 | MR AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001310021 |
| B103 01 | 11/20/06 11/20/06 | MR CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001310922 |
| B103 02 | 11/21/06 11/21/06 | TI CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312001 |
| A814 01 | 11/27/06 11/20/06 | TI AP | ADDRESS CONFIRMATION VRU #: 001310977 120 WOOD POINT DR LOT 144 |
| B103 03 | 11/27/06 11/27/06 | MR AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312948 |
| P309 01 | 11/29/06 11/29/06 | MR AP | R*PLUMB UNDER SLAB VRU #: 001314857 |
| B111 01 | 11/30/06 11/30/06 | MR AP | R*BLDG SLAB INSP VRU #: 001315650 |
| R425 01 | 1/17/07 1/17/07 | CE DA | FOUR TRADE ROUGH IN VRU #: 001338519 MECH. ELEC. AP PLUMBING DA 1) NO WATER OR DRAIN TESTS BUILDING DA 1) FIRECAULK BLUE WIRES AT KITCHEN AND LR WALL 2) NAIL PLATE IN FRONT CORNER OF LR AT GREEN WIRE 3) FIREBLOCK UNDER STAIRS ABOVE PLUMBING 4) FIREBLOCK DUCT CHASE UPSTAIRS. OK FOR SIDING DO NOT INSULATE. CE |
| R425 02 | 1/24/07 | TI <i>AP-MR</i> | FOUR TRADE ROUGH IN VRU #: 001342014 |

----- COMMENTS AND NOTES -----

ADDRESS : 120 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER : H & H CONSTRUCTOR INC #144 PHONE : (910) 486-4864
PARCEL : 01-0536-04- -0028- -43-
APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
144 JB

STRUCTURE: 000 000 42X53 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 11/14/06 11/14/06 | MR DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 plan calls for footer... builder says its a lug footer ... must provide letter from plan engineer or install footer to code |
| B101 02 | 11/17/06 11/17/06 | MR AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001310021 |
| B103 01 | 11/20/06 11/20/06 | MR CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001310922 |
| B103 02 | 11/21/06 11/21/06 | TI CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312001 |
| A814 01 | 11/27/06 11/20/06 | TI AP | ADDRESS CONFIRMATION VRU #: 001310977 120 WOOD POINT DR LOT 144 |
| B103 03 | 11/27/06 11/27/06 | MR AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312948 |
| P309 01 | 11/29/06 11/29/06 | MR AP | R*PLUMB UNDER SLAB VRU #: 001314857 |
| B111 01 | 11/30/06 | TI | R*BLDG SLAB INSP VRU #: 001315650 |

AP-IVR

COMMENTS AND NOTES

ADDRESS : 120 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
 OWNER : H & H CONSTRUCTOR INC #144 PHONE : (910) 486-4864
 PARCEL : 01-0536-04- -0028- -43-
 APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
 ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
 144 JB

STRUCTURE: 000 000 42X53 3BDR

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 BASEMENT : NA
 PROPOSED USE : SFD SEPTIC - EXISTING? : NEW
 SEWER : UNKNOWN WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| B101 01 | 11/14/06 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 |
| | 11/14/06 | DA | plan calls for footer... builder says its a lug footer ... must provide letter from plan engineer or install footer to code |
| B101 02 | 11/17/06 | MR | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001310021 |
| | 11/17/06 | AP | |
| B103 01 | 11/20/06 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001310922 |
| | 11/20/06 | CA | |
| B103 02 | 11/21/06 | TI | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312001 |
| | 11/21/06 | CA | |
| A814 01 | 11/27/06 | TI | ADDRESS CONFIRMATION VRU #: 001310977 |
| | 11/20/06 | AP | 120 WOOD POINT DR LOT 144 |
| B103 03 | 11/27/06 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312948 |
| | 11/27/06 | AP | |
| P309 01 | 11/29/06 | MR | R*PLUMB UNDER SLAB VRU #: 001314857 |
| | 11/29/06 | AP | |
| B111 01 | 11/30/06 | MR | R*BLDG SLAB INSP VRU #: 001315650 |
| | 11/30/06 | AP | |
| R425 01 | 1/17/07 | CE | FOUR TRADE ROUGH IN VRU #: 001338519 |
| | 1/17/07 | DA | MECH. ELEC. AP PLUMBING DA 1) NO WATER OR DRAIN TESTS BUILDING DA 1) FIRECAULK BLUE WIRES AT KITCHEN AND LR WALL 2) NAIL PLATE IN FRONT CORNER OF LR AT GREEN WIRE 3) FIREBLOCK UNDER STAIRS ABOVE PLUMBING 4) FIREBLOCK DUCT CHASE UPSTAIRS. OK FOR SIDING DO NOT INSULATE. CE |
| R425 02 | 1/24/07 | MR | FOUR TRADE ROUGH IN VRU #: 001342014 |
| | 1/24/07 | AP | |
| I129 01 | 1/29/07 | MR | R*INSULATION INSPECTION VRU #: 001344888 |
| | 1/29/07 | DA | no insul under platform |
| I129 02 | 1/31/07 | TI | R*INSULATION INSPECTION VRU #: 001346207 |

AP - MR

ADDRESS . : 120 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER . . : H & H CONSTRUCTOR INC #144 PHONE : (910) 486-4864
PARCEL . . : 01-0536-04- -0028- -43-
APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
144 JB

STRUCTURE: 000 000 42X53 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 11/14/06 11/14/06 | MR DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 plan calls for footer... builder says its a lug footer ... must provide letter from plan engineer or install footer to code |
| B101 02 | 11/17/06 11/17/06 | MR AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001310021 |
| B103 01 | 11/20/06 11/20/06 | MR CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001310922 |
| B103 02 | 11/21/06 11/21/06 | TI CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312001 |
| A814 01 | 11/27/06 11/20/06 | TI AP | ADDRESS CONFIRMATION VRU #: 001310977 120 WOOD POINT DR LOT 144 |
| B103 03 | 11/27/06 11/27/06 | MR AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312948 |
| P309 01 | 11/29/06 11/29/06 | MR AP | R*PLUMB UNDER SLAB VRU #: 001314857 |
| B111 01 | 11/30/06 11/30/06 | MR AP | R*BLDG SLAB INSP VRU #: 001315650 |
| R425 01 | 1/17/07 1/17/07 | CE DA | FOUR TRADE ROUGH IN VRU #: 001338519 MECH. ELEC. AP PLUMBING DA 1) NO WATER OR DRAIN TESTS BUILDING DA 1) FIRECAULK BLUE WIRES AT KITCHEN AND LR WALL 2) NAIL PLATE IN FRONT CORNER OF LR AT GREEN WIRE 3) FIREBLOCK UNDER STAIRS ABOVE PLUMBING 4) FIREBLOCK DUCT CHASE UPSTAIRS. OK FOR SIDING DO NOT INSULATE. CE |
| R425 02 | 1/24/07 1/24/07 | MR AP | FOUR TRADE ROUGH IN VRU #: 001342014 |
| I129 01 | 1/29/07 | TI | R*INSULATION INSPECTION VRU #: 001344888 |

DA-MR

No insul. under AHU platform

COMMENTS AND NOTES

ADDRESS . . : 120 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
 OWNER . . : H & H CONSTRUCTOR INC #144 PHONE : (910) 486-4864
 PARCEL . . : 01-0536-04- -0028- -43-
 APPL NUMBER: 06-50015613 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
 ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
 144 JB

STRUCTURE: 000 000 42X53 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 11/14/06 11/14/06 | MR DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001307543 plan calls for footer... builder says its a lug footer ... must provide letter from plan engineer or install footer to code |
| B101 02 | 11/17/06 11/17/06 | MR AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001310021 |
| B103 01 | 11/20/06 11/20/06 | MR CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001310922 |
| B103 02 | 11/21/06 11/21/06 | TI CA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312001 |
| A814 01 | 11/27/06 11/20/06 | TI AP | ADDRESS CONFIRMATION VRU #: 001310977 ✓ 120 WOOD POINT DR LOT 144 |
| B103 03 | 11/27/06 11/27/06 | MR AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001312948 |
| P309 01 | 11/29/06 11/29/06 | MR AP | R*PLUMB UNDER SLAB VRU #: 001314857 |
| B111 01 | 11/30/06 11/30/06 | MR AP | R*BLDG SLAB INSP VRU #: 001315650 |
| R425 01 | 1/17/07 1/17/07 | CE DA | FOUR TRADE ROUGH IN VRU #: 001338519 MECH. ELEC. AP PLUMBING DA 1) NO WATER OR DRAIN TESTS BUILDING DA 1) FIRECAULK BLUE WIRES AT KITCHEN AND LR WALL 2) NAIL PLATE IN FRONT CORNER OF LR AT GREEN WIRE 3) FIREBLOCK UNDER STAIRS ABOVE PLUMBING 4) FIREBLOCK DUCT CHASE UPSTAIRS. OK FOR SIDING DO NOT INSULATE. CE |
| R425 02 | 1/24/07 1/24/07 | MR AP | FOUR TRADE ROUGH IN VRU #: 001342014 |
| I129 01 | 1/29/07 1/29/07 | MR DA | R*INSULATION INSPECTION VRU #: 001344888 no insul under platform |
| I129 02 | 1/31/07 1/31/07 | MR AP | R*INSULATION INSPECTION VRU #: 001346207 |
| H824 01 | 2/14/07 2/14/07 | JW AP | ✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001354844 |
| R429 01 | 3/26/07 | TI | FOUR TRADE FINAL VRU #: 001376861 |

3-26-7 AP-CE

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Res. SFD

Type of Construction: -

Owner of Building: H J H Constr.

Building Address: 120 Wood Pt.

Zoning District: -

Zoning Permit No.: -

Date: 3-26-07

C. Edge
Building Official

Conditional Use Permit No.: -

Building Permit No.: 06-50015613 ^{CE}

Electrical Permit No.: "

Insulation Permit No.: "

Plumbing Permit No.: "

Mech. Permit No.: "

Envir. C.O. No.: -

Zoning Official