

ADDRESS : 145 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER : H & H CONSTRUCTOR INC #150 PHONE : (910) 486-4864
PARCEL : 01-0536-04- -0028- -49-
APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
150 JB

STRUCTURE: 000 000 60X62 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07 <u>4-10-7</u>	TI <u>Ap ce</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058

COMMENTS AND NOTES

T-pole approved

ADDRESS : 145 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER : H & H CONSTRUCTOR INC #150 PHONE : (910) 486-4864
PARCEL : 01-0536-04- -0028- -49-
APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
150 JB

STRUCTURE: 000 000 60X62 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058
	4/10/07	AP	
B103 01	4/16/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388947

4-16-7 AP-CE

COMMENTS AND NOTES

ADDRESS : 145 WOOD POINT DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : H & H CONSTRUCTOR INC #150
PARCEL : 01-0536-04- -0028- -49-
APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
150 JB

SUBDIV: WOODSHIRE
PHONE :
PHONE : (910) 486-4864

STRUCTURE: 000 000 60X62 4BDR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 4.00

PROPOSED USE : SFD

SEWER : UNKNOWN

BASEMENT : NA

SEPTIC - EXISTING? : NEW

WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058
	4/10/07	AP	
B103 01	4/16/07	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388947
	4/16/07	AP	
P309 01	4/20/07	TI	R*PLUMB UNDER SLAB VRU #: 001393245

4-20-07 AP-CE

----- COMMENTS AND NOTES -----

ADDRESS . : 145 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER . . : H & H CONSTRUCTOR INC #150 PHONE : (910) 486-4864
PARCEL . . : 01-0536-04- -0028- -49-
APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
150 JB

STRUCTURE: 000 000 60X62 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058
	4/10/07	AP	
B103 01	4/16/07	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388947
	4/16/07	AP	
P309 01	4/20/07	CE	R*PLUMB UNDER SLAB VRU #: 001393245
	4/20/07	AP	
B111 01	4/24/07	TI	R*BLDG SLAB INSP VRU #: 001395760
A814 01	4/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001392530
	4/20/07	AP	145 Wood Point Dr Lot 150

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . : 145 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER . . : H & H CONSTRUCTOR INC #150 PHONE : (910) 486-4864
PARCEL . . : 01-0536-04- -0028- -49-
APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
150 JB

STRUCTURE: 000 000 60X62 4BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058
	4/10/07	AP	
B103 01	4/16/07	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388947
	4/16/07	AP	
P309 01	4/20/07	CE	R*PLUMB UNDER SLAB VRU #: 001393245
	4/20/07	AP	
B111 01	4/24/07	MR	R*BLDG SLAB INSP VRU #: 001395760
	4/24/07	AP	
A814 01	4/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001392530
	4/20/07	AP	145 Wood Point Dr Lot 150
R425 01	5/17/07	TI	FOUR TRADE ROUGH IN VRU #: 001411092

DAJH

----- COMMENTS AND NOTES -----

ADDRESS . : 145 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
 OWNER . . : H & H CONSTRUCTOR INC #150 PHONE : (910) 486-4864
 PARCEL . . : 01-0536-04- -0028- -49-
 APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
 ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
 150 JB

STRUCTURE: 000 000 60X62 4BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058
	4/10/07	AP	
B103 01	4/16/07	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388947
	4/16/07	AP	
P309 01	4/20/07	CE	R*PLUMB UNDER SLAB VRU #: 001393245
	4/20/07	AP	
B111 01	4/24/07	MR	R*BLDG SLAB INSP VRU #: 001395760
	4/24/07	AP	
A814 01	4/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001392530
	4/20/07	AP	145 Wood Point Dr Lot 150
R425 01	5/17/07	JH	FOUR TRADE ROUGH IN VRU #: 001411092
	5/17/07	DA	1)Nail all 2ply roof truss per truss drawing. 2)Flex duct for bath exhaust vents are 14'max. 3)Leak in 1 1/2" pvc vent pipe over right sink in the masterbath @ T. 4)Need to seal sleeve for drain line outside of foundation wall.
I129 01	5/21/07	TI	R*INSULATION INSPECTION VRU #: 001412242
		DA JH	
R425 02	5/21/07	TI	FOUR TRADE ROUGH IN VRU #: 001412536
		AP JH	

COMMENTS AND NOTES

ADDRESS . : 145 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER . . : H & H CONSTRUCTOR INC #150 PHONE : (910) 486-4864
PARCEL . . : 01-0536-04- -0028- -49-
APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
150 JB

STRUCTURE: 000 000 60X62 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058
	4/10/07	AP	
B103 01	4/16/07	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388947
	4/16/07	AP	
P309 01	4/20/07	CE	R*PLUMB UNDER SLAB VRU #: 001393245
	4/20/07	AP	
B111 01	4/24/07	MR	R*BLDG SLAB INSP VRU #: 001395760
	4/24/07	AP	
A814 01	4/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001392530
	4/20/07	AP	145 Wood Point Dr Lot 150
R425 01	5/17/07	JH	FOUR TRADE ROUGH IN VRU #: 001411092
	5/17/07	DA	1)Nail all 2ply roof truss per truss drawing. 2)Flex duct for bath exhaust vents are 14'max. 3)Leak in 1 1/2" pvc vent pipe over right sink in the masterbath @ T. 4)Need to seal sleeve for drain line outside of foundation wall.
I129 01	5/21/07	JH	R*INSULATION INSPECTION VRU #: 001412242
	5/21/07	DA	not ready
R425 02	5/21/07	JH	FOUR TRADE ROUGH IN VRU #: 001412536
	5/21/07	AP	
I129 02	5/24/07	TI	R*INSULATION INSPECTION VRU #: 001414188

AP-JH

----- COMMENTS AND NOTES -----

ADDRESS : 145 WOOD POINT DR SUBDIV: WOODSHIRE
CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
OWNER : H & H CONSTRUCTOR INC #150 PHONE : (910) 486-4864
PARCEL : 01-0536-04- -0028- -49-
APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
150 JB

STRUCTURE: 000 000 60X62 4BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 BASEMENT : NA
PROPOSED USE : SFD SEPTIC - EXISTING? : NEW
SEWER : UNKNOWN WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058
	4/10/07	AP	
B103 01	4/16/07	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388947
	4/16/07	AP	
P309 01	4/20/07	CE	R*PLUMB UNDER SLAB VRU #: 001393245
	4/20/07	AP	
B111 01	4/24/07	MR	R*BLDG SLAB INSP VRU #: 001395760
	4/24/07	AP	
A814 01	4/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001392530
	4/20/07	AP	145 Wood Point Dr Lot 150
R425 01	5/17/07	JH	FOUR TRADE ROUGH IN VRU #: 001411092
	5/17/07	DA	1)Nail all 2ply roof truss per truss drawing. 2)Flex duct for bath exhaust vents are 14'max. 3)Leak in 1 1/2" pvc vent pipe over right sink in the masterbath @ T. 4)Need to seal sleeve for drain line outside of foundation wall.
I129 01	5/21/07	JH	R*INSULATION INSPECTION VRU #: 001412242
	5/21/07	DA	not ready
R425 02	5/21/07	JH	FOUR TRADE ROUGH IN VRU #: 001412536
	5/21/07	AP	
I129 02	5/24/07	MR	R*INSULATION INSPECTION VRU #: 001414188
	5/24/07	AP	
H824 01	6/06/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001424530
	6/06/07	AP	
R429 01	7/05/07	TI	FOUR TRADE FINAL VRU #: 001441130

DA JH

COMMENTS AND NOTES

ADDRESS : 145 WOOD POINT DR SUBDIV: WOODSHIRE
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE :
 OWNER : H & H CONSTRUCTOR INC #150 PHONE : (910) 486-4864
 PARCEL : 01-0536-04- -0028- -49-
 APPL NUMBER: 06-50015616 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 27 TO NURSERY RD TURN LEFT ON
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
 ON WOODSHIRE DR INTO WOODSHIRE S/D LOT
 150 JB

STRUCTURE: 000 000 60X62 4BDR

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 BASEMENT : NA
 PROPOSED USE : SFD SEPTIC - EXISTING? : NEW
 SEWER : UNKNOWN WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/10/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001385058
	4/10/07	AP	
B103 01	4/16/07	CE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388947
	4/16/07	AP	
P309 01	4/20/07	CE	R*PLUMB UNDER SLAB VRU #: 001393245
	4/20/07	AP	
B111 01	4/24/07	MR	R*BLDG SLAB INSP VRU #: 001395760
	4/24/07	AP	
A814 01	4/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001392530
	4/20/07	AP	145 Wood Point Dr Lot 150
R425 01	5/17/07	JH	FOUR TRADE ROUGH IN VRU #: 001411092
	5/17/07	DA	1)Nail all 2ply roof truss per truss drawing. 2)Flex duct for bath exhaust vents are 14'max. 3)Leak in 1 1/2" pvc vent pipe over right sink in the masterbath @ T. 4)Need to seal sleeve for drain line outside of foundation wall.
I129 01	5/21/07	JH	R*INSULATION INSPECTION VRU #: 001412242
	5/21/07	DA	not ready
R425 02	5/21/07	JH	FOUR TRADE ROUGH IN VRU #: 001412536
	5/21/07	AP	
I129 02	5/24/07	MR	R*INSULATION INSPECTION VRU #: 001414188
	5/24/07	AP	
H824 01	6/06/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001424530
	6/06/07	AP	
R429 01	7/05/07	JH	FOUR TRADE FINAL VRU #: 001441130
	7/05/07	DA	need ladder for attic to check AHU
R429 02	7/09/07	TI	FOUR TRADE FINAL VRU #: 001442228

AP-14R

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>Res.</u>	Conditional Use Permit No.: _____
Type of Construction: <u>I</u>	Building Permit No.: <u>06-50015616</u>
Owner of Building: <u>H+H Constructor</u>	Electrical Permit No.: <u>11</u>
Building Address: <u>145 Wood Point</u>	Insulation Permit No.: <u>X</u>
Zoning District: _____	Plumbing Permit No.: <u>11</u>
Zoning Permit No.: _____	Mech. Permit No.: <u>11</u>
Date: <u>7-9-7</u>	Envir. C.O. No.: _____

Mike Ream
Building Official

Zoning Official