
ADDRESS . : 79 SAPPHIRE DR SUBDIV: LAUREL VALLEY
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . : D & D HOMES #48 PHONE : (910) 892-4345
PARCEL . . : 03-9589- - -1015- -46-
APPL NUMBER: 06-50015643 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 48. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
FIFTH LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 55X37.6 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06 <i>12-5-6</i>	TI <i>AP</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001318310

----- COMMENTS AND NOTES -----
FS

ADDRESS . . : 79 SAPPHIRE DR SUBDIV: LAUREL VALLEY
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . . : D & D HOMES #48 PHONE : (910) 892-4345
PARCEL . . . : 03-9589- - -1015- -46-
APPL NUMBER: 06-50015643 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 48. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
FIFTH LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 55X37.6 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06 12/05/06	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001318310
A814 01	12/13/06	TI	ADDRESS CONFIRMATION VRU #: 001322312
B103 01	12/13/06 <i>12.13.06</i>	TI <i>AP</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001322320

COMMENTS AND NOTES
J
B

ADDRESS : 79 SAPPHIRE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : D & D HOMES #48
PARCEL : 03-9589- - -1015- -46-
APPL NUMBER: 06-50015643 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 48. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
FIFTH LOT ON LEFT. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
PHONE : (910) 892-4345
PHONE : (910) 892-4345

STRUCTURE: 000 000 55X37.6 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001318310
	12/05/06	AP	
A814 01	12/13/06	TI	ADDRESS CONFIRMATION VRU #: 001322312
	12/13/06	AP	79 SAPPHIRE DR LOT 48
B103 01	12/13/06	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001322320
	12/13/06	AP	
P309 01	12/18/06	TI	R*PLUMB UNDER SLAB VRU #: 001324524

12-18-06 *AP*

COMMENTS AND NOTES

FS

ADDRESS . . : 79 SAPPHIRE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER . . . : D & D HOMES #48
PARCEL . . . : 03-9589- - -1015- -46-
APPL NUMBER: 06-50015643 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 48. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
FIFTH LOT ON LEFT. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
PHONE : (910) 892-4345
PHONE : (910) 892-4345

STRUCTURE: 000 000 55X37.6 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001318310
	12/05/06	AP	
A814 01	12/13/06	TI	ADDRESS CONFIRMATION VRU #: 001322312
	12/13/06	AP	79 SAPPHIRE DR LOT 48
B103 01	12/13/06	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001322320
	12/13/06	AP	
P309 01	12/18/06	TI	R*PLUMB UNDER SLAB VRU #: 001324524
B111 01	12/19/06	TI	R*BLDG SLAB INSP VRU #: 001325818
	<u>12-19-06</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

FS

ADDRESS : 79 SAPPHIRE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : D & D HOMES #48
PARCEL : 03-9589- - -1015- -46-
APPL NUMBER: 06-50015643 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 48. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
FIFTH LOT ON LEFT. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
PHONE : (910) 892-4345
PHONE : (910) 892-4345

STRUCTURE: 000 000 55X37.6 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001318310
	12/05/06	AP	
A814 01	12/13/06	TI	ADDRESS CONFIRMATION VRU #: 001322312
	12/13/06	AP	79 SAPPHIRE DR LOT 48
B103 01	12/13/06	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001322320
	12/13/06	AP	
P309 01	12/18/06	FS	R*PLUMB UNDER SLAB VRU #: 001324524
	12/18/06	AP	
B111 01	12/19/06	FS	R*BLDG SLAB INSP VRU #: 001325818
	12/19/06	AP	
R425 01	2/07/07	TT	FOUR TRADE ROUGH IN VRU #: 001349204

2-7-7 DA

COMMENTS AND NOTES

FS

235 PSI
DRAIN TEST

DO NOT REMOVE!

Harnett County Inspection Department

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: ALA Date: 2-7-7

Address: 79 SARAHITE

Lot No.: 48 Permit No.: 6-5-15543

(Check Box for Violation)

Footing

Foundation

Bldg.

Elec.

Plumb.

Mech.

Insul.

Floor Fram.

Floor Slab

MFG. Home

Modular

Damp/Water Proof.

Structural

Wall Sheath.

Other

Violations Found: FIRE STOP & FLASH ARDURA
BATH TUB & SHOWER DRAIN LISTS

SUPPORT PLUMBING VENT LINE MID-WAY OF WALL (AT END OF BATH TUB AT STAIRS)

Will Check on Insulation Inspection

Code Enforcement Official [Signature] Date: 2-7-7

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS : 79 SAPPHIRE DR SUBDIV: LAUREL VALLEY
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : D & D HOMES #48 PHONE : (910) 892-4345
PARCEL : 03-9589- - -1015- -46-
APPL NUMBER: 06-50015643 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 48. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
FIFTH LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 55X37.6 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001318310
	12/05/06	AP	
A814 01	12/13/06	TI	ADDRESS CONFIRMATION VRU #: 001322312
	12/13/06	AP	79 SAPPHIRE DR LOT 48
B103 01	12/13/06	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001322320
	12/13/06	AP	
P309 01	12/18/06	FS	R*PLUMB UNDER SLAB VRU #: 001324524
	12/18/06	AP	
B111 01	12/19/06	FS	R*BLDG SLAB INSP VRU #: 001325818
	12/19/06	AP	
R425 01	2/07/07	FS	FOUR TRADE ROUGH IN VRU #: 001349204
	2/07/07	DA	flashing around drain lines plumbing mid-way of walls
I129 01	2/12/07	TI	R*INSULATION INSPECTION VRU #: 001351972
	2-12-07	AP	
R427 01	2/12/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001351980
	2-12-07	AP	

COMMENTS AND NOTES

FS

ADDRESS : 79 SAPPHIRE DR SUBDIV: LAUREL VALLEY
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : D & D HOMES #48 PHONE : (910) 892-4345
PARCEL : 03-9589- - -1015- -46-
APPL NUMBER: 06-50015643 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : LAUREL VALLEY LOT 48. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
FIFTH LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 55X37.6 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001318310
	12/05/06	AP	
A814 01	12/13/06	TI	ADDRESS CONFIRMATION VRU #: 001322312
	12/13/06	AP	✓79 SAPPHIRE DR LOT 48
B103 01	12/13/06	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001322320
	12/13/06	AP	
P309 01	12/18/06	FS	R*PLUMB UNDER SLAB VRU #: 001324524
	12/18/06	AP	
B111 01	12/19/06	FS	R*BLDG SLAB INSP VRU #: 001325818
	12/19/06	AP	
R425 01	2/07/07	FS	FOUR TRADE ROUGH IN VRU #: 001349204
	2/07/07	DA	flashing around drain lines plumbing mid-way of walls
I129 01	2/12/07	FS	R*INSULATION INSPECTION VRU #: 001351972
	2/12/07	AP	
R427 01	2/12/07	FS	FOUR TRADE ROUGH IN >2500 VRU #: 001351980
	2/12/07	AP	
H824 01	4/03/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001384403
	4/03/07	AP	
R429 01	5/07/07	TI	FOUR TRADE FINAL VRU #: 001402896

5-7-07 AP

FS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>IV</u>	Conditional Use Permit No.: <u>RU 1A</u>
Type of Construction: <u>HOME</u>	Building Permit No.: <u>6-5-15643</u>
Owner of Building: <u>A & A Homes</u>	Electrical Permit No.: <u>6-5-15643</u>
Building Address: <u>79 SARAHIL*</u>	Insulation Permit No.: <u>6-5-15643</u>
Zoning District: <u>RA20R</u>	Plumbing Permit No.: <u>6-5-15643</u>
Zoning Permit No.: <u>6-5-15643</u>	Mech. Permit No.: <u>6-5-15643</u>
Date: <u>5-7-7</u>	Envir. C.O. No.: <u>6-5-15643</u>
<u>Fred Sperry</u> Building Official	_____ Zoning Official