

ADDRESS . : 65 SAPPHIRE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER . . : D & D HOMES #50
PARCEL . . : 03-9589- - -1015- -48-
APPL NUMBER: 06-50015644 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 50. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
THIRD LOT ON LEFT. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
PHONE : (910) 892-4345
PHONE : (910) 892-4345

STRUCTURE: 000 000 54X39 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/22/07 <i>3/22/07</i>	<i>AP</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001375381

COMMENTS AND NOTES

Fs

ADDRESS . : 65 SAPPHIRE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER . . : D & D HOMES #50
PARCEL . . : 03-9589- - -1015- -48-
APPL NUMBER: 06-50015644 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 50. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
THIRD LOT ON LEFT. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
PHONE : (910) 892-4345
PHONE : (910) 892-4345

STRUCTURE: 000 000 54X39 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/22/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001375381
	3/22/07	AP	
B103 01	4/04/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001383096

Handwritten: A-4-7 AP

COMMENTS AND NOTES

Handwritten: FS

ADDRESS : 65 SAPPHIRE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : D & D HOMES #50
PARCEL : 03-9589- - -1015- -48-
APPL NUMBER: 06-50015644 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 50. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
THIRD LOT ON LEFT. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
PHONE : (910) 892-4345
PHONE : (910) 892-4345

STRUCTURE: 000 000 54X39 3BR SFD

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/22/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001375381
	3/22/07	AP	
B103 01	4/04/07	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001383096
	4/04/07	AP	
A814 01	4/10/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001383103
	4/04/07	AP	65 Sapphire Dr
B105 01	4/19/07	TI	R*OPEN FLOOR VRU #: 001392281
	4/18/07	CA	
B105 02	4/20/07	TI	R*OPEN FLOOR VRU #: 001392772

4-20-07 AP
F

COMMENTS AND NOTES

ADDRESS : 65 SAPPHIRE DR SUBDIV: LAUREL VALLEY
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : D & D HOMES #50 PHONE : (910) 892-4345
PARCEL : 03-9589- - -1015- -48-
APPL NUMBER: 06-50015644 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 50. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
THIRD LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 54X39 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/22/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001375381
	3/22/07	AP	
B103 01	4/04/07	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001383096
	4/04/07	AP	
A814 01	4/10/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001383103
	4/04/07	AP	65 Sapphire Dr
B105 01	4/19/07	TI	R*OPEN FLOOR VRU #: 001392281
	4/18/07	CA	
B105 02	4/20/07	FS	R*OPEN FLOOR VRU #: 001392772
	4/20/07	AP	
R425 02	5/09/07	TI	FOUR TRADE ROUGH IN VRU #: 001405604

5-9-7 ~~AA~~

COMMENTS AND NOTES

fs

100 PSL
DRAIN TEST

DO NOT REMOVE!

Harnett County Inspection Department

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: ADD Date: 5.9.7

Address: 63 SAPHIRE

Lot No.: 55 Permit No.: 6-5-15644

(Check Box for Violation)

- | | | | | | | | |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg. | <input type="checkbox"/> Elec. | <input type="checkbox"/> Plumb. | <input type="checkbox"/> Mech. | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other | |

Violations Found: NEED TO REPAIR FLOOR
TOIST CUT BY PLUMBER

Will Check on insulation inspection

Code Enforcement Official [Signature] Date: 5.9.7
Signature [Signature]

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS : 65 SAPPHIRE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : D & D HOMES #50
PARCEL : 03-9589- - -1015- -48-
APPL NUMBER: 06-50015644 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 50. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
THIRD LOT ON LEFT. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
PHONE : (910) 892-4345
PHONE : (910) 892-4345

STRUCTURE: 000 000 54X39 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/22/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001375381
	3/22/07	AP	
B103 01	4/04/07	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001383096
	4/04/07	AP	
A814 01	4/10/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001383103
	4/04/07	AP	65 Sapphire Dr
B105 01	4/19/07	TI	R*OPEN FLOOR VRU #: 001392281
	4/18/07	CA	
B105 02	4/20/07	FS	R*OPEN FLOOR VRU #: 001392772
	4/20/07	AP	
R425 02	5/09/07	FS	FOUR TRADE ROUGH IN VRU #: 001405604
	5/09/07	DA	repair cut floor joist
R425 01	5/11/07	TI	FOUR TRADE ROUGH IN VRU #: 001405562
	5/08/07	CA	
I129 01	5/14/07	TI	R*INSULATION INSPECTION VRU #: 001407588
R425 03	5/14/07	TI	FOUR TRADE ROUGH IN VRU #: 001407579

COMMENTS AND NOTES

FS

ADDRESS : 65 SAPPHIRE DR SUBDIV: LAUREL VALLEY
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : D & D HOMES #50 PHONE : (910) 892-4345
PARCEL : 03-9589- - -1015- -48-
APPL NUMBER: 06-50015644 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 50. 27W LEFT INTO
LAUREL VALLEY RIGHT ON SAPPHIRE DRIVE
THIRD LOT ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 54X39 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/22/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001375381
	3/22/07	AP	
B103 01	4/04/07	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001383096
	4/04/07	AP	
A814 01	4/10/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001383103
	4/04/07	AP	✓65 Sapphire Dr
B105 01	4/19/07	TI	R*OPEN FLOOR VRU #: 001392281
	4/18/07	CA	
B105 02	4/20/07	FS	R*OPEN FLOOR VRU #: 001392772
	4/20/07	AP	
R425 02	5/09/07	FS	FOUR TRADE ROUGH IN VRU #: 001405604
	5/09/07	DA	repair cut floor joist
R425 01	5/11/07	TI	FOUR TRADE ROUGH IN VRU #: 001405562
	5/08/07	CA	
I129 01	5/14/07	FS	R*INSULATION INSPECTION VRU #: 001407588
	5/14/07	AP	
R425 03	5/14/07	FS	FOUR TRADE ROUGH IN VRU #: 001407579
	5/14/07	AP	
H824 01	7/10/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001444645
	7/10/07	AP	
R429 01	7/12/07	TI	FOUR TRADE FINAL VRU #: 001444900

7-12-07 *AP*

COMMENTS AND NOTES

IS

LAUREL VALLEY SD

COUNTY OF HARNETT DEPARTMENT OF BUILDING INSPECTION AND PLANNING/DEVELOPMENT CERTIFICATE OF OCCUPANCY

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: IV

Conditional Use Permit No.: N/A

Type of Construction: Home

Building Permit No.: 6-5-15644

Owner of Building: A & A Homes

Electrical Permit No.: 6-5-15644

Building Address: 65 SAPPHIRE DR

Insulation Permit No.: 6-5-15644

Zoning District: LA208

Plumbing Permit No.: 6-5-15644

Zoning Permit No.: 6-5-15644

Mech. Permit No.: 6-5-15644

Date: 7-12-7

Envir. C.O. No.: 6-5-15644

Fred Sperry
Building Official

Zoning Official