

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: JASON AVERY
PROPERTY LOCATION: SR2019 BRICKMILL RD
SUBDIVISION: HAZEL McLAMB
Type of Structure: 4 BEDROOM HOME
Proposed Wastewater System Type: CONVENTIONAL
Projected Daily Flow: 480 GPD
Number of bedrooms: 4 Number of Occupants: 8 max
Basement: No
Pump Required: No
Type of Water Supply: Public
Permit conditions: Five years

Authorized State Agent: [Signature] (OLIVER TOLKDOFF) Date: 9/14/06 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: JASON AVERY
PROPERTY LOCATION: SR2019 BRICKMILL RD
SUBDIVISION: HAZEL McLAMB
Facility Type: 4 BEDROOM HOME
Basement? No
Type of Wastewater System: CONVENTIONAL
Wastewater Flow: 480 GPD

Installation Requirements/Conditions

Septic Tank Size: 1000 gallons
Pump Tank Size:
Exact length of each trench: 90 feet (4 TRENCHES)
Trench Spacing: 9 Feet on Center
Soil Cover: 24 inches
Maximum Trench Depth of: 36 inches
Aggregate Depth: 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: [Signature] Date: 9/14/06
Construction Authorization Expiration Date: 9/14/11

HTE# 06-5-15662

Permit # 23257

Harnett County Department of Public Health Site Sketch

ISSUED TO: JASON AVERY PROPERTY LOCATOR: SR2019 BRICK MILL RD
SUBDIVISION HAZEL McLAMB LOT # _____

Authorized State Agent: [Signature] RS (OLIVER TOLKSDORF) Date: 9/14/06

28.34 ACRES

