
ADDRESS . : 65 COTTLE LAKE DR SUBDIV: J L STONE
CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
OWNER . . : POPE ROBERT #3 PHONE : (919) 868-2912
PARCEL . . : 07-0589- - -0102- -07-
APPL NUMBER: 06-50015748 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COTTLESTONE ESTATES #3
421 TOWARD DUNN LEFT HWY 27 RIGHT ON
BRICK MILL APPROX 2 MILES COTTLESTONE
ON LEFT JOB ON LEFT
T/S: 09/14/2006 04:12 PM JDAVIS ----

STRUCTURE: 000 000 47X55 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06 <i>12-5</i>	TI <i>AP</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317738 <i>KS</i>

----- COMMENTS AND NOTES -----

ADDRESS . : 65 COTTLE LAKE DR SUBDIV: J L STONE
CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
OWNER . . : POPE ROBERT #3 PHONE : (919) 868-2912
PARCEL . . : 07-0589- - -0102- -07-
APPL NUMBER: 06-50015748 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COTTLESTONE ESTATES #3
421 TOWARD DUNN LEFT HWY 27 RIGHT ON
BRICK MILL APPROX 2 MILES COTTLESTONE
ON LEFT JOB ON LEFT
T/S: 09/14/2006 04:12 PM JDAVIS ----

STRUCTURE: 000 000 47X55 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317738
	12/05/06	AP	
B103 01	12/18/06	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001324445
	<u>12.18</u>	<u>AP</u>	<u>KS</u>

----- COMMENTS AND NOTES -----

ADDRESS : 65 COTTLE LAKE DR
CONTRACTOR : POPE ROBERT
OWNER : POPE ROBERT #3
PARCEL : 07-0589- - -0102- -07-
APPL NUMBER: 06-50015748 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COTTLESTONE ESTATES #3
421 TOWARD DUNN LEFT HWY 27 RIGHT ON
BRICK MILL APPROX 2 MILES COTTLESTONE
ON LEFT JOB ON LEFT
T/S: 09/14/2006 04:12 PM JDAVIS ----

STRUCTURE: 000 000 47X55 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317738
	12/05/06	AP	
B103 01	12/18/06	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001324445
	12/18/06	AP	
A814 01	1/03/07	TI	ADDRESS CONFIRMATION VRU #: 001328897
	1/02/07	AP	65 COTTLE LAKE DR LOT 3
B105 01	1/03/07	TI	R*OPEN FLOOR VRU #: 001331071

1-3 AP KS

COMMENTS AND NOTES

ADDRESS . : 65 COTTLE LAKE DR SUBDIV: J L STONE
 CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
 OWNER . . : POPE ROBERT #3 PHONE : (919) 868-2912
 PARCEL . . : 07-0589- - -0102- -07-
 APPL NUMBER: 06-50015748 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COTTLESTONE ESTATES #3
 421 TOWARD DUNN LEFT HWY 27 RIGHT ON
 BRICK MILL APPROX 2 MILES COTTLESTONE
 ON LEFT JOB ON LEFT
 T/S: 09/14/2006 04:12 PM JDAVIS ----

STRUCTURE: 000 000 47X55 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06 12/05/06	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317738
B103 01	12/18/06 12/18/06	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001324445
A814 01	1/03/07 1/02/07	TI AP	ADDRESS CONFIRMATION VRU #: 001328897 65 COTTLE LAKE DR LOT 3
B105 01	1/03/07 1/03/07	KS AP	R*OPEN FLOOR VRU #: 001331071
R427 01	2/16/07 <u>2-16</u>	TI <u>DA</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001355198 <u>KJ</u>

----- COMMENTS AND NOTES -----

2

ADDRESS : 65 COTTLE LAKE DR SUBDIV: J L STONE
CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
OWNER : POPE ROBERT #3 PHONE : (919) 868-2912
PARCEL : 07-0589- - -0102- -07-
APPL NUMBER: 06-50015748 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : COTTLESTONE ESTATES #3
421 TOWARD DUNN LEFT HWY 27 RIGHT ON
BRICK MILL APPROX 2 MILES COTTLESTONE
ON LEFT JOB ON LEFT
T/S: 09/14/2006 04:12 PM JDAVIS ----

STRUCTURE: 000 000 47X55 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317738
	12/05/06	AP	
B103 01	12/18/06	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001324445
	12/18/06	AP	
A814 01	1/03/07	TI	ADDRESS CONFIRMATION VRU #: 001328897
	1/02/07	AP	65 COTTLE LAKE DR LOT 3
B105 01	1/03/07	KS	R*OPEN FLOOR VRU #: 001331071
	1/03/07	AP	
R427 01	2/16/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001355198
	2/16/07	DA	1. Fire caulk wires at top plate next to garage personnel door. 2. Change 2x6 hangers above garage to house entry door. Need proper hanger for 2x10. OK to insulate and side
I129 01	2/22/07	TI	R*INSULATION INSPECTION VRU #: 001358355
	<u>2-22</u>	<u>AP</u>	
R427 02	2/22/07	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001359132
	<u>2-22</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 65 COTTLE LAKE DR SUBDIV: J L STONE
CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
OWNER . . : POPE ROBERT #3 PHONE : (919) 868-2912
PARCEL . . : 07-0589- - -0102- -07-
APPL NUMBER: 06-50015748 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COTTLESTONE ESTATES #3
421 TOWARD DUNN LEFT HWY 27 RIGHT ON
BRICK MILL APPROX 2 MILES COTTLESTONE
ON LEFT JOB ON LEFT
T/S: 09/14/2006 04:12 PM JDAVIS ----

STRUCTURE: 000 000 47X55 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317738
	12/05/06	AP	
B103 01	12/18/06	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001324445
	12/18/06	AP	
A814 01	1/03/07	TI	ADDRESS CONFIRMATION VRU #: 001328897
	1/02/07	AP	✓65 COTTLE LAKE DR LOT 3
B105 01	1/03/07	KS	R*OPEN FLOOR VRU #: 001331071
	1/03/07	AP	
R427 01	2/16/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001355198
	2/16/07	DA	1. Fire caulk wires at top plate next to garage personnel door. 2. Change 2x6 hangers above garage to house entry door. Need proper hanger for 2x10. OK to insulate and side
I129 01	2/22/07	KS	R*INSULATION INSPECTION VRU #: 001358355
	2/22/07	AP	
R427 02	2/22/07	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001359132
	2/22/07	AP	
H824 01	4/12/07	BM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001389816
	4/12/07	AP	
R431 01	7/10/07	TI	FOUR TRADE FINAL >2500 VRU #: 001442488

7-10-07 DAVIS

COMMENTS AND NOTES

ADDRESS . . : 65 COTTLE LAKE DR SUBDIV: J L STONE
CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
OWNER . . : POPE ROBERT #3 PHONE : (919) 868-2912
PARCEL . . : 07-0589- - -0102- -07-
APPL NUMBER: 06-50015748 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COTTLESTONE ESTATES #3
421 TOWARD DUNN LEFT HWY 27 RIGHT ON
BRICK MILL APPROX 2 MILES COTTLESTONE
ON LEFT JOB ON LEFT
T/S: 09/14/2006 04:12 PM JDAVIS ----

STRUCTURE: 000 000 47X55 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317738
	12/05/06	AP	
B103 01	12/18/06	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001324445
	12/18/06	AP	
A814 01	1/03/07	TI	ADDRESS CONFIRMATION VRU #: 001328897
	1/02/07	AP	✓65 COTTLE LAKE DR LOT 3
B105 01	1/03/07	KS	R*OPEN FLOOR VRU #: 001331071
	1/03/07	AP	
R427 01	2/16/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001355198
	2/16/07	DA	1. Fire caulk wires at top plate next to garage personnel door. 2. Change 2x6 hangers above garage to house entry door. Need proper hanger for 2x10. OK to insulate and side
I129 01	2/22/07	KS	R*INSULATION INSPECTION VRU #: 001358355
	2/22/07	AP	
R427 02	2/22/07	KS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001359132
	2/22/07	AP	
H824 01	4/12/07	BM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001389816
	4/12/07	AP	
R431 01	7/10/07	BS	FOUR TRADE FINAL >2500 VRU #: 001442488
	7/10/07	DA	1. Need plastic under house. 2. Caulk 1/2 bath toilet and pedestal at floor 3. Install weatherstrip at upstairs attic storage door (weatherstrip is in storage area) NO FEE--Reschedule
R431 02	7/17/07	TI	FOUR TRADE FINAL >2500 VRU #: 001447376

7-17 AP

KS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Conditional Use Permit No.: _____

Type of Construction: V

Building Permit No.: _____

Owner of Building: Robert Pope

Electrical Permit No.: _____

Building Address: 65- Bottle Road

Insulation Permit No.: _____

Zoning District: _____

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: _____

Envir. C.O. No.: _____

Date: 7-17-87

K. Stalt

Building Official

Zoning Official

06-5-15748