

HT# 06-5-15751R

# Hannett County Department of Public Health

23316

## Improvement Permit

J.A. JOHNSON Const + Custom Homes building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: SR1703 RED HILL CH RD

ISSUED TO: Whittenton Builders

SUBDIVISION BLS

LOT # 2

NEW  REPAIR  EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD

Proposed Wastewater System Type: 25% REDUCTION system

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Bdr Number of Occupants: 6 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet

Permit valid for:

Five years  
 No expiration

Permit conditions:

Authorized State Agent: James Markant Date: 10-24-06

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Whittenton Builders

PROPERTY LOCATION: SR1703 RED HILL CH RD

SUBDIVISION BLS

LOT # 2

Facility Type: SFD  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* 25% REDUCTION system (initial)

Wastewater Flow: 360 GPD

(See note below, if applicable )

25% REDUCTION system (Repair)

### Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 4x 60 feet Trench Spacing: 9 Feet on Center

Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches  
Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM Aggregate Depth: 6 inches below pipe

Conditions: \_\_\_\_\_ 2 inches above pipe  
12 inches total

\*\*If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James Markant Date: 10-25-06 10/31/06

Construction Authorization Expiration Date: 10-25-11


HTE# 06-5-15751R

Permit # 23316

# Harnett County Department of Public Health Site Sketch

ISSUED TO: T.A. Johnson Const. Custom Homes PROPERTY LOCATOR: SR 1703 RED HELL CH RD  
~~Walter J. Builders~~ SUBDIVISION BLS LOT # 2

Authorized State Agent: James E. Markant Date: 10-25-06 & 10/31/06



SR 1703 RED HELL CH RD