

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: 10/11/2006
 Proposed Facility: _____ Design Flow (.1949): _____ Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
L5 590		0-23	G/SL	VH NSNP					PS.3
		23-41	ABK/G	Fi SP					
		0-17	G/SL	VH NSNP					25 PS.3
		17-38	VH/ABK/SCI	Fi SS SP	10 YR 8/1 @ 2"	35' PM			
		0-12	G/SL	VH NSNP					PS.35
		12-40	SKU/SCI	Fi SSSP	10 YR 7/1 @ 38"				
290 L5		0-20	G/SL	VH NSNP					PS.25
		20-37	ABK/C*	Fi SP	10 YR 8/1 @ 34"				

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	256	prop 256
Site LTAR	.3	.25

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: BM
 Others Present: _____