

ADDRESS . . : 12 ROBERT BRANCH CIR
CONTRACTOR : COCHRAN, MICHAEL W.
OWNER . . . : COCHRAN MICHAEL W & JAMIE L
PARCEL . . . : 08-0652- - -0097- -26-
APPL NUMBER: 06-50015864 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 NORTH RIGHT INTO MILL BRANCH S/D
LOT IS ON THE CORNER OF MILL BRANCH AND
ROBERT BRANCH ON LEFT LOT 26 JB

SUBDIV: MILL BRANCH
PHONE : (919) 552-1599
PHONE : (919) 771-2243

STRUCTURE: 000 000 57X55 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

SUB: COOKS ELECTRIC OF NC INC (919)557-3460
SUB: PROTECTIVE INSULATION (910)892-4302
SUB: CAROLINA PLUMBING & REPAIR
SUB: SUBURBAN SERVICE (919)625-6644

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06 <i>12-5-06</i>	TI <i>APBS</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317999

----- COMMENTS AND NOTES -----

ADDRESS . . : 12 ROBERT BRANCH CIR
CONTRACTOR : D T F CONSTRUCTION, INC
OWNER . . . : COCHRAN MICHAEL W & JAMIE L
PARCEL . . . : 08-0652- - -0097- -26-
APPL NUMBER: 06-50015864 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 NORTH RIGHT INTO MILL BRANCH S/D
LOT IS ON THE CORNER OF MILL BRANCH AND
ROBERT BRANCH ON LEFT LOT 26 JB

SUBDIV: MILL BRANCH
PHONE : (919) 557-1396
PHONE : (919) 771-2243

STRUCTURE: 000 000 57X55 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06 12/05/06	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317999
A814 01	10/31/07	TI	ADDRESS CONFIRMATION VRU #: 001513050
B103 01	10/31/07 <u>10-31-07</u>	TI <u>APBS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001513068

----- COMMENTS AND NOTES -----

ADDRESS . : 12 ROBERT BRANCH CIR
CONTRACTOR : D T F CONSTRUCTION, INC
OWNER . . : COCHRAN MICHAEL W & JAMIE L
PARCEL . . : 08-0652- - -0097- -26-
APPL NUMBER: 06-50015864 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 NORTH RIGHT INTO MILL BRANCH S/D
LOT IS ON THE CORNER OF MILL BRANCH AND
ROBERT BRANCH ON LEFT LOT 26 JB

SUBDIV: MILL BRANCH
PHONE : (919) 557-1396
PHONE : (919) 771-2243

STRUCTURE: 000 000 57X55 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317999
	12/05/06	AP	
B103 01	10/31/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001513068
	10/31/07	AP	
A814 01	10/31/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001513050
	10/31/07	AP	12 Robert Branch Cir
B105 01	11/02/07	BS	R*OPEN FLOOR VRU #: 001514418
	11/02/07	AP	
R425 01	11/15/07	BS	FOUR TRADE ROUGH IN VRU #: 001520651
	11/15/07	DA	1. Nail blocking at OSb within 4' of all corners 6"oc 2. Washing machine drain must be vented individually with a dry vent.3. Roofing not completed. Ok to insulate, do not side
I129 01	11/19/07	TI	R*INSULATION INSPECTION VRU #: 001521856
	<u>11-19-07</u>	<u>APBS</u>	
R427 01	11/19/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001521847
	<u>11/19/07</u>	<u>IV</u>	

COMMENTS AND NOTES

Joe Fanjoy 919-723-0507

Jennifer Junker - 919-639-6867

Bryan Haddock 919-796-0564

ADDRESS . : 12 ROBERT BRANCH CIR SUBDIV: MILL BRANCH
CONTRACTOR : D T F CONSTRUCTION, INC PHONE : (919) 557-1396
OWNER . . : COCHRAN MICHAEL W & JAMIE L PHONE : (919) 771-2243
PARCEL . . : 08-0652- - -0097- -26-
APPL NUMBER: 06-50015864 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 NORTH RIGHT INTO MILL BRANCH S/D
LOT IS ON THE CORNER OF MILL BRANCH AND
ROBERT BRANCH ON LEFT LOT 26 JB

STRUCTURE: 000 000 57X55 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317999
	12/05/06	AP	
B103 01	10/31/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001513068
	10/31/07	AP	
A814 01	10/31/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001513050
	10/31/07	AP	✓ 12 Robert Branch Cir
B105 01	11/02/07	BS	R*OPEN FLOOR VRU #: 001514418
	11/02/07	AP	
R425 01	11/15/07	BS	FOUR TRADE ROUGH IN VRU #: 001520651
	11/15/07	DA	1. Nail blocking at OSb within 4' of all corners 6"oc 2. Washing machine drain must be vented individually with a dry vent.3. Roofing not completed. Ok to insulate, do not side
I129 01	11/19/07	BS	R*INSULATION INSPECTION VRU #: 001521856
	11/19/07	AP	
R427 01	11/19/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001521847
	11/19/07	AP	
H824 01	2/04/08	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001557792
	2/04/08	AP	
R429 01	3/07/08	TI	FOUR TRADE FINAL VRU #: 001573309

3-7-08 DABS

----- COMMENTS AND NOTES -----

ADDRESS : 12 ROBERT BRANCH CIR SUBDIV: MILL BRANCH
CONTRACTOR : D T F CONSTRUCTION, INC PHONE : (919) 557-1396
OWNER : COCHRAN MICHAEL W & JAMIE L PHONE : (919) 771-2243
PARCEL : 08-0652- - -0097- -26-
APPL NUMBER: 06-50015864 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401 NORTH RIGHT INTO MILL BRANCH S/D
LOT IS ON THE CORNER OF MILL BRANCH AND
ROBERT BRANCH ON LEFT LOT 26 JB

STRUCTURE: 000 000 57X55 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/05/06	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001317999
	12/05/06	AP	
B103 01	10/31/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001513068
	10/31/07	AP	
A814 01	10/31/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001513050
	10/31/07	AP	✓ 12 Robert Branch Cir
B105 01	11/02/07	BS	R*OPEN FLOOR VRU #: 001514418
	11/02/07	AP	
R425 01	11/15/07	BS	FOUR TRADE ROUGH IN VRU #: 001520651
	11/15/07	DA	1. Nail blocking at OSb within 4' of all corners 6"oc 2. Washing machine drain must be vented individually with a dry vent.3. Roofing not completed. Ok to insulate, do not side
I129 01	11/19/07	BS	R*INSULATION INSPECTION VRU #: 001521856
	11/19/07	AP	
R427 01	11/19/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001521847
	11/19/07	AP	
H824 01	2/04/08	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001557792
	2/04/08	AP	
R429 01	3/07/08	BS	FOUR TRADE FINAL VRU #: 001573309
	3/07/08	DA	1. Insulate pulldown attic access. 2. Need a platform under water heater. 3. Tie up ducts under house to maintain 4 inches clearance (2 places) 4. Move address to garage side of house.
R229 01	3/13/08	TI	TWO TRADE FINAL VRU #: 001576146
	<u>3-13-08</u>	<u>APBS</u>	

COMMENTS AND NOTES

84920841



10/29/07

To Whom It May Concern:

This letter is to verify that Ample Lending Group LLC did in fact foreclose on the properties located on lots 13 and 26 Mill Branch subdivision. These lots were formerly owned by MWC Construction. Ample Lending was the successful bidder at the foreclosure sale, and have since agreed to assign our bids to DTF Construction and will be financing their construction. MWC no longer has any ownership in these properties. If you have any questions concerning this matter please do not hesitate to call me at 919-934-9200 ext. 122.

Sincerely

A handwritten signature in black ink, appearing to read "Dallas Dickerson", is written over a horizontal line.

Dallas Dickerson
Loan Officer

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SED

Conditional Use Permit No.: _____

Type of Construction: V

Building Permit No.: _____

Owner of Building: DTE Construction

Electrical Permit No.: _____

Building Address: 12 Robert Branch Cir

Insulation Permit No.: _____

Zoning District: _____

Plumbing Permit No.: _____

Zoning Permit No.: N/A

Mech. Permit No.: old

Date: 3-13-08

Envir. C.O. No.: _____

Brad Sittler

Building Official

Zoning Official