

ADDRESS . : 41 SCARLET OAK CIR
CONTRACTOR : CEBCO CONSTRUCTION INC
OWNER . . : KENNETH CUMMINGS LLC #87
PARCEL . . : 01-0536-02- -0028- -87-
APPL NUMBER: 06-50015898 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #87. 27W LEFT ON NURSERY
LEFT ON LEMUEL BLACK LEFT ON FOREST
OAKS RIGHT ON SCARLET OAKS LOT ON LEFT.
-A.DRIGGERS

SUBDIV:
PHONE : (910) 893-3331
PHONE : (910) 893-5826

STRUCTURE: 000 000 42X50.8 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

SUB: J M POPE ELECTRIC (910)890-3655
SUB: JONES & JONES HEATING & AIR (910)424-7702
SUB: CALLAHAN RICHARD (PROGRESSIVE)
SUB: BLOWN-RITE INSULATION INC.

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001298722
	10/26/06	AP	
B103 01	11/06/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001303752
	11/06/06	AP	
P309 01	11/09/06	MR	R*PLUMB UNDER SLAB VRU #: 001305885
	11/09/06	CA	
B111 01	11/14/06	TI	R*BLDG SLAB INSP VRU #: 001306848

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . : 41 SCARLET OAK CIR
CONTRACTOR : CEBCO CONSTRUCTION INC
OWNER . . : KENNETH CUMMINGS LLC #87
PARCEL . . : 01-0536-02- -0028- -87-
APPL NUMBER: 06-50015898 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #87. 27W LEFT ON NURSERY
LEFT ON LEMUEL BLACK LEFT ON FOREST
OAKS RIGHT ON SCARLET OAKS LOT ON LEFT.
-A.DRIGGERS

SUBDIV:
PHONE : (910) 893-3331
PHONE : (910) 893-5826

STRUCTURE: 000 000 42X50.8 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

SUB: J M POPE ELECTRIC (910)890-3655
SUB: JONES & JONES HEATING & AIR (910)424-7702
SUB: CALLAHAN RICHARD (PROGRESSIVE)
SUB: BLOWN-RITE INSULATION INC.

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001298722
	10/26/06	AP	
B103 01	11/06/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001303752
	11/06/06	AP	
P309 01	11/09/06	MR	R*PLUMB UNDER SLAB VRU #: 001305885
	11/09/06	CA	
B111 01	11/14/06	MR	R*BLDG SLAB INSP VRU #: 001306848
	11/14/06	AP	
A814 01	12/04/06	TI	ADDRESS CONFIRMATION VRU #: 001317635
	12/04/06	AP	41 SCARLET OAK CIR LOT 87
R427 01	12/04/06	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001317643
	12/04/06	CA	
R425 01	12/06/06	TI	FOUR TRADE ROUGH IN VRU #: 001318817

DA-MR

COMMENTS AND NOTES

ADDRESS . : 41 SCARLET OAK CIR SUBDIV:
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER . . : KENNETH CUMMINGS LLC #87 PHONE : (910) 893-5826
PARCEL . . : 01-0536-02- -0028- -87-
APPL NUMBER: 06-50015898 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : FOREST OAKS #87. 27W LEFT ON NURSERY
LEFT ON LEMUEL BLACK LEFT ON FOREST
OAKS RIGHT ON SCARLET OAKS LOT ON LEFT.
-A.DRIGGERS

STRUCTURE: 000 000 42X50.8 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD
SUB: J M POPE ELECTRIC (910)890-3655
SUB: JONES & JONES HEATING & AIR (910)424-7702
SUB: CALLAHAN RICHARD (PROGRESSIVE)
SUB: BLOWN-RITE INSULATION INC.

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001298722
	10/26/06	AP	
B103 01	11/06/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001303752
	11/06/06	AP	
P309 01	11/09/06	MR	R*PLUMB UNDER SLAB VRU #: 001305885
	11/09/06	CA	
B111 01	11/14/06	MR	R*BLDG SLAB INSP VRU #: 001306848
	11/14/06	AP	
A814 01	12/04/06	TI	ADDRESS CONFIRMATION VRU #: 001317635
	12/04/06	AP	41 SCARLET OAK CIR LOT 87
R427 01	12/04/06	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001317643
	12/04/06	CA	
R425 01	12/06/06	MR	FOUR TRADE ROUGH IN VRU #: 001318817
	12/06/06	DA	fireblock at fireplace strap all trusses per plans fill all holes through slab no DWV water
R425 02	12/08/06	TI	two bricks under AHU in attic not allowed FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001320738

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 41 SCARLETT OAK CIR
 CONTRACTOR : CEBCO CONSTRUCTION INC
 OWNER : KENNETH CUMMINGS LLC #87
 PARCEL : 01-0536-02-0028-87
 APPL NUMBER: 06-50015898 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #87. 27W LEFT ON NURSERY
 LEFT ON LEMUEL BLACK LEFT ON FOREST
 OAKS RIGHT ON SCARLETT OAKS LOT ON LEFT.
 -A.DRIGGERS

STRUCTURE: 000 000 42X50.8 3BR SFD
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSP 00 CP * SFD

SUBDIV:
 SUB: J M POPE ELECTRIC (910) 893-3331
 SUB: JONES & JONES HEATING & AIR (910) 424-7702
 SUB: CALLAHAN RICHARD (PROGRESSIVE)
 SUB: BLOWN-RITE INSULATION INC.

TYPE/SQ	COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001298722
B103 01	10/26/06	AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001303752
P309 01	11/06/06	AP	R*PLUMB UNDER SLAB VRU #: 001305885
B111 01	11/09/06	MR	R*BLDG UNDER SLAB VRU #: 001306848
B111 01	11/14/06	CA	R*BLDG SLAB INSP VRU #: 001306848
A814 01	12/04/06	AP	ADDRESS CONFIRMATION VRU #: 001317635
R427 01	12/04/06	AP	41 SCARLETT OAK CIR LOT 87
R425 01	12/04/06	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001317643
R425 01	12/06/06	MR	FOUR TRADE ROUGH IN VRU #: 001318817
R425 02	12/08/06	MR	fireblock at fireplace
I129 01	12/12/06	TI	strap all trusses per plans
			fill all holes through slab
			no DWV water
			two bricks under AHU in attic not allowed
			FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001320738
			R*INSULATION INSPECTION VRU #: 001321867

AP-TWR

COMMENTS AND NOTES

ADDRESS : 41 SCARLET OAK CIR
 CONTRACTOR : CEBCO CONSTRUCTION INC
 OWNER : KENNETH CUMMINGS LLC #87
 PARCEL : 01-0536-02- -0028- -87-
 APPL NUMBER: 06-50015898 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #87. 27W LEFT ON NURSERY
 LEFT ON LEMUEL BLACK LEFT ON FOREST
 OAKS RIGHT ON SCARLET OAKS LOT ON LEFT.
 -A.DRIGGERS

SUBDIV:
 PHONE : (910) 893-3331
 PHONE : (910) 893-5826

STRUCTURE: 000 000 42X50.8 3BR SFD
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

SUB: J M POPE ELECTRIC (910)890-3655
 SUB: JONES & JONES HEATING & AIR (910)424-7702
 SUB: CALLAHAN RICHARD (PROGRESSIVE)
 SUB: BLOWN-RITE INSULATION INC.

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/26/06	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001298722
	10/26/06	AP	
B103 01	11/06/06	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001303752
	11/06/06	AP	
P309 01	11/09/06	MR	R*PLUMB UNDER SLAB VRU #: 001305885
	11/09/06	CA	
B111 01	11/14/06	MR	R*BLDG SLAB INSP VRU #: 001306848
	11/14/06	AP	
A814 01	12/04/06	TI	ADDRESS CONFIRMATION VRU #: 001317635
	12/04/06	AP	✓ 41 SCARLET OAK CIR LOT 87
R427 01	12/04/06	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001317643
	12/04/06	CA	
R425 01	12/06/06	MR	FOUR TRADE ROUGH IN VRU #: 001318817
	12/06/06	DA	fireblock at fireplace strap all trusses per plans fill all holes through slab no DWV water two bricks under AHU in attic not allowed
R425 02	12/08/06	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001320738
	12/08/06	AP	
I129 01	12/12/06	MR	R*INSULATION INSPECTION VRU #: 001321867
	12/12/06	AP	
H824 01	1/04/07	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001333210
	1/04/07	AP	
R429 01	1/16/07	TI	FOUR TRADE FINAL VRU #: 001337342

AP.MR

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Res.
Type of Construction: I
Owner of Building: Kenneth Cummings
Building Address: 41 Scarlett Oak
Zoning District: _____
Zoning Permit No.: _____

Conditional Use Permit No.: _____
Building Permit No.: 06-50015898
Electrical Permit No.: 11
Insulation Permit No.: 11
Plumbing Permit No.: 11
Mech. Permit No.: 11
Envir. C.O. No.: _____

Date: 1-17-7
Mike Rean
Building Official

Zoning Official