HTE#06-5-15922

Harnest County Department of Public sealth 23313

Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: 1403 Cokes bury RD SUBDIVISION Corobus Park ISSUED TO: RICHARD E ANDERSON Site Improvements required prior to Construction Authorization Issuance: Type of Structure: Proposed Wastewater System Type: 250/0 REDUCTION System Projected Daily Flow: 360 GPD 3 Number of Occupants: 6 max Number of bedrooms: Basement Yes Pump Required: ☐Yes ☐ No ☐ May be required based on final location and elevations of facilities Type of Water Supply:
Community Public Well Distance from well 50 feet Five years Permit valid for: ☐ No expiration Permit conditions: Authorized State Agent: James Manhantens Date: 10-19-06 SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. **Construction Authorization** (Required for Building Permit) The construction and installation requirements of Rules .1950, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSIED TO: RICHARD & Anderson New Expansion Expansion Facility Type: SFD Basement? Yes No Basement Fixtures?

Yes 25 YOR EDVETIN Type of Wastewater System** (Initial) Wastewater Flow: 360 GPD (See note below, if applicable

) 25% REDUCTION System (Repair) Installation Requirements/Conditions Exact length of each trench 20 feet Septic Tank Size 1000 gallons Trench Spacing: 9 Feet on Center Trenches shall be installed on contour at a Soil Cover: Pump Tank Size gallons Maximum Trench Depth of: 20-7/8 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. GPM I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. **If applicable: Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Date: 10-19-06 Authorized State Agent.

Construction Authorization Expiration Date: 1019-11

Harnett County Department of Public Health Site Sketch

	PROPERTY LOCATON: 5/2 140 3	Cokesbu	WRD
ISSUED TO: RICHARD E Andreason	PROPERTY LOCATON: <u>SR 1403</u> SUBDIVISION <u>Cahashi</u>	in bonh	O LOT # 64
		8	
Authorized State Agent anes Manh	not -	Date:	-19-06

