

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: ADK Partners PROPERTY LOCATION: 1116
SUBDIVISION Colonial Hills LOT # 69

NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFO 3BR 40x65

Proposed Wastewater System Type: Pumps 25% reduction system

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years

Permit conditions: Meet onsite - Maintain all set backs No expiration

STUD out Plumbing shall be shown at ground level or higher

Keep drain lines 20' from property line with Elevation Along it

Authorized State Agent: J. W. [Signature] Date: 11-9-06 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: ADK Partners PROPERTY LOCATION: 1116
SUBDIVISION Colonial Hills LOT # 69

Facility Type: SFO 3BR 40x65 New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** Pumps 25% Reduction (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable) LPP 360 LTR (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 3x75 feet Trench Spacing: 9 Feet on Center

Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches

Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed

(Trench bottoms shall be level to +1-1/4" 36" above the trench bottom)

in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe

Aggregate Depth: _____ inches above pipe

Conditions: _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. W. [Signature] SEE ATTACHED SITE SKETCH

Date: 11-9-06

Construction Authorization Expiration Date: 11-9-2011

HTE# 06-50015943

Permit # 23389

Harnett County Department of Public Health Site Sketch

ISSUED TO: ADK Partners

PROPERTY LOCATOR: 1116


SUBDIVISION Colonial Hills

LOT # 69

Authorized State Agent: J. L. Williams

Date: 11-9-08

144



Meet onsite

Maintain all setbacks

Keep drain lines 20' from property line with Easement Along it.

Install 3x75 of 25% Reduction system at 18"