

Improvement Permit

Gary Robinson A building permit cannot be issued with only an Improvement Permit

ISSUED TO: ~~AOB~~ Gary Robinson PROPERTY LOCATION: 1116
 SUBDIVISION: Colonial Hills LOT # 33

NEW REPAIR EXPANSION
 Type of Structure: SFD - (45x29) 3BR 45x29 Site Improvements required prior to Construction Authorization Issuance:

Proposed Wastewater System Type: 2 1/2" Reduction System
 Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years

Permit conditions: STUB out Plumbing shall be shown at ground level or higher maintain all set backs No expiration

Meet on site NOTE Water Line & Power Line must be 10' from septic system & Repair Area

Authorized State Agent: J. W. ARENS Date: 11-9-06 02-17-2010 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: ~~AOB~~ Gary Robinson PROPERTY LOCATION: 1116
 SUBDIVISION: Colonial Hills LOT # 33

Facility Type: SFD 45x29 3BR New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 2 1/2" Reduction System (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable) LPP - 360 LF (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x225 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/- 1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 Aggregate Depth: _____ inches above pipe
 Conditions: _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. W. ARENS Date: 11-9-06 02-17-2010 SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 11-9-2011 02-17-2015

HTE# 06-500 15951R

Permit # 23378

Harnett County Department of Public Health

Site Sketch

GARY Robinson

ISSUED TO:

AOC Partners

PROPERTY LOCATOR:

1116

SUBDIVISION

Colonial Hills

LOT #


33

Authorized State Agent:

J. L. [Signature]

Date:

11-9-06 Revised 02-17-2010



Meet onsite for Final septic layout

STUB out Plumbing shallow @ Where shown at ground level or higher

Maintain All setbacks

1x225 of 25% Reduction system at 18"

Keep Power Line & water Line 10' from Any part of the septic system or Repair Area

to SA 1116 ↓