

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: ADK Partners
NEW REPAIR EXPANSION
Type of Structure: SFO 42x55 30a
Proposed Wastewater System Type: 25% Reduction System
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max

PROPERTY LOCATION: 1116
SUBDIVISION: Colonial Hills LOT # 37
Site Improvements required prior to Construction Authorization Issuance:

Basement Yes No
Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years No expiration
Permit conditions: Meet onsite for final layout - maintain all set backs
Start plumbing shallow where shown - at ground level or higher
Keep clean lines 25' from property line with easement along it.

Authorized State Agent: [Signature] Date: 11-9-06 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: ADK Partners
Facility Type: SFO 42x55 30a New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** 25% Reduction System (Initial)
(See note below, if applicable
LPP 360 LF (Repair)

PROPERTY LOCATION: 1116
SUBDIVISION: Colonial Hills LOT # 37
Wastewater Flow: 360 GPD

Installation Requirements/Conditions

Septic Tank Size 1200 gallons Exact length of each trench 5x45 feet Trench Spacing: 9 Feet on Center
Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
(Trench bottoms shall be level to +/-1/4" in all directions)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe _____ inches above pipe _____ inches total
Conditions: _____

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: [Signature] Date: 11-9-06 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 11-9-2011

HTE# 06-50015955

Permit # 23382

Harnett County Department of Public Health Site Sketch

ISSUED TO: AOK Partners


PROPERTY LOCATOR: 1116

SUBDIVISION Colonial Hills

LOT # 37

Authorized State Agent: J. [Signature]

Date: 11-9-06



STUB out Plumbing shallow where shown at ground level or higher
 MAINTAIN ALL SETBACKS
 Meet on site for Final Layout
 install 5x45 of 25% reduction system at 18"
 keep drain field 20' from property line with Easement along it