
ADDRESS . : 716 COLONIAL HILLS DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER . . : ADK PROPERTIES #38
 PARCEL . . : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

SUBDIV: COLONIAL HILLS
 PHONE : (910) 977-2562
 PHONE :

DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
 RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
 RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR, CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	8/03/10	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	<u>8-3-10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS . . : 716 COLONIAL HILLS DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER . . . : ADK PROPERTIES #38
 PARCEL . . . : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
 RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
 RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
A814 01	8/06/10	TI	ADDRESS CONFIRMATION VRU #: 001965458
B103 01	8/06/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8-6-10	PA-MR	
	8-6-10		

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 08-06-10

PERMIT # 06-50015956

ADDRESS: 716 colonial hills

Some piers do not appear to have 2" projection
Clean off all footings for reinspection

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : ADK PROPERTIES #38 PHONE :
PARCEL : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC ----- some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD ----- 716 colonial hills dr lot 38 lillington 27546 T/S: 08/06/2010 04:40 PM TWARD -----
B103 02	8/10/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	<u>8/10/10</u>	<u>AP DT</u>	Please call if necessary. Billy Elmore (919) 441-5656

----- COMMENTS AND NOTES -----

ADDRESS . . : 716 COLONIAL HILLS DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER . . . : ADK PROPERTIES #38
PARCEL . . . : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

SUBDIV: COLONIAL HILLS
PHONE : (910) 977-2562
PHONE :

DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC ----- some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD ----- 716 colonial hills dr lot 38 lillington 27546 T/S: 08/06/2010 04:40 PM TWARD -----
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	TI	R*OPEN FLOOR VRU #: 001968486
	<u>8/12/10</u>	<u>AP DT</u>	Please call if necessary. Billy Elmore (919) 441-5656

----- COMMENTS AND NOTES -----

ADDRESS : 716 COLONIAL HILLS DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : ADK PROPERTIES #38
PARCEL : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD 716 colonial hills dr lot 38 lillington 27546 T/S: 08/06/2010 04:40 PM TWARD
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC
R425 02	9/15/10	TI	FOUR TRADE ROUGH IN VRU #: 001982255

9-15-10 DA-MR

COMMENTS AND NOTES

Flashing - Ponds
missing - back bedroom

ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : ADK PROPERTIES #38 PHONE :
PARCEL : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR, CRAWL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC ----- some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD ----- 716 colonial hills dr lot 38 lillington 27546 T/S: 08/06/2010 04:40 PM TWARD -----
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC -----
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC ----- 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	TI	R*INSULATION INSPECTION VRU #: 001983543

9/17/10 DA DT

----- COMMENTS AND NOTES -----

ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : ADK PROPERTIES #38 PHONE :
PARCEL : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD 716 colonial hills dr lot 38 lillington 27546 T/S: 08/06/2010 04:40 PM TWARD
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	DT	R*INSULATION INSPECTION VRU #: 001983543
	9/17/10	DA	Insulation inspection was done and sheetrock is permitted to be installed. Awaiting ruling for aluminum flashing. T/S: 09/17/2010 11:49 AM DETAYLOR
R425 03	9/21/10	TI	FOUR TRADE ROUGH IN VRU #: 001984715
	9/21/10	DA DT	
I129 02	9/21/10	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001984806
	9/21/10	DA DT	T/S: 09/20/2010 02:08 PM NTART

COMMENTS AND NOTES

ADDRESS . : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . : ADK PROPERTIES #38 PHONE :
PARCEL . . : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC ----- some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD ----- 716 colonial hills dr lot 38 lillington 27546
			T/S: 08/06/2010 04:40 PM TWARD -----
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC -----
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC ----- 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	DT	R*INSULATION INSPECTION VRU #: 001983543
	9/17/10	DA	Insulation inspection was done and sheetrock is permitted tobe installed. Awaiting ruling for aluminum flashing. T/S: 09/17/2010 11:49 AM DETAYLOR -----
R425 03	9/21/10	DT	FOUR TRADE ROUGH IN VRU #: 001984715
	9/21/10	DA	Awaiting letter from doi regarding flashing. Okay to hang sheetrock. T/S: 09/21/2010 10:59 AM DETAYLOR -----
I129 02	9/21/10	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001984806
	9/21/10	DA	T/S: 09/20/2010 02:08 PM NTART ----- Awaiting rough in approval. T/S: 09/21/2010 11:00 AM DETAYLOR -----
R125 01	9/23/10	TI	ONE TRADE ROUGH IN VRU #: 001985928

----- CONTINUED ONTO NEXT PAGE -----

PREPARED 9/22/10, 13:58:43
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 4
DATE 9/23/10

ADDRESS . : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . : ADK PROPERTIES #38 PHONE :
PARCEL . . : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

	REQUESTED	INSP	DESCRIPTION
TYP/SQ	COMPLETED	RESULT	RESULTS/COMMENTS

_____ Framing inspection for porch flashing.

----- COMMENTS AND NOTES -----

ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : ADK PROPERTIES #38 PHONE :
 PARCEL : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
 RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
 RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD 716 colonial hills dr lot 38 lillington 27546
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	DT	R*INSULATION INSPECTION VRU #: 001983543
	9/17/10	DA	Insulation inspection was done and sheetrock is permitted to be installed. Awaiting ruling for aluminum flashing. T/S: 09/17/2010 11:49 AM DETAYLOR
R425 03	9/21/10	DT	FOUR TRADE ROUGH IN VRU #: 001984715
	9/21/10	DA	Awaiting letter from doi regarding flashing. Okay to hang sheetrock. T/S: 09/21/2010 10:59 AM DETAYLOR
I129 02	9/21/10	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001984806
	9/21/10	DA	T/S: 09/20/2010 02:08 PM NTART Awaiting rough in approval. T/S: 09/21/2010 11:00 AM DETAYLOR

CONTINUED ONTO NEXT PAGE

 ADDRESS . : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER . . : ADK PROPERTIES #38 PHONE :
 PARCEL . . : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	9/23/10 9/22/10	RD CA	ONE TRADE ROUGH IN VRU #: 001985928 Framing inspection for porch flashing. T/S: 09/22/2010 04:17 PM RDCONTE ----- CUS ROLLED TO 9/24/10
I129 03	9/27/10 9/27/10	JH CA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001986132 T/S: 09/22/2010 04:21 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy -----
R125 02	9/27/10 9/27/10	JH CA	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 001986157 T/S: 09/22/2010 04:22 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy -----
R125 03	10/05/10 10/05/10	DT AP	ONE TRADE ROUGH IN VRU #: 001989698 Porch Flashing - Please call for any questions (919)441-5656
I129 04	10/05/10 <u>10/5/10</u>	TI <u>AP DT</u>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001990290 T/S: 10/05/2010 01:16 PM NTART -----
R425 04	10/05/10 10/05/10	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001989870 T/S: 10/04/2010 02:13 PM NTART ----- T/S: 10/05/2010 01:15 PM NTART -----

----- COMMENTS AND NOTES -----

ADDRESS : 716 COLONIAL HILLS DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : ADK PROPERTIES #38
PARCEL : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

SUBDIV: COLONIAL HILLS
PHONE : (910) 977-2562
PHONE :

DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR, CRAWL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD 716 colonial hills dr lot 38 lillington 27546
B103 02	8/10/10	DT	T/S: 08/06/2010 04:40 PM TWARD
	8/10/10	AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025 Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	DT	R*INSULATION INSPECTION VRU #: 001983543
	9/17/10	DA	Insulation inspection was done and sheetrock is permitted to be installed. Awaiting ruling for aluminum flashing. T/S: 09/17/2010 11:49 AM DETAYLOR
R425 03	9/21/10	DT	FOUR TRADE ROUGH IN VRU #: 001984715
	9/21/10	DA	Awaiting letter from doi regarding flashing. Okay to hang sheetrock. T/S: 09/21/2010 10:59 AM DETAYLOR
I129 02	9/21/10	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001984806
	9/21/10	DA	T/S: 09/20/2010 02:08 PM NTART Awaiting rough in approval. T/S: 09/21/2010 11:00 AM DETAYLOR

CONTINUED ONTO NEXT PAGE

ADDRESS . : 716 COLONIAL HILLS DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER . . : ADK PROPERTIES #38
PARCEL . . : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

SUBDIV: COLONIAL HILLS
PHONE : (910) 977-2562
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	9/23/10 9/22/10	RD CA	ONE TRADE ROUGH IN VRU #: 001985928 Framing inspection for porch flashing. T/S: 09/22/2010 04:17 PM RDCONTE ----- CUS ROLLED TO 9/24/10
I129 03	9/27/10 9/27/10	JH CA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001986132 T/S: 09/22/2010 04:21 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy
R125 02	9/27/10 9/27/10	JH CA	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 001986157 T/S: 09/22/2010 04:22 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy
R125 03	10/05/10 <u>10/15/10</u>	TI <u>APDT</u>	ONE TRADE ROUGH IN VRU #: 001989698 Porch Flashing - Please call for any questions (919)441-5656
R425 04	10/05/10 <u>10/15/10</u>	TI <u>APDT</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001989870 T/S: 10/04/2010 02:13 PM NTART -----

----- COMMENTS AND NOTES -----

ADDRESS . . : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER . . : ADK PROPERTIES #38 PHONE :
 PARCEL . . : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
 RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
 RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC ----- some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD ----- 716 colonial hills dr lot 38 lillington 27546 T/S: 08/06/2010 04:40 PM TWARD -----
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC -----
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC ----- 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	DT	R*INSULATION INSPECTION VRU #: 001983543
	9/17/10	DA	Insulation inspection was done and sheetrock is permitted to be installed. Awaiting ruling for aluminum flashing. T/S: 09/17/2010 11:49 AM DETAYLOR -----
R425 03	9/21/10	DT	FOUR TRADE ROUGH IN VRU #: 001984715
	9/21/10	DA	Awaiting letter from doi regarding flashing. Okay to hang sheetrock. T/S: 09/21/2010 10:59 AM DETAYLOR -----
I129 02	9/21/10	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001984806
	9/21/10	DA	T/S: 09/20/2010 02:08 PM NTART ----- Awaiting rough in approval. T/S: 09/21/2010 11:00 AM DETAYLOR -----
R125 01	9/23/10	RD	ONE TRADE ROUGH IN VRU #: 001985928

----- CONTINUED ONTO NEXT PAGE -----

ADDRESS . : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . : ADK PROPERTIES #38 PHONE :
PARCEL . . : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	9/22/10	CA	Framing inspection for porch flashing. T/S: 09/22/2010 04:17 PM RDCONTE ----- CUS ROLLED TO 9/24/10
I129 03	9/27/10 9/27/10	JH CA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001986132 T/S: 09/22/2010 04:21 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy -----
R125 02	9/27/10 9/27/10	JH CA	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 001986157 T/S: 09/22/2010 04:22 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy -----
R125 03	10/05/10 10/05/10	DT AP	ONE TRADE ROUGH IN VRU #: 001989698 Porch Flashing - Please call for any questions (919)441-5656
I129 04	10/05/10 10/05/10	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001990290 T/S: 10/05/2010 01:16 PM NTART ----- T/S: 10/05/2010 02:06 PM NTART -----
R425 04	10/05/10 10/05/10	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001989870 T/S: 10/04/2010 02:13 PM NTART ----- T/S: 10/05/2010 01:15 PM NTART -----
H824 01	10/07/10 10/07/10	JW DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001991793 HOLD. NOT COMPLETE YET. NEED POWER AND WATER LINE CHECK. T/S: 10/07/2010 04:04 PM SZIMMER ----- T/S: 10/07/2010 04:06 PM SZIMMER -----
M305 01	10/21/10	TI	R*PLUMB SEWER CONNECTION VRU #: 001996982

10/21/10 AP

----- COMMENTS AND NOTES -----

FS

ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : ADK PROPERTIES #38 PHONE :
PARCEL : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR, CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC ----- some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD ----- ✓716 colonial hills dr lot 38 lillington 27546 T/S: 08/06/2010 04:40 PM TWARD -----
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC -----
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC ----- 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	DT	R*INSULATION INSPECTION VRU #: 001983543
	9/17/10	DA	Insulation inspection was done and sheetrock is permitted to be installed. Awaiting ruling for aluminum flashing. T/S: 09/17/2010 11:49 AM DETAYLOR -----
R425 03	9/21/10	DT	FOUR TRADE ROUGH IN VRU #: 001984715
	9/21/10	DA	Awaiting letter from doi regarding flashing. Okay to hang sheetrock. T/S: 09/21/2010 10:59 AM DETAYLOR -----
I129 02	9/21/10	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001984806
	9/21/10	DA	T/S: 09/20/2010 02:08 PM NTART ----- Awaiting rough in approval. T/S: 09/21/2010 11:00 AM DETAYLOR -----

----- CONTINUED ONTO NEXT PAGE -----

 ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : ADK PROPERTIES #38 PHONE :
 PARCEL : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	9/23/10 9/22/10	RD CA	ONE TRADE ROUGH IN VRU #: 001985928 Framing inspection for porch flashing. T/S: 09/22/2010 04:17 PM RDCONTE ----- CUS ROLLED TO 9/24/10
I129 03	9/27/10 9/27/10	JH CA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001986132 T/S: 09/22/2010 04:21 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy
R125 02	9/27/10 9/27/10	JH CA	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 001986157 T/S: 09/22/2010 04:22 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy
R125 03	10/05/10 10/05/10	DT AP	ONE TRADE ROUGH IN VRU #: 001989698 Porch Flashing - Please call for any questions (919)441-5656
I129 04	10/05/10 10/05/10	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001990290 T/S: 10/05/2010 01:16 PM NTART ----- T/S: 10/05/2010 02:06 PM NTART -----
R425 04	10/05/10 10/05/10	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001989870 T/S: 10/04/2010 02:13 PM NTART ----- T/S: 10/05/2010 01:15 PM NTART -----
H824 01	10/07/10 10/07/10	JW DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001991793 HOLD. NOT COMPLETE YET. NEED POWER AND WATER LINE CHECK. T/S: 10/07/2010 04:04 PM SZIMMER ----- T/S: 10/07/2010 04:06 PM SZIMMER -----
M305 01	10/21/10 10/21/10	FS AP	R*PLUMB SEWER CONNECTION VRU #: 001996982 T/S: 10/21/2010 01:53 PM FSPIVEY -----
H824 02	10/21/10 10/21/10	JW AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001997717 T/S: 10/22/2010 09:08 AM SZIMMER ----- T/S: 10/22/2010 09:08 AM SZIMMER -----
R429 01	1/26/11 1/26/11	RD CA	FOUR TRADE FINAL VRU #: 002033793 T/S: 01/26/2011 07:57 AM RDCONTE ----- CUSTOMER ROLLED TO 1/27/11
R429 02	1/27/11 1/27/11	TI CA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002034122 T/S: 01/26/2011 08:00 AM RDCONTE ----- T/S: 01/27/2011 08:31 AM NTART -----
R429 03	2/10/11 <u>2-11-11</u>	TI <u>CA-MR</u>	FOUR TRADE FINAL VRU #: 002039345

----- COMMENTS AND NOTES -----

ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : ADK PROPERTIES #38 PHONE :
 PARCEL : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
 RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
 RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR, CRAWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC ----- some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD ----- ✓716 colonial hills dr lot 38 lillington 27546
			T/S: 08/06/2010 04:40 PM TWARD -----
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC -----
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC ----- 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	DT	R*INSULATION INSPECTION VRU #: 001983543
	9/17/10	DA	Insulation inspection was done and sheetrock is permitted to be installed. Awaiting ruling for aluminum flashing. T/S: 09/17/2010 11:49 AM DETAYLOR -----
R425 03	9/21/10	DT	FOUR TRADE ROUGH IN VRU #: 001984715
	9/21/10	DA	Awaiting letter from doi regarding flashing. Okay to hang sheetrock. T/S: 09/21/2010 10:59 AM DETAYLOR -----
I129 02	9/21/10	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001984806
	9/21/10	DA	T/S: 09/20/2010 02:08 PM NTART ----- Awaiting rough in approval. T/S: 09/21/2010 11:00 AM DETAYLOR -----

----- CONTINUED ONTO NEXT PAGE -----

ADDRESS : 726 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : ADK PROPERTIES #38 PHONE :
PARCEL : 03-0507- - -0226- -56-
APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	9/23/10 9/22/10	RD CA	ONE TRADE ROUGH IN VRU #: 001985928 Framing inspection for porch flashing. T/S: 09/22/2010 04:17 PM RDCONTE ----- CUS ROLLED TO 9/24/10
I129 03	9/27/10 9/27/10	JH CA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001986132 T/S: 09/22/2010 04:21 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy
R125 02	9/27/10 9/27/10	JH CA	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 001986157 T/S: 09/22/2010 04:22 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy
R125 03	10/05/10 10/05/10	DT AP	ONE TRADE ROUGH IN VRU #: 001989698 Porch Flashing - Please call for any questions (919)441-5656
I129 04	10/05/10 10/05/10	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001990290 T/S: 10/05/2010 01:16 PM NTART ----- T/S: 10/05/2010 02:06 PM NTART -----
R425 04	10/05/10 10/05/10	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001989870 T/S: 10/04/2010 02:13 PM NTART ----- T/S: 10/05/2010 01:15 PM NTART -----
H824 01	10/07/10 10/07/10	JW DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001991793 HOLD. NOT COMPLETE YET. NEED POWER AND WATER LINE CHECK. T/S: 10/07/2010 04:04 PM SZIMMER ----- T/S: 10/07/2010 04:06 PM SZIMMER -----
M305 01	10/21/10 10/21/10	FS AP	R*PLUMB SEWER CONNECTION VRU #: 001996982 T/S: 10/21/2010 01:53 PM FSPIVEY -----
H824 02	10/21/10 10/21/10	JW AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001997717 T/S: 10/22/2010 09:08 AM SZIMMER ----- T/S: 10/22/2010 09:08 AM SZIMMER -----
R429 01	1/26/11 1/26/11	RD CA	FOUR TRADE FINAL VRU #: 002033793 T/S: 01/26/2011 07:57 AM RDCONTE ----- CUSTOMER ROLLED TO 1/27/11
R429 02	1/27/11 1/27/11	TI CA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002034122 T/S: 01/26/2011 08:00 AM RDCONTE ----- T/S: 01/27/2011 08:31 AM NTART -----
R429 03	2/11/11 <u>2-11-11</u>	TI <u>DP-MR</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002039345 T/S: 02/10/2011 08:43 AM VBROWN -----

COMMENTS AND NOTES

connect Dishwasher
ins. on duct in attic
add Φ back Porch
~~Seal~~ pipe between Meter + Panel

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 02-11-11

PERMIT # 06-50015956

ADDRESS: 716 colonial hills dr.

CORRECTIONS NEEDED:

1. Connect the dishwasher
2. Add an outlet on back deck
3. Insulation is loose on return end of attic ac

Mike Rearic cell# (910) 984- 4772

ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : ADK PROPERTIES #38 PHONE :
 PARCEL : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : COLONIAL HILLS LOT 38. 210 RIGHT ON
 RAY RD RIGHT ON NURSERY RD LEFT ON DOCS
 RD ONE MILE ON LEFT. -A.DRIGGERS

STRUCTURE: 000 000 49.7X30 3BDR 2.5BATH SFD W GAR,CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001962943
	8/03/10	AP	T/S: 08/03/2010 12:02 PM MREARIC -----
B103 01	8/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001965466
	8/06/10	DA	T/S: 08/06/2010 01:02 PM MREARIC ----- some piers and footings do not appear to have 2" projection, clean off an call for reinspection
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001965458
	8/06/10	AP	T/S: 08/06/2010 04:40 PM TWARD ----- ✓ 716 colonial hills dr lot 38 lillington 27546 T/S: 08/06/2010 04:40 PM TWARD -----
B103 02	8/10/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001967025
	8/10/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
B105 01	8/12/10	DT	R*OPEN FLOOR VRU #: 001968486
	8/12/10	AP	Please call if necessary. Billy Elmore (919) 441-5656
R425 01	9/10/10	MR	FOUR TRADE ROUGH IN VRU #: 001980648
	9/10/10	CA	T/S: 09/10/2010 12:16 PM MREARIC -----
R425 02	9/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001982255
	9/15/10	DA	T/S: 09/15/2010 12:22 PM MREARIC ----- 1. porch flashing 2. outlet missing in back bedroom
I129 01	9/17/10	DT	R*INSULATION INSPECTION VRU #: 001983543
	9/17/10	DA	Insulation inspection was done and sheetrock is permitted to be installed. Awaiting ruling for aluminum flashing. T/S: 09/17/2010 11:49 AM DETAYLOR -----
R425 03	9/21/10	DT	FOUR TRADE ROUGH IN VRU #: 001984715
	9/21/10	DA	Awaiting letter from doi regarding flashing. Okay to hang sheetrock. T/S: 09/21/2010 10:59 AM DETAYLOR -----
I129 02	9/21/10	DT	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001984806
	9/21/10	DA	T/S: 09/20/2010 02:08 PM NTART ----- Awaiting rough in approval. T/S: 09/21/2010 11:00 AM DETAYLOR -----

CONTINUED ONTO NEXT PAGE

ADDRESS : 716 COLONIAL HILLS DR SUBDIV: COLONIAL HILLS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : ADK PROPERTIES #38 PHONE :
 PARCEL : 03-0507- - -0226- -56-
 APPL NUMBER: 06-50015956 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R125 01	9/23/10 9/22/10	RD CA	ONE TRADE ROUGH IN VRU #: 001985928 Framing inspection for porch flashing. T/S: 09/22/2010 04:17 PM RDCONTE ----- CUS ROLLED TO 9/24/10
I129 03	9/27/10 9/27/10	JH CA	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001986132 T/S: 09/22/2010 04:21 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy
R125 02	9/27/10 9/27/10	JH CA	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 001986157 T/S: 09/22/2010 04:22 PM RDCONTE ----- PER DEEN:INSUL REINSPECTION & ONE TRADE ROUGH-IN T/S: 09/23/2010 04:31 PM NTART ----- per Billy
R125 03	10/05/10 10/05/10	DT AP	ONE TRADE ROUGH IN VRU #: 001989698 Porch Flashing - Please call for any questions (919)441-5656
I129 04	10/05/10 10/05/10	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001990290 T/S: 10/05/2010 01:16 PM NTART ----- T/S: 10/05/2010 02:06 PM NTART -----
R425 04	10/05/10 10/05/10	DT AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001989870 T/S: 10/04/2010 02:13 PM NTART ----- T/S: 10/05/2010 01:15 PM NTART -----
H824 01	10/07/10 10/07/10	JW DA	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001991793 HOLD. NOT COMPLETE YET. NEED POWER AND WATER LINE CHECK. T/S: 10/07/2010 04:04 PM SZIMMER ----- T/S: 10/07/2010 04:06 PM SZIMMER -----
M305 01	10/21/10 10/21/10	FS AP	R*PLUMB SEWER CONNECTION VRU #: 001996982 T/S: 10/21/2010 01:53 PM FSPIVEY -----
H824 02	10/21/10 10/21/10	JW AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001997717 T/S: 10/22/2010 09:08 AM SZIMMER ----- T/S: 10/22/2010 09:08 AM SZIMMER -----
R429 01	1/26/11 1/26/11	RD CA	FOUR TRADE FINAL VRU #: 002033793 T/S: 01/26/2011 07:57 AM RDCONTE ----- CUSTOMER ROLLED TO 1/27/11
R429 02	1/27/11 1/27/11	TI CA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002034122 T/S: 01/26/2011 08:00 AM RDCONTE ----- T/S: 01/27/2011 08:31 AM NTART -----
R429 03	2/11/11 2/11/11	MR DP	FOUR TRADE FINAL TIME: 17:00 VRU #: 002039345 T/S: 02/10/2011 08:43 AM VBROWN ----- T/S: 02/11/2011 09:44 AM MREARIC ----- connect the dishwasher an outlet is required on back porch insulation is loose on return end of attic
R429 04	2/18/11 <u>2-18-11</u>	TI <u>AP-MR</u>	FOUR TRADE FINAL VRU #: 002043073

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: ADK Properties

Building: 06-50015956

Electrical: "

Address: 716 Colonial Hills Dr

Insulation: "

Plumbing: "

Mechanical: "

MFG Home: "

Date: 2-18-11

Building Official: T. Michael Reavis