
ADDRESS . : 71 ENGLISH OAK DR
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER . . : WOODSHIRE PARTNERS LLC #2
 PARCEL . . : 01-0536-02- -0028- -02-
 APPL NUMBER: 06-50015991 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #2
 27W TURN LEFT ON NURSERY RD LEFT ON
 LEMEUL BLACK LEFT INTO FOREST OAKS.
 T/S: 10/19/2006 04:01 PM JDAVIS -----

SUBDIV: FOREST OAKS PH 1 & 2
 PHONE : (919) 481-0503
 PHONE :

LAND NOTES : LXMN 6/23/05 SPLIT FROM 01-0536-0028-89

STRUCTURE: 000 000 54X42 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	VRU #:
B101 01	<u>4/13/07</u> <u>4-13-7</u>	TI <u>AP-CE</u>	R*BLDG FOOTING / TEMP SVC POLE	001388750

----- COMMENTS AND NOTES -----

No - T-pole

ADDRESS . : 71 ENGLISH OAK DR SUBDIV: FOREST OAKS PH 1 & 2
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER . . : WOODSHIRE PARTNERS LLC #2 PHONE :
 PARCEL . . : 01-0536-02- -0028- -02-
 APPL NUMBER: 06-50015991 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #2
 27W TURN LEFT ON NURSERY RD LEFT ON
 LEMEUL BLACK LEFT INTO FOREST OAKS.
 T/S: 10/19/2006 04:01 PM JDAVIS ----
 LAND NOTES : LXMN 6/23/05 SPLIT FROM 01-0536-0028-89

STRUCTURE: 000 000 54X42 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/13/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001388750
	4/13/07	AP	No t-pole on site. ce
B103 01	4/24/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001395751

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . . : 71 ENGLISH OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER . . . : WOODSHIRE PARTNERS LLC #2
PARCEL . . . : 01-0536-02- -0028- -02-
APPL NUMBER: 06-50015991 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #2

SUBDIV: FOREST OAKS PH 1 & 2
PHONE : (919) 481-0503
PHONE :

27W TURN LEFT ON NURSERY RD LEFT ON
LEMEUL BLACK LEFT INTO FOREST OAKS.

T/S: 10/19/2006 04:01 PM JDAVIS ----

LAND NOTES : LXMN 6/23/05 SPLIT FROM 01-0536-0028-89

STRUCTURE: 000 000 54X42 3BR

FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/13/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001388750
	4/13/07	AP	No t-pole on site. ce
B103 01	4/24/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001395751
	4/24/07	AP	
B105 01	4/26/07	TI	R*OPEN FLOOR VRU #: 001398197

AP JH

----- COMMENTS AND NOTES -----

ADDRESS : 71 ENGLISH OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #2
PARCEL : 01-0536-02- -0028- -02-
APPL NUMBER: 06-50015991 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #2

SUBDIV: FOREST OAKS PH 1 & 2
PHONE : (919) 481-0503
PHONE :

27W TURN LEFT ON NURSERY RD LEFT ON
LEMEUL BLACK LEFT INTO FOREST OAKS.
T/S: 10/19/2006 04:01 PM JDAVIS ----

LAND NOTES : LXMN 6/23/05 SPLIT FROM 01-0536-0028-89

STRUCTURE: 000 000 54X42 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/13/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001388750
	4/13/07	AP	No t-pole on site. ce
B103 01	4/24/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001395751
	4/24/07	AP	
B105 01	4/26/07	JH	R*OPEN FLOOR VRU #: 001398197
	4/26/07	AP	
A814 01	4/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395788
	4/24/07	AP	71 English Oak Dr Lot 2
R425 01	5/17/07	TI	FOUR TRADE ROUGH IN VRU #: 001411485

OP JH

----- COMMENTS AND NOTES -----

ADDRESS : 71 ENGLISH OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #2
PARCEL : 01-0536-02- -0028- -02-
APPL NUMBER: 06-50015991 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #2

SUBDIV: FOREST OAKS PH 1 & 2
PHONE : (919) 481-0503
PHONE :

27W TURN LEFT ON NURSERY RD LEFT ON
LEMEUL BLACK LEFT INTO FOREST OAKS.
T/S: 10/19/2006 04:01 PM JDAVIS ----

LAND NOTES : LXMN 6/23/05 SPLIT FROM 01-0536-0028-89

STRUCTURE: 000 000 54X42 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/13/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001388750
	4/13/07	AP	No t-pole on site. ce
B103 01	4/24/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001395751
	4/24/07	AP	
B105 01	4/26/07	JH	R*OPEN FLOOR VRU #: 001398197
	4/26/07	AP	
A814 01	4/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395788
	4/24/07	AP	71 English Oak Dr Lot 2
R425 01	5/17/07	JH	FOUR TRADE ROUGH IN VRU #: 001411485
	5/17/07	DP	1)Nail all holes in roof truss hangers & uplift clips in garage. 2)Missing nail guard @ top plate in kitchen on garage wall. 3)Missing nail guard to right of stove in corner on back side of wall. 4)Fire caulk holes @ water heater in top plate. 5)Need truss drawings for correct lot #. 6)Missing nail guards on wires in masterbath to left of sink. 7)Need to strap top plate in closet of #3 bedroom @ 3" drain pipe. 8)Need 3' head of water on drain lines. 9)Water lines under house need support every 32". 10)Drain lines need support every 4'. 11)Replace cut floor joist under masterbath sink.
R425 02	5/24/07	MR	FOUR TRADE ROUGH IN VRU #: 001415481
	5/24/07	CA	
R425 03	6/05/07	TI	FOUR TRADE ROUGH IN VRU #: 001422188

AP-MR

COMMENTS AND NOTES

ADDRESS : 71 ENGLISH OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #2
PARCEL : 01-0536-02- -0028- -02-
APPL NUMBER: 06-50015991 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #2

SUBDIV: FOREST OAKS PH 1 & 2
PHONE : (919) 481-0503
PHONE :

27W TURN LEFT ON NURSERY RD LEFT ON
LEMEUL BLACK LEFT INTO FOREST OAKS.

T/S: 10/19/2006 04:01 PM JDAVIS ----

LAND NOTES : LXMN 6/23/05 SPLIT FROM 01-0536-0028-89

STRUCTURE: 000 000 54X42 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/13/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001388750
	4/13/07	AP	No t-pole on site. ce
B103 01	4/24/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001395751
	4/24/07	AP	
B105 01	4/26/07	JH	R*OPEN FLOOR VRU #: 001398197
	4/26/07	AP	
A814 01	4/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395788
	4/24/07	AP	71 English Oak Dr Lot 2
R425 01	5/17/07	JH	FOUR TRADE ROUGH IN VRU #: 001411485
	5/17/07	DP	1)Nail all holes in roof truss hangers & uplift clips in garage. 2)Missing nail guard @ top plate in kitchen on garage wall. 3)Missing nail guard to right of stove in corner on back side of wall. 4)Fire caulk holes @ water heater in top plate. 5)Need truss drawings for correct lot #. 6)Missing nail guards on wires in masterbath to left of sink. 7)Need to strap top plate in closet of #3 bedroom @ 3" drain pipe. 8)Need 3' head of water on drain lines. 9)Water lines under house need support every 32". 10)Drain lines need support every 4'. 11)Replace cut floor joist under masterbath sink.
R425 02	5/24/07	MR	FOUR TRADE ROUGH IN VRU #: 001415481
	5/24/07	CA	
R425 03	6/05/07	MR	FOUR TRADE ROUGH IN VRU #: 001422188
	6/05/07	AP	
I129 01	6/08/07	TI	R*INSULATION INSPECTION VRU #: 001425407

DA-MR

COMMENTS AND NOTES

ADDRESS . : 71 ENGLISH OAK DR SUBDIV: FOREST OAKS PH 1 & 2
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : WOODSHIRE PARTNERS LLC #2 PHONE :
PARCEL . . : 01-0536-02- -0028- -02-
APPL NUMBER: 06-50015991 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #2
27W TURN LEFT ON NURSERY RD LEFT ON
LEMEUL BLACK LEFT INTO FOREST OAKS.
T/S: 10/19/2006 04:01 PM JDAVIS ----
LAND NOTES : LXMN 6/23/05 SPLIT FROM 01-0536-0028-89

STRUCTURE: 000 000 54X42 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/13/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001388750
	4/13/07	AP	No t-pole on site. ce
B103 01	4/24/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001395751
	4/24/07	AP	
B105 01	4/26/07	JH	R*OPEN FLOOR VRU #: 001398197
	4/26/07	AP	
A814 01	4/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395788
	4/24/07	AP	71 English Oak Dr Lot 2
R425 01	5/17/07	JH	FOUR TRADE ROUGH IN VRU #: 001411485
	5/17/07	DP	1)Nail all holes in roof truss hangers & uplift clips in garage. 2)Missing nail guard @ top plate in kitchen on garage wall. 3)Missing nail guard to right of stove in corner on back side of wall. 4)Fire caulk holes @ water heater in top plate. 5)Need truss drawings for correct lot #. 6)Missing nail guards on wires in masterbath to left of sink. 7)Need to strap top plate in closet of #3 bedroom @ 3" drain pipe. 8)Need 3' head of water on drain lines. 9)Water lines under house need support every 32". 10)Drain lines need support every 4'. 11)Replace cut floor joist under masterbath sink.
R425 02	5/24/07	MR	FOUR TRADE ROUGH IN VRU #: 001415481
	5/24/07	CA	
R425 03	6/05/07	MR	FOUR TRADE ROUGH IN VRU #: 001422188
	6/05/07	AP	
I129 01	6/08/07	MR	R*INSULATION INSPECTION VRU #: 001425407
	6/08/07	DA	* insulate pipes in garage * provide access to attic area over 2nd fl.
I129 02	6/11/07	TI	R*INSULATION INSPECTION VRU #: 001426923

AP JLD

----- COMMENTS AND NOTES -----

ADDRESS : 71 ENGLISH OAK DR
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER : WOODSHIRE PARTNERS LLC #2
 PARCEL : 01-0536-02- -0028- -02-
 APPL NUMBER: 06-50015991 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #2
 27W TURN LEFT ON NURSERY RD LEFT ON
 LEMEUL BLACK LEFT INTO FOREST OAKS.
 T/S: 10/19/2006 04:01 PM JDAVIS ----
 LAND NOTES : LXMN 6/23/05 SPLIT FROM 01-0536-0028-89

SUBDIV: FOREST OAKS PH 1 & 2
 PHONE : (919) 481-0503
 PHONE :

STRUCTURE: 000 000 54X42 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/13/07	CE	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001388750
	4/13/07	AP	No t-pole on site. ce
B103 01	4/24/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001395751
	4/24/07	AP	
B105 01	4/26/07	JH	R*OPEN FLOOR VRU #: 001398197
	4/26/07	AP	
A814 01	4/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395788
	4/24/07	AP	✓71 English Oak Dr Lot 2
R425 01	5/17/07	JH	FOUR TRADE ROUGH IN VRU #: 001411485
	5/17/07	DP	1)Nail all holes in roof truss hangers & uplift clips in garage. 2)Missing nail guard @ top plate in kitchen on garage wall. 3)Missing nail guard to right of stove in corner on back side of wall. 4)Fire caulk holes @ water heater in top plate. 5)Need truss drawings for correct lot #. 6)Missing nail guards on wires in masterbath to left of sink. 7)Need to strap top plate in closet of #3 bedroom @ 3" drain pipe. 8)Need 3' head of water on drain lines. 9)Water lines under house need support every 32". 10)Drain lines need support every 4'. 11)Replace cut floor joist under masterbath sink.
R425 02	5/24/07	MR	FOUR TRADE ROUGH IN VRU #: 001415481
	5/24/07	CA	
R425 03	6/05/07	MR	FOUR TRADE ROUGH IN VRU #: 001422188
	6/05/07	AP	
I129 01	6/08/07	MR	R*INSULATION INSPECTION VRU #: 001425407
	6/08/07	DA	1. insulate pipes in garage 2. provide access to attic area over 2nd fl.
I129 02	6/11/07	JH	R*INSULATION INSPECTION VRU #: 001426923
	6/11/07	AP	
R429 01	9/07/07	TI	FOUR TRADE FINAL VRU #: 001481738
	9/06/07	CA	CANCELLED FINAL FOR 09/07/07. NO OPERATIONS PERMIT. NJT
R429 02	9/14/07	TI	FOUR TRADE FINAL VRU #: 001485486
	9/13/07	CA	CANCELLED NO OPERATIONS PERMIT 09/13/07 NJT
H824 01	9/25/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001493345
	9/25/07	AP	
R429 03	9/28/07	TI	FOUR TRADE FINAL VRU #: 001495572

9/28/07 AP JT

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Woodshire Partners LLC Electrical Permit No.: _____
Building Address: 71 English Oak Dr. Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: 0630015991
Date: 9/28/07 Envir. C.O. No.: _____

[Signature]
Building Official

Zoning Official