

HTE# 06-50015999

# Hamilton County Department of Public Health

**23367**

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Kenneth Cummings

PROPERTY LOCATION: 1125

SUBDIVISION: FOREST JAK

LOT # 88

NEW  REPAIR  EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFO 52x32 4BR

Proposed Wastewater System Type: Conventional

Projected Daily Flow: 480 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well 55 feet

Permit valid for:  Five years

Permit conditions: keep drain lines 6 to 12" Below Fill - Lot has varying  No expiration

Depth of F.I.L - maintain all setbacks 5' out Plumbing shallow where shown, at ground level or higher

Authorized State Agent: J. L. [Signature]

Date: 10.26.06

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Kenneth Cummings

PROPERTY LOCATION: 1125

SUBDIVISION: FOREST JAK

LOT # 88

Facility Type: SFO 52x32 4BR  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* Conventional (Initial)

Wastewater Flow: 480 GPD

(See note below, if applicable ) LPP 385 LF (Repair)

### Installation Requirements/Conditions

Septic Tank Size 1200 gallons

Exact length of each trench 4x80 feet

Trench Spacing: 9 Feet on Center

Pump Tank Size \_\_\_\_\_ gallons

Trenches shall be installed on contour at a Maximum Trench Depth of: 18 inches (Trench bottoms shall be level to +/-1/4" in all directions)

Soil Cover: 6 inches (Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: 6 inches below pipe 2 inches above pipe

Conditions: \_\_\_\_\_ 12 inches total

\*\*If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. L. [Signature]

Date: 10.26.06

SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 10.26.2011

HTE# 06-50015999

Permit # 23767

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Kenneth Cummings PROPERTY LOCATOR: 1125  
SUBDIVISION: Forest Oak LOT # 88

Authorized State Agent: [Signature] Date: 10.26.06

Meet on site

Keep drain lines 6 to 12" below F.I.L. - lot has varying depths of F.I.L. - maintain all jet back stub at plumbing shallow 4 Lines of 80' each

