

Application number 06 50016029
 Address 577 COLONIAL HILLS DR 03
 PARCEL NUMBER 03-0507 - -0226 -75-
 Application type CP NEW RESIDENTIAL (SFD)
 PIN 0506-14-9844.000
 Tenant name, number

Clone Delete View Fast log Action log maintenance In/opt maint

| Agency description | Rev | Path | Step | Req | Key Dates | | | Action Summary | | |
|----------------------|-----|------|------|-----|-----------|----------|------|----------------|------|----|
| | | | | | In | Est | Cmpl | Last | Type | By |
| ENVIRONMENTAL HEALTH | A | 10 | N | | 03/08/07 | 11/07/06 | | 03/21/07 | AP | JW |
| BUILDING PLAN REVIEW | B | 18 | N | | 10/24/06 | 11/07/06 | | | | |
| INSPECTIONS REVIEW | B | 20 | N | | | | | | | |

*=Closed by a revision

OK Exit Cancel Add Land inq Misc info inquiry

ADDRESS . : 577 COLONIAL HILLS DR
 CONTRACTOR : R B C HOMES, INC.
 OWNER . . : RBC HOMES #57
 PARCEL . . : 03-0507- - -0226- -75-
 APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COLONIAL HILLS #57
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD
 LEFT ON DOCS RD 1MILE ON LEFT
 T/S: 10/24/2006 10:40 AM JDAVIS -----

STRUCTURE: 000 000 34X39 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|--------------------|--|
| B101 01 | 4/17/07 | TI <i>AP JH</i> | R*BLDG FOOTING / TEMP SVC POLE <i>Tempole</i> |

VRU #: 001390426

COMMENTS AND NOTES -----

ADDRESS . . : 577 COLONIAL HILLS DR
CONTRACTOR : R B C HOMES, INC.
OWNER . . . : RBC HOMES #57
PARCEL . . . : 03-0507- - -0226- -75-
APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COLONIAL HILLS #57
210 RIGHT ON RAY RD RIGHT ON NURSERY RD
LEFT ON DOCS RD 1MILE ON LEFT
T/S: 10/24/2006 10:40 AM JDAVIS ----

SUBDIV: COLONIAL HILLS
PHONE : (910) 423-3555
PHONE : (910) 423-3555

STRUCTURE: 000 000 34X39 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 4/17/07 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001390426 |
| | 4/17/07 | AP | Temp pole passed JH 4/17/07 |
| A814 01 | 4/24/07 | TI | ADDRESS CONFIRMATION VRU #: 001395284 |
| B103 01 | 4/24/07 | TI | R*BLDG FOUND & TEMP SVC POLE VRU #: 001395292 |

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . : 18 KINGSTON DR SUBDIV: COLONIAL HILLS
 CONTRACTOR : R B C HOMES, INC. PHONE : (910) 423-3555
 OWNER . . : RBC HOMES #57 PHONE : (910) 423-3555
 PARCEL . . : 03-0507- - -0226- -75-
 APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COLONIAL HILLS #57
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD
 LEFT ON DOCS RD 1MILE ON LEFT
 T/S: 10/24/2006 10:40 AM JDAVIS -----

STRUCTURE: 000 000 34X39 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 4/17/07 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001390426 |
| | 4/17/07 | AP | Temp pole passed JH 4/17/07 |
| B103 01 | 4/24/07 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001395292 |
| | 4/24/07 | AP | |
| A814 01 | 4/24/07 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395284 |
| | 4/25/07 | AP | 18 Kingston Dr Lot 57 |
| B105 01 | 4/30/07 | TI | R*OPEN FLOOR VRU #: 001399500 |

 DA-MR

No Plans

----- COMMENTS AND NOTES -----

ADDRESS . . : 18 KINGSTON DR
CONTRACTOR : R B C HOMES, INC.
OWNER . . . : RBC HOMES #57
PARCEL . . . : 03-0507- - -0226- -75-
APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COLONIAL HILLS #57
210 RIGHT ON RAY RD RIGHT ON NURSERY RD
LEFT ON DOCS RD 1MILE ON LEFT
T/S: 10/24/2006 10:40 AM JDAVIS -----

STRUCTURE: 000 000 34X39 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 4/17/07 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001390426 |
| | 4/17/07 | AP | Temp pole passed JH 4/17/07 |
| B103 01 | 4/24/07 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001395292 |
| | 4/24/07 | AP | |
| A814 01 | 4/24/07 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395284 |
| | 4/25/07 | AP | 18 Kingston Dr Lot 57 |
| B105 01 | 4/30/07 | MR | R*OPEN FLOOR VRU #: 001399500 |
| | 4/30/07 | DA | no plans |
| B105 02 | 5/01/07 | TI | R*OPEN FLOOR VRU #: 001400738 |

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . : 18 KINGSTON DR
CONTRACTOR : R B C HOMES, INC.
OWNER . . : RBC HOMES #57
PARCEL . . : 03-0507- - -0226- -75-
APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COLONIAL HILLS #57
210 RIGHT ON RAY RD RIGHT ON NURSERY RD
LEFT ON DOCS RD 1MILE ON LEFT
T/S: 10/24/2006 10:40 AM JDAVIS ----

STRUCTURE: 000 000 34X39 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 4/17/07 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001390426 |
| | 4/17/07 | AP | Temp pole passed JH 4/17/07 |
| B103 01 | 4/24/07 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001395292 |
| | 4/24/07 | AP | |
| A814 01 | 4/24/07 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395284 |
| | 4/25/07 | AP | 18 Kingston Dr Lot 57 |
| B105 01 | 4/30/07 | MR | R*OPEN FLOOR VRU #: 001399500 |
| | 4/30/07 | DA | no plans |
| B105 02 | 5/01/07 | MR | R*OPEN FLOOR VRU #: 001400738 |
| | 5/01/07 | AP | |
| R425 01 | 5/16/07 | MR | FOUR TRADE ROUGH IN VRU #: 001410125 |
| | 5/16/07 | CA | per builder |
| R425 02 | 5/31/07 | TI | FOUR TRADE ROUGH IN VRU #: 001419332 |

~~DA-MK~~

----- COMMENTS AND NOTES -----

ADDRESS . : 18 KINGSTON DR
 CONTRACTOR : R B C HOMES, INC.
 OWNER . . : RBC HOMES #57
 PARCEL . . : 03-0507- - -0226- -75-
 APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COLONIAL HILLS #57
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD
 LEFT ON DOCS RD 1MILE ON LEFT
 T/S: 10/24/2006 10:40 AM JDAVIS ----

SUBDIV: COLONIAL HILLS
 PHONE : (910) 423-3555
 PHONE : (910) 423-3555

STRUCTURE: 000 000 34X39 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 4/17/07 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001390426 |
| | 4/17/07 | AP | Temp pole passed JH 4/17/07 |
| B103 01 | 4/24/07 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001395292 |
| | 4/24/07 | AP | |
| A814 01 | 4/24/07 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395284 |
| | 4/25/07 | AP | 18 Kingston Dr Lot 57 |
| B105 01 | 4/30/07 | MR | R*OPEN FLOOR VRU #: 001399500 |
| | 4/30/07 | DA | no plans |
| B105 02 | 5/01/07 | MR | R*OPEN FLOOR VRU #: 001400738 |
| | 5/01/07 | AP | |
| R425 01 | 5/16/07 | MR | FOUR TRADE ROUGH IN VRU #: 001410125 |
| | 5/16/07 | CA | per builder |
| R425 02 | 5/31/07 | MR | FOUR TRADE ROUGH IN VRU #: 001419332 |
| | 5/31/07 | DA | <ol style="list-style-type: none"> 1. remove untreated wood from under front threshold and flash with galv or plastic at front and back doors... no aluminum 2. box around plumb stack in garage and fireblock on rough 3. protect gas line at fireplace entry and seal up hole 4. outlet needed in small wall in MBR 5. no boots on roof 6. support or secure all water pipes @ 32" and fiknish plumbing 7. trusses drilled or notched by plumber need a letter to show correct repair |
| R425 03 | 6/08/07 | TI | FOUR TRADE ROUGH IN VRU #: 001425321 |

AP. MR

COMMENTS AND NOTES

ADDRESS . : 18 KINGSTON DR SUBDIV: COLONIAL HILLS
CONTRACTOR : R B C HOMES, INC. PHONE : (910) 423-3555
OWNER . . : RBC HOMES #57 PHONE : (910) 423-3555
PARCEL . . : 03-0507- - -0226- -75-
APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COLONIAL HILLS #57
210 RIGHT ON RAY RD RIGHT ON NURSERY RD
LEFT ON DOCS RD 1MILE ON LEFT
T/S: 10/24/2006 10:40 AM JDAVIS -----

STRUCTURE: 000 000 34X39 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 4/17/07 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001390426 |
| | 4/17/07 | AP | Temp pole passed JH 4/17/07 |
| B103 01 | 4/24/07 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001395292 |
| | 4/24/07 | AP | |
| A814 01 | 4/24/07 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395284 |
| | 4/25/07 | AP | 18 Kingston Dr Lot 57 |
| B105 01 | 4/30/07 | MR | R*OPEN FLOOR VRU #: 001399500 |
| | 4/30/07 | DA | no plans |
| B105 02 | 5/01/07 | MR | R*OPEN FLOOR VRU #: 001400738 |
| | 5/01/07 | AP | |
| R425 01 | 5/16/07 | MR | FOUR TRADE ROUGH IN VRU #: 001410125 |
| | 5/16/07 | CA | per builder |
| R425 02 | 5/31/07 | MR | FOUR TRADE ROUGH IN VRU #: 001419332 |
| | 5/31/07 | DA | 1. remove untreated wood from under front threshold and flash with galv or plastic at front and back doors... no aluminum 2. box around plumb stack in garage and fireblock on rough 3. protect gas line at fireplace entry and seal up hole 4. outlet needed in small wall in MBR 5. no boots on roof 6. support or secure all water pipes @ 32" and fiknish plumbing 7. trusses drilled or notched by plumber need a letter to show correct repair |
| R425 03 | 6/08/07 | MR | FOUR TRADE ROUGH IN VRU #: 001425321 |
| | 6/08/07 | AP | |
| I129 01 | 6/15/07 | TI | R*INSULATION INSPECTION VRU #: 001429554 |
| | <u>6/15/07</u> | <u>AP DT</u> | |

COMMENTS AND NOTES

ADDRESS . . : 18 KINGSTON DR
CONTRACTOR : R B C HOMES, INC.
OWNER . . . : RBC HOMES #57
PARCEL . . . : 03-0507- - -0226- -75-
APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)

SUBDIV: COLONIAL HILLS
PHONE : (910) 423-3555
PHONE : (910) 423-3555

DIRECTIONS : COLONIAL HILLS #57
210 RIGHT ON RAY RD RIGHT ON NURSERY RD
LEFT ON DOCS RD 1MILE ON LEFT
T/S: 10/24/2006 10:40 AM JDAVIS ----

STRUCTURE: 000 000 34X39 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| B101 01 | 4/17/07 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001390426 |
| | 4/17/07 | AP | Temp pole passed JH 4/17/07 |
| B103 01 | 4/24/07 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001395292 |
| | 4/24/07 | AP | |
| A814 01 | 4/24/07 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395284 |
| | 4/25/07 | AP | 18 Kingston Dr Lot 57 |
| B105 01 | 4/30/07 | MR | R*OPEN FLOOR VRU #: 001399500 |
| | 4/30/07 | DA | no plans |
| B105 02 | 5/01/07 | MR | R*OPEN FLOOR VRU #: 001400738 |
| | 5/01/07 | AP | |
| R425 01 | 5/16/07 | MR | FOUR TRADE ROUGH IN VRU #: 001410125 |
| | 5/16/07 | CA | per builder |
| R425 02 | 5/31/07 | MR | FOUR TRADE ROUGH IN VRU #: 001419332 |
| | 5/31/07 | DA | 1. remove untreated wood from under front threshold and flash with galv or plastic at front and back doors... no aluminum 2. box around plumb stack in garage and fireblock on rough 3. protect gas line at fireplace entry and seal up hole 4. outlet needed in small wall in MBR 5. no boots on roof 6. support or secure all water pipes @ 32" and fiknish plumbing 7. trusses drilled or notched by plumber need a letter to show correct repair |
| R425 03 | 6/08/07 | MR | FOUR TRADE ROUGH IN VRU #: 001425321 |
| | 6/08/07 | AP | |
| I129 01 | 6/15/07 | DT | R*INSULATION INSPECTION VRU #: 001429554 |
| | 6/15/07 | AP | |
| H824 01 | 6/19/07 | JW | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001433655 |
| | 6/19/07 | AP | |
| R429 02 | 8/13/07 | TI | FOUR TRADE FINAL VRU #: 001464478 |
| R429 01 | 8/13/07 | TI | FOUR TRADE FINAL VRU #: 001464460 |
| | 8/10/07 | CA | |

SA-MR

----- COMMENTS AND NOTES -----

ADDRESS : 18 KINGSTON DR
 CONTRACTOR : R B C HOMES, INC.
 OWNER : RBC HOMES #57
 PARCEL : 03-0507- - -0226- -75-
 APPL NUMBER: 06-50016029 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COLONIAL HILLS #57
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD
 LEFT ON DOCS RD 1MILE ON LEFT
 T/S: 10/24/2006 10:40 AM JDAVIS ----

STRUCTURE: 000 000 34X39 3BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| B101 01 | 4/17/07 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001390426 |
| | 4/17/07 | AP | Temp pole passed JH 4/17/07 |
| B103 01 | 4/24/07 | MR | R*BLDG FOUND & TEMP SVC POLE VRU #: 001395292 |
| | 4/24/07 | AP | |
| A814 01 | 4/24/07 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001395284 |
| | 4/25/07 | AP | ✓18 Kingston Dr Lot 57 |
| B105 01 | 4/30/07 | MR | R*OPEN FLOOR VRU #: 001399500 |
| | 4/30/07 | DA | no plans |
| B105 02 | 5/01/07 | MR | R*OPEN FLOOR VRU #: 001400738 |
| | 5/01/07 | AP | |
| R425 01 | 5/16/07 | MR | FOUR TRADE ROUGH IN VRU #: 001410125 |
| | 5/16/07 | CA | per builder |
| R425 02 | 5/31/07 | MR | FOUR TRADE ROUGH IN VRU #: 001419332 |
| | 5/31/07 | DA | 1. remove untreated wood from under front threshold and flash with galv or plastic at front and back doors... no aluminum 2. box around plumb stack in garage and fireblock on rough 3. protect gas line at fireplace entry and seal up hole 4. outlet needed in small wall in MBR 5. no boots on roof 6. support or secure all water pipes @ 32" and fiknish plumbing 7. trusses drilled or notched by plumber need a letter to show correct repair |
| R425 03 | 6/08/07 | MR | FOUR TRADE ROUGH IN VRU #: 001425321 |
| | 6/08/07 | AP | |
| I129 01 | 6/15/07 | DT | R*INSULATION INSPECTION VRU #: 001429554 |
| | 6/15/07 | AP | |
| H824 01 | 6/19/07 | JW | ✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001433655 |
| | 6/19/07 | AP | |
| R429 02 | 8/13/07 | TI | FOUR TRADE FINAL VRU #: 001464478 |
| | 8/13/07 | CA | |
| R429 01 | 8/13/07 | TI | FOUR TRADE FINAL VRU #: 001464460 |
| | 8/10/07 | CA | |
| R429 03 | 8/14/07 | MR | FOUR TRADE FINAL VRU #: 001465921 |
| | 8/14/07 | CA | per cust. |
| R429 04 | 8/16/07 | TI | FOUR TRADE FINAL VRU #: 001468172 |

AP-MB

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3
Type of Construction: II
Owner of Building: RBC Homes
Building Address: 18 Kingston
Zoning District: _____
Zoning Permit No.: _____

Conditional Use Permit No.: _____
Building Permit No.: 06-50016029
Electrical Permit No.: 11
Insulation Permit No.: 11
Plumbing Permit No.: 11
Mech. Permit No.: _____
Envir. C.O. No.: _____

Date: 8-16-7

Mike Ream
Building Official

Zoning Official