

ADDRESS . . : 36 TORY CT  
CONTRACTOR : BECKER CHAD WILLIAM  
OWNER . . . : DENARLA ENTERPRISES LLC #63  
PARCEL . . . : 03-0507- - -0226- -81-  
APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : COLONIAL HILLS #63  
210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
LEFT ON DOCS RD 1MILE ON LEFT GO TO  
TORY CT. JDAVIS ----

SUBDIV: COLONIAL HILLS  
PHONE : (910) 263-2612  
PHONE : (910) 890-1275

STRUCTURE: 000 000 45X55 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 <u>3-28-7</u>	TI <u>AP-CE</u>	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPS INSPECTIONS SINCE THEY ARE SIDE BY SIDE.

COMMENTS AND NOTES

*T-pole 10062*

-----

ADDRESS . . : 36 TORY CT  
 CONTRACTOR : BECKER CHAD WILLIAM  
 OWNER . . . : DENARLA ENTERPRISES LLC #63  
 PARCEL . . . : 03-0507- - -0226- -81-  
 APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : COLONIAL HILLS #63  
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
 LEFT ON DOCS RD 1MILE ON LEFT GO TO  
 TORY CT. JDAVIS ----

SUBDIV: COLONIAL HILLS  
 PHONE : (910) 263-2612  
 PHONE : (910) 890-1275

-----

STRUCTURE: 000 000 45X55 3BR W/GARAGE  
 FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 3/28/07	CE AP	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPS INSPECTIONS SINCE THEY ARE SIDE BY SIDE. T-pole approved. ce
B101 01	4/05/07 <u>4-5-7</u>	TI <u>AP-CE</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001384643

----- COMMENTS AND NOTES -----

-----  
ADDRESS . : 36 TORY CT  
CONTRACTOR : BECKER CHAD WILLIAM  
OWNER . . : DENARLA ENTERPRISES LLC #63  
PARCEL . . : 03-0507- - -0226- -81-  
APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : COLONIAL HILLS #63  
210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
LEFT ON DOCS RD 1MILE ON LEFT GO TO  
TORY CT. JDAVIS ----  
-----

STRUCTURE: 000 000 45X55 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 3/28/07	CE AP	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPTS INSPECTIONS SINCE THEY ARE SIDE BY SIDE. T-pole approved. ce
B101 01	4/05/07 4/05/07	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001384643
A814 01	4/13/07	TI	ADDRESS CONFIRMATION VRU #: 001388727
B103 01	4/13/07	TI <i>AP JH</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388719

----- COMMENTS AND NOTES -----

-----

ADDRESS . : 36 TORY CT  
 CONTRACTOR : BECKER CHAD WILLIAM  
 OWNER . . : DENARLA ENTERPRISES LLC #63  
 PARCEL . . : 03-0507- - -0226- -81-  
 APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : COLONIAL HILLS #63  
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
 LEFT ON DOCS RD 1MILE ON LEFT GO TO  
 TORY CT. JDAVIS ----

-----

STRUCTURE: 000 000 45X55 3BR W/GARAGE  
 FLOOD ZONE . . . . : FLOOD ZONE X

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 3/28/07	CE AP	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPTS INSPECTIONS SINCE THEY ARE SIDE BY SIDE. T-pole approved. ce
B101 01	4/05/07 4/05/07	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001384643
A814 01	4/13/07 4/13/07	JH AP	ADDRESS CONFIRMATION VRU #: 001388727
B103 01	4/13/07 4/13/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388719
A814 02	4/13/07 4/13/07	FB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001389931 36 TORY CT LOT 63 36 TORY CT LOT 63
B105 01	4/24/07	TI	R*OPEN FLOOR VRU #: 001395508

\_\_\_\_\_ *AP. MR*

----- COMMENTS AND NOTES -----

ADDRESS : 36 TORY CT  
CONTRACTOR : BECKER CHAD WILLIAM  
OWNER : DENARLA ENTERPRISES LLC #63  
PARCEL : 03-0507- - -0226- -81-  
APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : COLONIAL HILLS #63  
210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
LEFT ON DOCS RD 1MILE ON LEFT GO TO  
TORY CT. JDAVIS ----

STRUCTURE: 000 000 45X55 3BR W/GARAGE

FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 3/28/07	CE AP	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPS INSPECTIONS SINCE THEY ARE SIDE BY SIDE. T-pole approved. ce
B101 01	4/05/07 4/05/07	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001384643
A814 01	4/13/07 4/13/07	JH AP	ADDRESS CONFIRMATION VRU #: 001388727
B103 01	4/13/07 4/13/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388719
A814 02	4/13/07 4/13/07	FB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001389931 36 TORY CT LOT 63 36 TORY CT LOT 63
B105 01	4/24/07 4/24/07	MR AP	R*OPEN FLOOR VRU #: 001395508
R425 01	5/23/07	TI	FOUR TRADE ROUGH IN VRU #: 001414523

DL-MR

COMMENTS AND NOTES

ADDRESS . . : 36 TORY CT  
 CONTRACTOR : BECKER CHAD WILLIAM  
 OWNER . . . : DENARLA ENTERPRISES LLC #63  
 PARCEL . . . : 03-0507- - -0226- -81-  
 APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)

SUBDIV: COLONIAL HILLS  
 PHONE : (910) 263-2612  
 PHONE : (910) 890-1275

DIRECTIONS : COLONIAL HILLS #63  
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
 LEFT ON DOCS RD 1MILE ON LEFT GO TO  
 TORY CT. JDAVIS ----

STRUCTURE: 000 000 45X55 3BR W/GARAGE  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 3/28/07	CE AP	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPS INSPECTIONS SINCE THEY ARE SIDE BY SIDE. T-pole approved. ce
B101 01	4/05/07 4/05/07	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001384643
A814 01	4/13/07 4/13/07	JH AP	ADDRESS CONFIRMATION VRU #: 001388727
B103 01	4/13/07 4/13/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388719
A814 02	4/13/07 4/13/07	FB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001389931 36 TORY CT LOT 63 36 TORY CT LOT 63
B105 01	4/24/07 4/24/07	MR AP	R*OPEN FLOOR VRU #: 001395508
R425 01	5/23/07 5/23/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001414523 <del>bolts</del> bolts needed in garage <del>nails</del> nailsguards at panel <del>outlet</del> outlet needed at front . accessible from grade Will check on insul. .. OK to side and insulate
I129 01	5/29/07	TI	R*INSULATION INSPECTION VRU #: 001417336
R425 02	5/29/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001417484

AP-MR  
 AP-MR

COMMENTS AND NOTES

-----

ADDRESS . . : 36 TORY CT  
 CONTRACTOR : BECKER CHAD WILLIAM  
 OWNER . . . : DENARLA ENTERPRISES LLC #63  
 PARCEL . . . : 03-0507- - -0226- -81-  
 APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : COLONIAL HILLS #63  
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
 LEFT ON DOCS RD 1MILE ON LEFT GO TO  
 TORY CT. JDAVIS ----

-----

SUBDIV: COLONIAL HILLS  
 PHONE : (910) 263-2612  
 PHONE : (910) 890-1275

-----

STRUCTURE: 000 000 45X55 3BR W/GARAGE  
 FLOOD ZONE . . . . : FLOOD ZONE X

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 3/28/07	CE AP	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPS INSPECTIONS SINCE THEY ARE SIDE BY SIDE. T-pole approved. ce
B101 01	4/05/07 4/05/07	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001384643
A814 01	4/13/07 4/13/07	JH AP	ADDRESS CONFIRMATION VRU #: 001388727
B103 01	4/13/07 4/13/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388719
A814 02	4/13/07 4/13/07	FB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001389931 ✓36 TORY CT LOT 63 36 TORY CT LOT 63
B105 01	4/24/07 4/24/07	MR AP	R*OPEN FLOOR VRU #: 001395508
R425 01	5/23/07 5/23/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001414523 1. bolts needed in garage 2. nailsguards at panel 3. outlet needed at front . accessible from grade Will check on insul. .. OK to side and insulate
I129 01	5/29/07 5/29/07	MR AP	R*INSULATION INSPECTION VRU #: 001417336
R425 02	5/29/07 5/29/07	MR AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001417484
H824 01	7/31/07 7/31/07	JW AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001457704
R429 01	1/07/08 <u>1/7/08</u>	TI <u>DA DT</u>	FOUR TRADE FINAL VRU #: 001543149

-----

COMMENTS AND NOTES

-----

ADDRESS . : 36 TORY CT  
CONTRACTOR : BECKER CHAD WILLIAM  
OWNER . . : DENARLA ENTERPRISES LLC #63  
PARCEL . . : 03-0507- - -0226- -81-  
APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : COLONIAL HILLS #63  
210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
LEFT ON DOCS RD 1MILE ON LEFT GO TO  
TORY CT. JDAVIS ----

SUBDIV: COLONIAL HILLS  
PHONE : (910) 263-2612  
PHONE : (910) 890-1275

STRUCTURE: 000 000 45X55 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 3/28/07	CE AP	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPS INSPECTIONS SINCE THEY ARE SIDE BY SIDE. T-pole approved. ce
B101 01	4/05/07 4/05/07	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001384643
A814 01	4/13/07 4/13/07	JH AP	ADDRESS CONFIRMATION VRU #: 001388727
B103 01	4/13/07 4/13/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388719
A814 02	4/13/07 4/13/07	FB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001389931 ✓ 36 TORY CT LOT 63 36 TORY CT LOT 63
B105 01	4/24/07 4/24/07	MR AP	R*OPEN FLOOR VRU #: 001395508
R425 01	5/23/07 5/23/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001414523 1. bolts needed in garage 2. nailsguards at panel 3. outlet needed at front . accessible from grade Will check on insul. .. OK to side and insulate
I129 01	5/29/07 5/29/07	MR AP	R*INSULATION INSPECTION VRU #: 001417336
R425 02	5/29/07 5/29/07	MR AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001417484
H824 01	7/31/07 7/31/07	JW AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001457704
R429 01	1/07/08 1/07/08	DT DA	FOUR TRADE FINAL VRU #: 001543149 1. No 911 numbers on front of house. 2. Must have 6 inches of fall for 10 ft at rear of house.
R429 02	1/09/08 <u>1/9/08</u>	TI <u>DP DT</u>	FOUR TRADE FINAL VRU #: 001544485

----- COMMENTS AND NOTES -----



-----  
 ADDRESS : 36 TORY CT  
 CONTRACTOR : BECKER CHAD WILLIAM  
 OWNER : DENARLA ENTERPRISES LLC #63  
 PARCEL : 03-0507- - -0226- -81-  
 APPL NUMBER: 06-50016035 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : COLONIAL HILLS #63  
 210 RIGHT ON RAY RD RIGHT ON NURSERY RD  
 LEFT ON DOCS RD 1MILE ON LEFT GO TO  
 TORY CT. JDAVIS -----

SUBDIV: COLONIAL HILLS  
 PHONE : (910) 263-2612  
 PHONE : (910) 890-1275

-----  
**STRUCTURE: 000 000 45X55 3BR W/GARAGE**  
 FLOOD ZONE . . . . : FLOOD ZONE X

-----  
**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E207 01	3/28/07 3/28/07	CE AP	R*ELEC TEMP SERVICE POLE VRU #: 001378991 HAS NOT HAD ANY OTHER INSPECTIONS ON THIS LOT BUT HOPED TO GET BOTH TSPS INSPECTIONS SINCE THEY ARE SIDE BY SIDE. T-pole approved. ce
B101 01	4/05/07 4/05/07	CE AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001384643
A814 01	4/13/07 4/13/07	JH AP	ADDRESS CONFIRMATION VRU #: 001388727
B103 01	4/13/07 4/13/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001388719
A814 02	4/13/07 4/13/07	FB AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001389931 ✓36 TORY CT LOT 63 36 TORY CT LOT 63
B105 01	4/24/07 4/24/07	MR AP	R*OPEN FLOOR VRU #: 001395508
R425 01	5/23/07 5/23/07	MR DA	FOUR TRADE ROUGH IN VRU #: 001414523 1. bolts needed in garage 2. nailsguards at panel 3. outlet needed at front . accessible from grade Will check on insul. .. OK to side and insulate
I129 01	5/29/07 5/29/07	MR AP	R*INSULATION INSPECTION VRU #: 001417336
R425 02	5/29/07 5/29/07	MR AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001417484
H824 01	7/31/07 7/31/07	JW AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001457704
R429 01	1/07/08 1/07/08	DT DA	✓FOUR TRADE FINAL VRU #: 001543149 1. No 911 numbers on front of house. 2. Must have 6 inches of fall for 10 ft at rear of house.
R429 02	1/09/08 1/09/08	DT DP	FOUR TRADE FINAL VRU #: 001544485 1. Must have positive drainage away from entire rear of home, including under the deck.
R131 01	1/11/08	TI	ONE TRADE FINAL VRU #: 001545854

*AP-MR*

-----  
 COMMENTS AND NOTES -----

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3  
Type of Construction: I  
Owner of Building: Dencia Ent.  
Building Address: 36 Tory Ct.  
Zoning District: \_\_\_\_\_  
Zoning Permit No.: \_\_\_\_\_

Conditional Use Permit No.: \_\_\_\_\_  
Building Permit No.: 06-50016035  
Electrical Permit No.: "  
Insulation Permit No.: "  
Plumbing Permit No.: "  
Mech. Permit No.: "  
Envir. C.O. No.: \_\_\_\_\_

Date: 1-11-8  
Mh Reaw  
Building Official

\_\_\_\_\_  
Zoning Official