

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Mitchell C Coats PROPERTY LOCATION: SR 1551 COUNTY LANE ROAD
 NEW REPAIR EXPANSION SUBDIVISION: DONNIE DUPREE LOT # 3
 Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% REDUCTION STUB PLUMBING OUT HERE TO ACHIEVE
 Projected Daily Flow: 360 GPD Shallow TANK Placement for 12"
 Number of bedrooms: 3 Number of Occupants: 6 max DITCH DEPTHS
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years
 Permit conditions: STUB PLUMBING OUT HERE TO ACHIEVE Shallow TANK No expiration
Placement for 17" DITCH DEPTHS

Authorized State Agent: James E. Markham Date: 11-16-06 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Mitchell C Coats PROPERTY LOCATION: SR 1551 COUNTY LANE ROAD
 SUBDIVISION DONNIE DUPREE LOT # 3
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% REDUCTION (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable) 25% REDUCTION system (Repair)

Installation Requirements/Conditions

1 X
 Septic Tank Size 1000 gallons Exact length of each trench 360 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: _____ inches
 Maximum Trench Depth of: 12" inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to $\pm 1/4"$ 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
 Conditions: SOLID PVC PIPE TO CONNECT DITCHES 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH
 Authorized State Agent: James E. Markham Date: 11-16-06
 Construction Authorization Expiration Date: 11-16-11

HTE# 06-5-16070

Permit # 23336

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: SR 1551 County Line RD

ISSUED TO: Mitchell C Coats SUBDIVISION DORNEE DUNN LOT # 3

Authorized State Agent: James E. Markant @ 168 Date: 11-16-06

* TANK WILL BE OUT OF GROUND
TO ACHIEVE 12" DITCH DEPTHS

* 6" MINIMUM COVER REQUIRED
OVER ENTIRE DRAINFIELD.

