
ADDRESS . . : 144 ADRIAN ST
 CONTRACTOR : SCOTT LEE HOMES INC
 OWNER . . . : SCOTT LEE HOMES INC #24
 PARCEL . . . : 05-0635- - -0103- -40-
 APPL NUMBER: 06-50016125 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : JOHNATHAN RIDGE #24
 210 TOWARDS ANGIER LEFT ONTO HWY 55 TO
 42 THRU FUQUAY LEFT ONTO TRUELOVE S/D
 ON RIGHT 11/07/2006 01:48 PM JDAVIS

STRUCTURE: 000 000 77X45 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	1/24/07 <u>1.24.07</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001342682

COMMENTS AND NOTES -----

ADDRESS . : 144 ADRIAN ST
CONTRACTOR : SCOTT LEE HOMES INC
OWNER . . : SCOTT LEE HOMES INC #24
PARCEL . . : 05-0635- - -0103- -40-
APPL NUMBER: 06-50016125 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : JOHNATHAN RIDGE #24
210 TOWARDS ANGIER LEFT ONTO HWY 55 TO
42 THRU FUQUAY LEFT ONTO TRUELOVE S/D
ON RIGHT 11/07/2006 01:48 PM JDAVIS

STRUCTURE: 000 000 77X45 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/24/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001342682
	1/24/07	AP	
B103 01	2/15/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001354620
	<u>2/15/07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 144 ADRIAN ST
CONTRACTOR : SCOTT LEE HOMES INC
OWNER : SCOTT LEE HOMES INC #24
PARCEL : 05-0635- - -0103- -40-
APPL NUMBER: 06-50016125 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : JOHNATHAN RIDGE #24
210 TOWARDS ANGIER LEFT ONTO HWY 55 TO
42 THRU FUQUAY LEFT ONTO TRUELOVE S/D
ON RIGHT 11/07/2006 01:48 PM JDAVIS

SUBDIV: JONATHAN RIDGE
PHONE : (919) 553-2085
PHONE : (919) 553-2085

STRUCTURE: 000 000 77X45 3BR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/24/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001342682
	1/24/07	AP	
B103 01	2/15/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001354620
	2/16/07	AP	
B105 01	2/20/07	TI	R*OPEN FLOOR VRU #: 001357037
	<u>2-20-07</u>	<u>AEBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 144 ADRIAN ST
 CONTRACTOR : SCOTT LEE HOMES INC
 OWNER . . : SCOTT LEE HOMES INC #24
 PARCEL . . : 05-0635- - -0103- -40-
 APPL NUMBER: 06-50016125 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : JOHNATHAN RIDGE #24
 210 TOWARDS ANGIER LEFT ONTO HWY 55 TO
 42 THRU FUQUAY LEFT ONTO TRUELOVE S/D
 ON RIGHT 11/07/2006 01:48 PM JDAVIS

SUBDIV: JONATHAN RIDGE
 PHONE : (919) 553-2085
 PHONE : (919) 553-2085

STRUCTURE: 000 000 77X45 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/24/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001342682
	1/24/07	AP	
B103 01	2/15/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001354620
	2/16/07	AP	
B105 01	2/20/07	BS	R*OPEN FLOOR VRU #: 001357037
	2/20/07	AE	1. Flash ends of girders within 1/2 inch of masonry. 2. Move vent or install steel angle lintel at front cantilever double. Ok to cover, check at rough-in
A814 01	3/16/07	TI	ADDRESS CONFIRMATION VRU #: 001372606
R425 01	<u>3/16/07</u> <u>3-16-07</u>	<u>TI</u> <u>DAB</u>	FOUR TRADE ROUGH IN VRU #: 001372598

COMMENTS AND NOTES

ADDRESS . . : 144 ADRIAN ST
 CONTRACTOR : SCOTT LEE HOMES INC
 OWNER . . . : SCOTT LEE HOMES INC #24
 PARCEL . . . : 05-0635- - -0103- -40-
 APPL NUMBER: 06-50016125 CP NEW RESIDENTIAL (SFD)

SUBDIV: JONATHAN RIDGE
 PHONE : (919) 553-2085
 PHONE : (919) 553-2085

DIRECTIONS : JOHNATHAN RIDGE #24
 210 TOWARDS ANGIER LEFT ONTO HWY 55 TO
 42 THRU FUQUAY LEFT ONTO TRUELOVE S/D
 ON RIGHT 11/07/2006 01:48 PM JDAVIS

STRUCTURE: 000 000 77X45 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/24/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001342682
	1/24/07	AP	
B103 01	2/15/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001354620
	2/16/07	AP	
B105 01	2/20/07	BS	R*OPEN FLOOR VRU #: 001357037
	2/20/07	AE	1. Flash ends of girders within 1/2 inch of masonry. 2. Move vent or install steel angle lintel at front cantilever double. Ok to cover, check at rough-in
R425 01	3/16/07	BS	FOUR TRADE ROUGH IN VRU #: 001372598
	3/16/07	DA	1. Install rear door. 2. Install missing truss bracing (attached) 3. Washing machine box is too low (attached) 4. Make sure stairs meet code at final inspection (attached) 5. Rodent proof all tub drains with sheet metal (attached) 6. Install and seal HVAC floor boots. ok to side...DO NOT INSULATE
A814 01	3/16/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001372606
	3/16/07	AP	144 Adrian St Lot 24
R427 01	3/21/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001374917
	3/21/07	DA	1. Brace trusses at dining room trey...they were missed. 2. Violation written up at open floor not corrected...Front baydouble sitting on top of foundation vent. ok to insulate, check at insulation
I129 01	3/23/07	TI	R*INSULATION INSPECTION VRU #: 001376458
	<u>3-23-07</u>	<u>APBS</u>	
R427 02	3/23/07	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001376748
	<u>3-23-07</u>	<u>VJ</u>	

COMMENTS AND NOTES

ADDRESS . . : 144 ADRIAN ST
 CONTRACTOR : SCOTT LEE HOMES INC
 OWNER . . : SCOTT LEE HOMES INC #24
 PARCEL . . : 05-0635- - -0103- -40-
 APPL NUMBER: 06-50016125 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : JOHNATHAN RIDGE #24
 210 TOWARDS ANGIER LEFT ONTO HWY 55 TO
 42 THRU FUQUAY LEFT ONTO TRUELOVE S/D
 ON RIGHT 11/07/2006 01:48 PM JDAVIS

SUBDIV: JONATHAN RIDGE
 PHONE : (919) 553-2085
 PHONE : (919) 553-2085

STRUCTURE: 000 000 77X45 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/24/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001342682
	1/24/07	AP	
B103 01	2/15/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001354620
	2/16/07	AP	
B105 01	2/20/07	BS	R*OPEN FLOOR VRU #: 001357037
	2/20/07	AE	1. Flash ends of girders within 1/2 inch of masonry. 2. Move vent or install steel angle lintel at front cantilever double. Ok to cover, check at rough-in
R425 01	3/16/07	BS	FOUR TRADE ROUGH IN VRU #: 001372598
	3/16/07	DA	1. Install rear door. 2. Install missing truss bracing (attached) 3. Washing machine box is too low (attached) 4. Make sure stairs meet code at final inspection (attached) 5. Rodent proof all tub drains with sheet metal (attached) 6. Install and seal HVAC floor boots. ok to side...DO NOT INSULATE
A814 01	3/16/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001372606
	3/16/07	AP	✓144 Adrian St Lot 24
R427 01	3/21/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001374917
	3/21/07	DA	1. Brace trusses at dining room trey...they were missed. 2. Violation written up at open floor not corrected...Front baydouble sitting on top of foundation vent. ok to insulate, check at insulation
I129 01	3/23/07	BS	R*INSULATION INSPECTION VRU #: 001376458
	3/23/07	AP	
R427 02	3/23/07	BS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001376748
	3/23/07	AP	
H824 01	6/06/07	BM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001425586
	6/06/07	AP	
R429 01	6/11/07	TI	FOUR TRADE FINAL VRU #: 001426774
	<u>6-11-07</u>	<u>APBS</u>	

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>SFH</u>	Conditional Use Permit No.: _____
Type of Construction: <u>V</u>	Building Permit No.: <u>0</u>
Owner of Building: <u>Sec 4 Lee Homes Inc</u>	Electrical Permit No.: _____
Building Address: <u>144 Adrian St</u>	Insulation Permit No.: _____
Zoning District: _____	Plumbing Permit No.: <u>do 500/16/25</u>
Zoning Permit No.: _____	Mech. Permit No.: _____
Date: <u>6-11-07</u>	Envir. C.O. No.: _____
<u>Brad Sitter</u> Building Official	_____ Zoning Official