

ADDRESS . . : 85868 *UNASSIGNED

SUBDIV: PAD PARTNERS

CONTRACTOR :

PHONE :

OWNER . . . : DAWSON TRAVIS & NICOLE #5

PHONE : (919) 552-0246

PARCEL . . . : 05-0624- - -0075- -22-

APPL NUMBER: 06-50016129 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : TAKE 401 TOWARDS FUQUAY TURN LEFT ON
CHRISTIAN LIGHT RD TAKE CHRISTIAN LIGHT
TO COKESBURY RD TURN LEFT ON COKESBURY
AT BOBAND NANS GO DOWN PAST OAKRIDGE
RIVER RD AND PAST BALL RD PASS DEWAR
ST ON RIGHT AND LOT IS ON RIGHT PAST
MOBILE HOME. JDAVIS 11/8/06

STRUCTURE: 000 000 54X52 4BR

FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|----------------------------|-------------------|--|
| B101 01 | 11/28/06 11/28/06 | BS CA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314244 per phone call |
| B101 02 | 11/29/06 11/29/06 | BS CA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314913 If possible could this inspection be done mid morning on the 29th sometime before 12 per phone call |
| B101 03 | 11/30/06 <i>1' 3006</i> | TI <i>APBS</i> | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001315415 |

----- COMMENTS AND NOTES -----

ADDRESS : 3754 COKESEBURY RD
 SUBDIV: PAD PARTNERS
 CONTRACTOR : DAWSON TRAVIS & NICOLE #5
 OWNER : . . . : 05-0624-0075-22
 PARCEL . . . : 05-0624-0075-22
 APPL NUMBER: 06-50016129 CP NEW RESIDENTIAL (SPD)
 DIRECTIONS : TAKE 401 TOWARDS FUQUAY TURN LEFT ON
 CHRISTIAN LIGHT RD TAKE CHRISTIAN LIGHT
 TO COKESEBURY RD TURN LEFT ON COKESEBURY
 AT BOBAND NANS GO DOWN PAST OAKRIDGE
 RIVER RD AND PAST BALL RD PASS DEWAR
 ST ON RIGHT AND LOT IS ON RIGHT PAST
 MOBILE HOME. JDAVIS 11/8/06
 PHONE : (919) 552-0246

STRUCTURE: 000 000 54X52 4BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSE 00 CP * SPD

| TYPE/SQ | REQUESTED | INSPECTION | DESCRIPTION |
|---------|-----------|------------|--|
| TYPE/SQ | COMPLETED | RESULT | RESULTS/COMMENTS |
| B101 01 | 11/28/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314244 per phone call |
| B101 02 | 11/28/06 | CA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314913 If possible could this inspection be done mid morning on the 29th sometime before 12 per phone call |
| B101 02 | 11/29/06 | CA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001315415 per phone call |
| B101 03 | 11/30/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001321314 ADDRESS CONFIRMATION VRU #: 001321314 |
| A814 01 | 12/12/06 | FB | 3754 COKESEBURY RD LOT 5-A |
| B103 01 | 12/12/06 | AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001321595 |

12-12-06 DAB

COMMENTS AND NOTES

ADDRESS . : 3754 COKESBURY RD
CONTRACTOR :
OWNER . . : DAWSON TRAVIS & NICOLE #5
PARCEL . . : 05-0624- - -0075- -22-
APPL NUMBER: 06-50016129 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TAKE 401 TOWARDS FUQUAY TURN LEFT ON
CHRISTIAN LIGHT RD TAKE CHRISTIAN LIGHT
TO COKESBURY RD TURN LEFT ON COKESBURY
AT BOBAND NANS GO DOWN PAST OAKRIDGE
RIVER RD AND PAST BALL RD PASS DEWAR
ST ON RIGHT AND LOT IS ON RIGHT PAST
MOBILE HOME. JDAVIS 11/8/06

STRUCTURE: 000 000 54X52 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|-----------------------------|-------------------|---|
| B101 01 | 11/28/06 11/28/06 | BS CA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314244 per phone call |
| B101 02 | 11/29/06 11/29/06 | BS CA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314913 If possible could this inspection be done mid morning on the 29th sometime before 12 per phone call |
| B101 03 | 11/30/06 11/30/06 | BS AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001315415 |
| A814 01 | 12/12/06 12/11/06 | FB AP | ADDRESS CONFIRMATION VRU #: 001321314 3754 COKESBURY RD LOT 5-A |
| B103 01 | 12/12/06 12/12/06 | BS DA | R*BLDG FOUND & TEMP SVC POLE VRU #: 001321595 3 piers not centered or hanging off their footing. dig out footing, pin with rebar and call for reinspection. do not frame |
| B103 02 | 12/13/06 <u>12.13.06</u> | TI <u>ADBS</u> | R*BLDG FOUND & TEMP SVC POLE VRU #: 001322825 |

----- COMMENTS AND NOTES -----

ADDRESS : 3754 COKESBURY RD
CONTRACTOR :
OWNER : DAWSON TRAVIS & NICOLE #5
PARCEL : 05-0624- - -0075- -22-
APPL NUMBER: 06-50016129 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TAKE 401 TOWARDS FUQUAY TURN LEFT ON
CHRISTIAN LIGHT RD TAKE CHRISTIAN LIGHT
TO COKESBURY RD TURN LEFT ON COKESBURY
AT BOBAND NANS GO DOWN PAST OAKRIDGE
RIVER RD AND PAST BALL RD PASS DEWAR
ST ON RIGHT AND LOT IS ON RIGHT PAST
MOBILE HOME. JDAVIS 11/8/06

SUBDIV: PAD PARTNERS
PHONE :
PHONE : (919) 552-0246

STRUCTURE: 000 000 54X52 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 11/28/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314244 |
| | 11/28/06 | CA | per phone call |
| B101 02 | 11/29/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314913 |
| | 11/29/06 | CA | If possible could this inspection be done mid morning on the 29th sometime before 12 per phone call |
| B101 03 | 11/30/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001315415 |
| | 11/30/06 | AP | |
| A814 01 | 12/12/06 | FB | ADDRESS CONFIRMATION VRU #: 001321314 |
| | 12/11/06 | AP | 3754 COKESBURY RD LOT 5-A |
| B103 01 | 12/12/06 | BS | R*BLDG FOUND & TEMP SVC POLE VRU #: 001321595 |
| | 12/12/06 | DA | 3 piers not centered or hanging off their footing. dig out footing, pin with rebar and call for reinspection. do not frame |
| B103 02 | 12/13/06 | BS | R*BLDG FOUND & TEMP SVC POLE VRU #: 001322825 |
| | 12/13/06 | AP | |
| B105 01 | 12/15/06 | BS | R*OPEN FLOOR VRU #: 001324052 |
| | 12/15/06 | AP | |
| R425 01 | 1/17/07 | MR | FOUR TRADE ROUGH IN VRU #: 001338573 |
| | 1/17/07 | DA | Flush porch and under doors Install valley bracing under lvl's not ridge Flush over windows so water sheds out not in plumbing OK |
| R425 02 | 1/19/07 | TI | FOUR TRADE ROUGH IN VRU #: 001340203 |

AP-mp

COMMENTS AND NOTES

ADDRESS : 3754 COKESBURY RD SUBDIV: PAD PARTNERS
CONTRACTOR : PHONE :
OWNER : DAWSON TRAVIS & NICOLE #5 PHONE : (919) 552-0246
PARCEL : 05-0624- - -0075- -22-
APPL NUMBER: 06-50016129 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TAKE 401 TOWARDS FUQUAY TURN LEFT ON
CHRISTIAN LIGHT RD TAKE CHRISTIAN LIGHT
TO COKESBURY RD TURN LEFT ON COKESBURY
AT BOBAND NANS GO DOWN PAST OAKRIDGE
RIVER RD AND PAST BALL RD PASS DEWAR
ST ON RIGHT AND LOT IS ON RIGHT PAST
MOBILE HOME. JDAVIS 11/8/06

STRUCTURE: 000 000 54X52 4BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 11/28/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314244 |
| | 11/28/06 | CA | per phone call |
| B101 02 | 11/29/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314913 |
| | 11/29/06 | CA | If possible could this inspection be done mid morning on the 29th sometime before 12 per phone call |
| B101 03 | 11/30/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001315415 |
| | 11/30/06 | AP | |
| A814 01 | 12/12/06 | FB | ADDRESS CONFIRMATION VRU #: 001321314 |
| | 12/11/06 | AP | 3754 COKESBURY RD LOT 5-A |
| B103 01 | 12/12/06 | BS | R*BLDG FOUND & TEMP SVC POLE VRU #: 001321595 |
| | 12/12/06 | DA | 3 piers not centered or hanging off their footing. dig out footing, pin with rebar and call for reinspection. do not frame |
| B103 02 | 12/13/06 | BS | R*BLDG FOUND & TEMP SVC POLE VRU #: 001322825 |
| | 12/13/06 | AP | |
| B105 01 | 12/15/06 | BS | R*OPEN FLOOR VRU #: 001324052 |
| | 12/15/06 | AP | |
| R425 01 | 1/17/07 | MR | FOUR TRADE ROUGH IN VRU #: 001338573 |
| | 1/17/07 | DA | flash porch and under doors install valley bracing under lvl's not ridge flash over windows so water sheds out not in plumbing OK |
| R425 02 | 1/19/07 | MR | FOUR TRADE ROUGH IN VRU #: 001340203 |
| | 1/19/07 | AP | |
| I129 01 | 1/29/07 | TI | R*INSULATION INSPECTION VRU #: 001344803 |
| | <u>1-29-07</u> | <u>DABK</u> | |

COMMENTS AND NOTES

ADDRESS . . : 3754 COKESBURY RD SUBDIV: PAD PARTNERS
 CONTRACTOR : PHONE :
 OWNER . . : DAWSON TRAVIS & NICOLE #5 PHONE : (919) 552-0246
 PARCEL . . : 05-0624- - -0075- -22-
 APPL NUMBER: 06-50016129 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TAKE 401 TOWARDS FUQUAY TURN LEFT ON
 CHRISTIAN LIGHT RD TAKE CHRISTIAN LIGHT
 TO COKESBURY RD TURN LEFT ON COKESBURY
 AT BOBAND NANS GO DOWN PAST OAKRIDGE
 RIVER RD AND PAST BALL RD PASS DEWAR
 ST ON RIGHT AND LOT IS ON RIGHT PAST
 MOBILE HOME. JDAVIS 11/8/06

STRUCTURE: 000 000 54X52 4BR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 11/28/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314244 |
| | 11/28/06 | CA | per phone call |
| B101 02 | 11/29/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314913 |
| | 11/29/06 | CA | If possible could this inspection be done mid morning on the 29th sometime before 12 per phone call |
| B101 03 | 11/30/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001315415 |
| | 11/30/06 | AP | |
| A814 01 | 12/12/06 | FB | ADDRESS CONFIRMATION VRU #: 001321314 |
| | 12/11/06 | AP | 3754 COKESBURY RD LOT 5-A |
| B103 01 | 12/12/06 | BS | R*BLDG FOUND & TEMP SVC POLE VRU #: 001321595 |
| | 12/12/06 | DA | 3 piers not centered or hanging off their footing. dig out footing, pin with rebar and call for reinspection. do not frame |
| B103 02 | 12/13/06 | BS | R*BLDG FOUND & TEMP SVC POLE VRU #: 001322825 |
| | 12/13/06 | AP | |
| B105 01 | 12/15/06 | BS | R*OPEN FLOOR VRU #: 001324052 |
| | 12/15/06 | AP | |
| R425 01 | 1/17/07 | MR | FOUR TRADE ROUGH IN VRU #: 001338573 |
| | 1/17/07 | DA | flash porch and under doors install valley bracing under lvl's not ridge flash over windows so water sheds out not in plumbing OK |
| R425 02 | 1/19/07 | MR | FOUR TRADE ROUGH IN VRU #: 001340203 |
| | 1/19/07 | AP | |
| I129 01 | 1/29/07 | BS | R*INSULATION INSPECTION VRU #: 001344803 |
| | 1/29/07 | DA | 1.pack windows and doors with insulation. 2.Bonus room floor not insulated (for future reference) 3. No soffit or gable vents. Only ridge vent.ING FOAM. THIS WILL DAMAGE THE WINDOWS 2. The floor of the bonus room above garage is not insulated. While it is not needed because it is unfinished, there will be no feasible way to insulate it at a later date without removing the sheetrock in the garage ceiling. 3. There is no attic ventilation. There are ridge vents, but no soffit ventilation or gable vents to create cross ventilation. Add one or the other before final inspection. |
| I129 02 | 1/31/07 | TI | R*INSULATION INSPECTION VRU #: 001346683 |

1-31-07 APBS

ADDRESS . : 3754 COKESBURY RD
 CONTRACTOR :
 OWNER . . : DAWSON TRAVIS & NICOLE #5
 PARCEL . . : 05-0624- - -0075- -22-
 APPL NUMBER: 06-50016129 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TAKE 401 TOWARDS FUQUAY TURN LEFT ON
 CHRISTIAN LIGHT RD TAKE CHRISTIAN LIGHT
 TO COKESBURY RD TURN LEFT ON COKESBURY
 AT BOBAND NANS GO DOWN PAST OAKRIDGE
 RIVER RD AND PAST BALL RD PASS DEWAR
 ST ON RIGHT AND LOT IS ON RIGHT PAST
 MOBILE HOME. JDAVIS 11/8/06

SUBDIV: PAD PARTNERS
 PHONE :
 PHONE : (919) 552-0246

919-201-3841

STRUCTURE: 000 000 54X52 4BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|---|
| B101 01 | 11/28/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314244 |
| | 11/28/06 | CA | per phone call |
| B101 02 | 11/29/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001314913 |
| | 11/29/06 | CA | If possible could this inspection be done mid morning on the 29th sometime before 12 per phone call |
| B101 03 | 11/30/06 | BS | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001315415 |
| | 11/30/06 | AP | |
| A814 01 | 12/12/06 | FB | ADDRESS CONFIRMATION VRU #: 001321314 |
| | 12/11/06 | AP | ✓3754 COKESBURY RD LOT 5-A |
| B103 01 | 12/12/06 | BS | R*BLDG FOUND & TEMP SVC POLE VRU #: 001321595 |
| | 12/12/06 | DA | 3 piers not centered or hanging off their footing. dig out footing, pin with rebar and call for reinspection. do not frame |
| B103 02 | 12/13/06 | BS | R*BLDG FOUND & TEMP SVC POLE VRU #: 001322825 |
| | 12/13/06 | AP | |
| B105 01 | 12/15/06 | BS | R*OPEN FLOOR VRU #: 001324052 |
| | 12/15/06 | AP | |
| R425 01 | 1/17/07 | MR | FOUR TRADE ROUGH IN VRU #: 001338573 |
| | 1/17/07 | DA | flash porch and under doors install valley bracing under lvl's not ridge flash over windows so water sheds out not in plumbing OK |
| R425 02 | 1/19/07 | MR | FOUR TRADE ROUGH IN VRU #: 001340203 |
| | 1/19/07 | AP | |
| I129 01 | 1/29/07 | BS | R*INSULATION INSPECTION VRU #: 001344803 |
| | 1/29/07 | DA | 1.pack windows and doors with insulation. 2.Bonus room floor not insulated (for future reference) 3. No soffit or gable vents. Only ridge vent.ING FOAM. THIS WILL DAMAGE THE WINDOWS 2. The floor of the bonus room above garage is not insulated. While it is not needed because it is unfinished, there will be no feasible way to insulate it at a later date without removing the sheetrock in the garage ceiling. 3. There is no attic ventilation. There are ridge vents, but no soffit ventilation or gable vents to create cross ventilation. Add one or the other before final inspection. |
| I129 02 | 1/31/07 | BS | R*INSULATION INSPECTION VRU #: 001346683 |
| | 1/31/07 | AP | |
| H824 01 | 3/07/07 | BM | ✓ENVI. OPERATIONS PERMIT TIME: 17:00 VRU #: 001368489 |
| | 3/07/07 | AP | |
| R429 01 | 4/13/07 | TI | FOUR TRADE FINAL VRU #: 001389089 |

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SED

Type of Construction: V

Owner of Building: Travis Nicole Dawson

Building Address: 3754 Conshing Rd

Zoning District: _____

Zoning Permit No.: N/A

Date: 4-13-07
Bud Sutton

Building Official

~~Conditional Use Permit No.:~~ _____

Building Permit No.: 06-5-16129

Electrical Permit No.: 06-5-16129

Insulation Permit No.: 06-5-16129

Plumbing Permit No.: 06-5-16129

Mech. Permit No.: 06-5-16129

~~Envir. C.O. No.:~~ _____

Zoning Official _____