

ADDRESS . : 204 SADDLE LN  
CONTRACTOR : MOSS KENNETH A  
OWNER . . : INVESTMENT CHOICES VI LLC  
PARCEL . . : 11-0661- - -0100- -13-  
APPL NUMBER: 06-50016141 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 210 N PAST MCDONALDS LEFT AT  
LILLINGTON VET ON JOHNSON FARM RD 1ST  
RD TO RIGHT LOT 7 JB

SUBDIV: JOHNSON FARMS 34 LOTS  
PHONE : (910) 893-4875  
PHONE :

STRUCTURE: 000 000 50X50 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	<u>4/23/07</u> <u>4-23</u>	<u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001394501  KS

COMMENTS AND NOTES

ADDRESS . . : 204 SADDLE LN  
CONTRACTOR : MOSS KENNETH A  
OWNER . . . : INVESTMENT CHOICES VI LLC  
PARCEL . . . : 11-0661- - -0100- -13-  
APPL NUMBER: 06-50016141 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 210 N PAST MCDONALDS LEFT AT  
LILLINGTON VET ON JOHNSON FARM RD 1ST  
RD TO RIGHT LOT 7 JB

SUBDIV: JOHNSON FARMS 34 LOTS  
PHONE : (910) 893-4875  
PHONE :

STRUCTURE: 000 000 50X50 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001394501
	4/23/07	AP	
B103 01	4/30/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001398776

4-30-07 APB

COMMENTS AND NOTES

Fri 404 pm  
552-1378

ADDRESS . : 204 SADDLE LN  
CONTRACTOR : MOSS KENNETH A  
OWNER . . : INVESTMENT CHOICES VI LLC  
PARCEL . . : 11-0661- - -0100- -13-  
APPL NUMBER: 06-50016141 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 210 N PAST MCDONALDS LEFT AT  
LILLINGTON VET ON JOHNSON FARM RD 1ST  
RD TO RIGHT LOT 13 JB

SUBDIV: JOHNSON FARMS 34 LOTS  
PHONE : (910) 893-4875  
PHONE :

STRUCTURE: 000 000 50X50 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001394501
	4/23/07	AP	
B103 01	4/30/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001398776
	4/30/07	AP	
B105 01	5/02/07	TI	R*OPEN FLOOR VRU #: 001400923
	<u>5.2</u>	<u>AP</u>	
A814 01	5/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001398785
	5/01/07	AP	KS 204 Saddle Ln Lot 13

COMMENTS AND NOTES

ADDRESS . : 204 SADDLE LN  
CONTRACTOR : MOSS KENNETH A  
OWNER . . : INVESTMENT CHOICES VI LLC  
PARCEL . . : 11-0661- - -0100- -13-  
APPL NUMBER: 06-50016141 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 210 N PAST MCDONALDS LEFT AT  
LILLINGTON VET ON JOHNSON FARM RD 1ST  
RD TO RIGHT LOT 13 JB

SUBDIV: JOHNSON FARMS 34 LOTS  
PHONE : (910) 893-4875  
PHONE :

STRUCTURE: 000 000 50X50 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/07 4/23/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001394501
B103 01	4/30/07 4/30/07	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001398776
B105 01	5/02/07 5/02/07	KS AP	R*OPEN FLOOR VRU #: 001400923
A814 01	5/02/07 5/01/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001398785 204 Saddle Ln Lot 13
R425 01	5/24/07	TI	FOUR TRADE ROUGH IN VRU #: 001415043

5-24-07 DPBS

----- COMMENTS AND NOTES -----

ADDRESS : 204 SADDLE LN  
 CONTRACTOR : MOSS KENNETH A  
 OWNER : INVESTMENT CHOICES VI LLC  
 PARCEL : 11-0661- - -0100- -13-  
 APPL NUMBER: 06-50016141 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : 210 N PAST MCDONALDS LEFT AT  
 LILLINGTON VET ON JOHNSON FARM RD 1ST  
 RD TO RIGHT LOT 13 JB

SUBDIV: JOHNSON FARMS 34 LOTS  
 PHONE : (910) 893-4875  
 PHONE :

STRUCTURE: 000 000 50X50 3BDR  
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001394501
	4/23/07	AP	
B103 01	4/30/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001398776
	4/30/07	AP	
B105 01	5/02/07	KS	R*OPEN FLOOR VRU #: 001400923
	5/02/07	AP	
A814 01	5/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001398785
	5/01/07	AP	204 Saddle Ln Lot 13
R425 01	5/24/07	BS	FOUR TRADE ROUGH IN VRU #: 001415043
	5/24/07	DP	<ol style="list-style-type: none"> <li>1. Need tempered glass right of rear door.</li> <li>2. Need hurricane ties at cathedral rafters.</li> <li>3. Fireblock wall at rear of master shower ceiling.</li> <li>4. Double stiffknee at front valley</li> <li>5. Face nail a 2x under rear dormer shed rafters at top .</li> <li>6. They are overnotched.</li> <li>7. Firestop doorbell wire.</li> <li>8. Firestop HVAC lines at all top and bottom plates for attic unit.</li> <li>9. Insulation baffles must extend all the way to the break in the ceiling.</li> <li>10. No flashing at front porch .</li> <li>11. Tie back rafters to the left of front gable.</li> </ol> DO NOT INSULATE, DO NOT SIDE ANY PORTIONS OF THE FRONT PORCH. \$50.00 re fee
R225 01	5/30/07	TI	TWO TRADE ROUGH IN VRU #: 001417898
	<u>5-30-07</u>	<u>APBS</u>	

COMMENTS AND NOTES

ADDRESS . : 204 SADDLE LN  
CONTRACTOR : MOSS KENNETH A  
OWNER . . : INVESTMENT CHOICES VI LLC  
PARCEL . . : 11-0661- - -0100- -13-  
APPL NUMBER: 06-50016141 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 210 N PAST MCDONALDS LEFT AT  
LILLINGTON VET ON JOHNSON FARM RD 1ST  
RD TO RIGHT LOT 13 JB

SUBDIV: JOHNSON FARMS 34 LOTS  
PHONE : (910) 893-4875  
PHONE :

STRUCTURE: 000 000 50X50 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001394501
	4/23/07	AP	
B103 01	4/30/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001398776
	4/30/07	AP	
B105 01	5/02/07	KS	R*OPEN FLOOR VRU #: 001400923
	5/02/07	AP	
A814 01	5/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001398785
	5/01/07	AP	204 Saddle Ln Lot 13
R425 01	5/24/07	BS	FOUR TRADE ROUGH IN VRU #: 001415043
	5/24/07	DP	1. Need tempered glass right of rear door. 2. Need hurricane ties at cathedral rafters. 3. Fireblock wall at rear of master shower ceiling. 4. Double stiffknee at front valley 5. Face nail a 2x under rear dormer shed rafters at top . They are overnotched. 6. Firestop doorbell wire. 7. Firestop HVAC lines at all top and bottom plates for attic unit. 8. Insulation baffles must extend all the way to the break in the ceiling. 9. No flashing at front porch . 10. Tie back rafters to the left of front gable. DO NOT INSULATE, DO NOT SIDE ANY PORTIONS OF THE FRONT PORCH. \$50.00 re fee
R225 01	5/30/07	BS	TWO TRADE ROUGH IN VRU #: 001417898
	5/30/07	AP	
I129 01	6/01/07	TI	R*INSULATION INSPECTION VRU #: 001420448
	<u>5-1-07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 204 SADDLE LN  
CONTRACTOR : MOSS KENNETH A  
OWNER : INVESTMENT CHOICES VI LLC  
PARCEL : 11-0661- - -0100- -13-  
APPL NUMBER: 06-50016141 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : 210 N PAST MCDONALDS LEFT AT  
LILLINGTON VET ON JOHNSON FARM RD 1ST  
RD TO RIGHT LOT 13 JB

SUBDIV: JOHNSON FARMS 34 LOTS  
PHONE : (910) 893-4875  
PHONE :

STRUCTURE: 000 000 50X50 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/23/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001394501
	4/23/07	AP	
B103 01	4/30/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001398776
	4/30/07	AP	
B105 01	5/02/07	KS	R*OPEN FLOOR VRU #: 001400923
	5/02/07	AP	
A814 01	5/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001398785
	5/01/07	AP	✓204 Saddle Ln Lot 13
R425 01	5/24/07	BS	FOUR TRADE ROUGH IN VRU #: 001415043
	5/24/07	DP	1. Need tempered glass right of rear door. 2. Need hurricane ties at cathedral rafters. 3. Fireblock wall at rear of master shower ceiling. 4. Double stiffknee at front valley. 5. Face nail a 2x under rear dormer shed rafters at top. They are overnotched. 6. Firestop doorbell wire. 7. Firestop HVAC lines at all top and bottom plates for attic unit. 8. Insulation baffles must extend all the way to the break in the ceiling. 9. No flashing at front porch. 10. Tie back rafters to the left of front gable. DO NOT INSULATE, DO NOT SIDE ANY PORTIONS OF THE FRONT PORCH. \$50.00 re fee
R225 01	5/30/07	BS	TWO TRADE ROUGH IN VRU #: 001417898
	5/30/07	AP	
I129 01	6/01/07	BS	R*INSULATION INSPECTION VRU #: 001420448
	6/01/07	AP	
H824 01	6/07/07	JM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001426741
	6/07/07	AP	
R429 01	8/10/07	TI	FOUR TRADE FINAL VRU #: 001464392
	8-10	AP	

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential IV Conditional Use Permit No.: \_\_\_\_\_  
Type of Construction: Alter-Moss Building Permit No.: \_\_\_\_\_  
Owner of Building: 204 Saddle Ln Electrical Permit No.: \_\_\_\_\_  
Building Address: \_\_\_\_\_ Insulation Permit No.: \_\_\_\_\_  
Zoning District: \_\_\_\_\_ Plumbing Permit No.: \_\_\_\_\_  
Zoning Permit No.: \_\_\_\_\_ Mech. Permit No.: \_\_\_\_\_  
Date: 8-10-07 Envir. C.O. No.: \_\_\_\_\_  
K. Stath Building Official \_\_\_\_\_ Zoning Official