
ADDRESS . : 65 GATEWEST DR
TENANT, NBR: REVISION 2/15/07 NEW MAP
CONTRACTOR : QUEST DEVELOPMENT
OWNER . . : EVEN PAR DEVELOPMENT LLC
PARCEL . . : 01-0525-01- -0095- -04-
APPL NUMBER: 06-50016150 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT THEN RIGHT ON LEMUEL BLACK RD S/D
ON RIGHT LOT 4 JB

SUBDIV: GATEWEST 53 LOTS
PHONE : (910) 567-4686
PHONE :

STRUCTURE: 000 000 63X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/25/07	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001453518
		<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 65 GATEWEST DR SUBDIV: GATEWEST 53 LOTS
TENANT, NBR: REVISION 2/15/07 NEW MAP
CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 567-4686
OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
PARCEL . . : 01-0525-01- -0095- -04-
APPL NUMBER: 06-50016150 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT THEN RIGHT ON LEMUEL BLACK RD S/D
ON RIGHT LOT 4 JB

STRUCTURE: 000 000 63X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001453518
	7/25/07	AP	
B103 01	8/13/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001465523
	<u>8/13/07</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 65 GATEWEST DR SUBDIV: GATEWEST 53 LOTS
TENANT, NBR: REVISION 2/15/07 NEW MAP
CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 567-4686
OWNER : EVEN PAR DEVELOPMENT LLC PHONE :
PARCEL : 01-0525-01- -0095- -04-
APPL NUMBER: 06-50016150 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT THEN RIGHT ON LEMUEL BLACK RD S/D
ON RIGHT LOT 4 JB

STRUCTURE: 000 000 63X60 3BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001453518
	7/25/07	AP	
B103 01	8/13/07	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001465523
	8/13/07	AP	
B105 01	8/27/07	TI	R*OPEN FLOOR VRU #: 001474103
	<u>8/27/07</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 65 GATEWEST DR SUBDIV: GATEWEST 53 LOTS
TENANT, NBR: REVISION 2/15/07 NEW MAP
CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 567-4686
OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
PARCEL . . : 01-0525-01- -0095- -04-
APPL NUMBER: 06-50016150 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT THEN RIGHT ON LEMUEL BLACK RD S/D
ON RIGHT LOT 4 JB

STRUCTURE: 000 000 63X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/25/07 7/25/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001453518
B103 01	8/13/07 8/13/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001465523
B105 01	8/27/07 8/27/07	DT AP	R*OPEN FLOOR VRU #: 001474103
R425 01	9/14/07 9/14/07	TI CA	FOUR TRADE ROUGH IN VRU #: 001486083
R425 02	9/20/07 <i>9/20/07</i>	TI <i>DA DT</i>	FOUR TRADE ROUGH IN VRU #: 001489623 VOICE MESSAGE LEFT

----- COMMENTS AND NOTES -----

DO NOT REMOVE!

Harnett County Inspection Department

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: Gatewest Quest Date: _____

Address: 65 Gatewest Dr.

Lot No.: 4 Permit No.: _____

(Check Box for Violation)

Footing

Foundation

Bldg.

Elec.

Plumb.

Mech.

Insul.

Floor Fram.

Floor Slab

MFG. Home

Modular

Damp/Water Proof.

Structural

Wall Sheath.

Other

Violations Found: • "A" and "E5/E6" truss not strapped for uplift correctly.

• Need 100 psi on water line.

• Need 10 psi on gas line

Okay to side & insulate

Code Enforcement Official

Signature: [Handwritten Signature]

Date: 9/20/07

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS : 65 GATEWEST DR SUBDIV: GATEWEST 53 LOTS
 TENANT, NBR: REVISION 2/15/07 NEW MAP
 CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 567-4686
 OWNER : EVEN PAR DEVELOPMENT LLC PHONE :
 PARCEL : 01-0525-01- -0095- -04-
 APPL NUMBER: 06-50016150 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
 RIGHT THEN RIGHT ON LEMUEL BLACK RD S/D
 ON RIGHT LOT 4 JB

STRUCTURE: 000 000 63X60 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/25/07 7/25/07	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001453518
B103 01	8/13/07 8/13/07	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001465523
B105 01	8/27/07 8/27/07	DT AP	R*OPEN FLOOR VRU #: 001474103
R425 01	9/14/07 9/14/07	TI CA	FOUR TRADE ROUGH IN VRU #: 001486083
R425 02	9/20/07 9/20/07	DT DA	FOUR TRADE ROUGH IN VRU #: 001489623 VOICE MESSAGE LEFT X "A" AND "E5/E6" TRUSS NOT STRAPPED FOR UPLIFT CORRECTLY. X NEED 100 psi ON WATER LINES. X NEED 10 psi ON GAS LINE. OKAY TO SIDE AND INSULATE.
A814 01	9/21/07	TI	ADDRESS CONFIRMATION VRU #: 001491224
I129 01	9/21/07	TI <i>AP JH</i>	R*INSULATION INSPECTION VRU #: 001491240
R425 03	9/21/07	TI <i>AP JD</i>	FOUR TRADE ROUGH IN VRU #: 001491232

COMMENTS AND NOTES

ADDRESS . : 65 GATEWEST DR SUBDIV: GATEWEST 53 LOTS
TENANT, NBR: REVISION 2/15/07 NEW MAP
CONTRACTOR : QUEST DEVELOPMENT PHONE : (910) 567-4686
OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
PARCEL . . : 01-0525-01- -0095- -04-
APPL NUMBER: 06-50016150 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 WEST TO ANDERSON CREEK RD TURN
RIGHT THEN RIGHT ON LEMUEL BLACK RD S/D
ON RIGHT LOT 4 JB

STRUCTURE: 000 000 63X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/25/07	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001453518
	7/25/07	AP	
B103 01	8/13/07	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001465523
	8/13/07	AP	
B105 01	8/27/07	DT	R*OPEN FLOOR VRU #: 001474103
	8/27/07	AP	
R425 01	9/14/07	TI	FOUR TRADE ROUGH IN VRU #: 001486083
	9/14/07	CA	
R425 02	9/20/07	DT	FOUR TRADE ROUGH IN VRU #: 001489623
	9/20/07	DA	VOICE MESSAGE LEFT "A" AND "E5/E6" TRUSS NOT STRAPPED FOR UPLIFT CORRECTLY. NEED 100 psi ON WATER LINES. NEED 10 psi ON GAS LINE. OKAY TO SIDE AND INSULATE.
I129 01	9/21/07	JH	R*INSULATION INSPECTION VRU #: 001491240
	9/21/07	AP	
R425 03	9/21/07	JH	FOUR TRADE ROUGH IN VRU #: 001491232
	9/21/07	AP	
A814 01	9/21/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001491224
	10/01/07	AP	65 Gatewest Dr
H824 01	11/01/07	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001514298
	11/01/07	AP	
R429 01	6/04/08	TI	FOUR TRADE FINAL VRU #: 001619403
	6/4/08	AP DT	

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: Quest Development

911 Address: 65 Gatewest Dr

State: NC Zip Code: _____

Date: 6/4/08

[Signature]
Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: 06-50216150

MFG. Home: _____