

HTE# 06-5-16153

# Harnett County Department of Public Health

25041

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: QUEST DEVELOPMENT CO. INC PROPERTY LOCATION: LEMUEL BLACK RD  
 SUBDIVISION GATEWEST LOT # 7  
 NEW  REPAIR  EXPANSION   
 Type of Structure: SFD (63'x60') Site Improvements required prior to Construction Authorization Issuance:  
 Proposed Wastewater System Type: 25% REDUCTION SYSTEM  
 Projected Daily Flow: 360 GPD  
 Number of bedrooms: 3 Number of Occupants: 6 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well 100 feet Permit valid for:  Five years  
 Permit conditions:  No expiration

Authorized State Agent: [Signature] Date: 10/9/08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: QUEST DEVELOPMENT CO. INC. PROPERTY LOCATION: LEMUEL BLACK RD  
 SUBDIVISION GATEWEST LOT # 7  
 Facility Type: SFD (63'x60')  New  Expansion  Repair  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable )  
Fill (Repair)

**Installation Requirements/Conditions**

Septic Tank Size <u>1000</u> gallons	Number of trenches <u>1</u>	
Pump Tank Size _____ gallons	Exact length of each trench <u>340</u> feet	Trench Spacing: <u>9</u> Feet on Center
	Trenches shall be installed on contour at a	Soil Cover: <u>6</u> inches minimum
	Maximum Trench Depth of: <u>17</u> inches	(Maximum soil cover shall not exceed
	(Trench bottoms shall be level to +/-1/4"	36" above the trench bottom)
	in all directions)	
Pump Requirements: _____ ft. TDH vs. _____ GPM		_____ inches below pipe
		Aggregate Depth: _____ inches above pipe
Conditions: _____		_____ inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 10/9/08  
Construction Authorization Expiration Date: 10/9/13

HTE# 06-5-16153

Permit # ~~2366~~ 2504

# Harnett County Department of Public Health Site Sketch

ISSUED TO: QUEST Development Co. Inc PROPERTY LOCATOR: LEMUEL BLACK RD  
SUBDIVISION GASWEST LOT # 7

Authorized State Agent: [Signature] RS Date: 10/9/08

- FOUNDATION POURED AT TIME OF PROPOSAL EVALUATION
- REPAIR - PUMP TO FILL OFFSITE EASEMENT ON LOT 4

