

HTE# 06-500-16191R

Harnett County Department of Public Health

23423

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Danny Norris PROPERTY LOCATION: NC 27
NEW ☒ REPAIR ☐ EXPANSION ☐ SUBDIVISION: Laurel Valley LOT # 55
Type of Structure: SFD - (55x34) JBR Site Improvements required prior to Construction Authorization Issuance:
Proposed Wastewater System Type: Pump to 25% Reduction system
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement ☐ Yes ☒ No
Pump Required: ☒ Yes ☐ No ☐ May be required based on final location and elevations of facilities
Type of Water Supply: ☐ Community ☒ Public ☐ Well Distance from well 50 feet Permit valid for: ☒ Five years
Permit conditions: met on site maintain all set back ☐ No expiration

Authorized State Agent: [Signature] Date: 12-12-06 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Danny Norris PROPERTY LOCATION: NC 27
SUBDIVISION: Laurel Valley LOT # 55
Facility Type: SFD - 55x34 JBR ☒ New ☐ Expansion ☐ Repair
Basement? ☐ Yes ☐ No Basement Fixtures? ☐ Yes ☒ No
Type of Wastewater System** Pump to 25% Red. sys (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable ☒ 240 LF 4 LRP (Repair))

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x150 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
(Trench bottoms shall be level to +/- 1/4" in all directions)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
Conditions: _____ inches above pipe
_____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: [Signature] Date: 12-12-06 SEE ATTACHED SITE SKETCHConstruction Authorization Expiration Date: 12-12-2011

HTE# 06-500161912

Permit # 23423

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: NC 27


ISSUED TO: Danny Harris

SUBDIVISION LA-rail valley

LOT # 55

Authorized State Agent: [Signature]

Date: 12-12-06



Meet onsite for Final L&A

Install 1x150 of 25% Reduction system at 18 ft. 24"