



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

8/26/2025

SUBJECT: **CPSF06-50016223**  
**BUILDING RESIDENTIAL**

To: WILLIAMS JOHN E & MARGARET

Here are the results of all Inspections located at **916 ABATTOIR RD:**

Inspection Type: ENVIR. HLTH. CONFIRMATION  
Scheduled Date/Time: 12/7/2006  
Completed Date/Time: 12/6/2006  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: BLDG PLAN REVIEW  
Scheduled Date/Time: 2/6/2007  
Completed Date/Time:  
Inspector: Unassigned  
Result:  
Remarks:  
Notes:

Inspection Type: R BLDG FOOTING / TEMP SVC POLE  
Scheduled Date/Time: 2/21/2007  
Completed Date/Time: 2/21/2007  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: R BLDG FOUND & TEMP SVC POLE  
Scheduled Date/Time: 3/6/2007  
Completed Date/Time: 3/6/2007  
Inspector: Unassigned  
Result: DISAPPROVED  
Remarks:  
Notes:

T/S: 03/06/2007 09:51 AM KSLATTUM ----- 1. the plans say the porches are to be filled. It appears that you are planning to swing porches. If you do, you must have crawl space access to each area. Correct and call for reinspection



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ADDRESS CONFIRMATION

Scheduled Date/Time: 3/8/2007

Completed Date/Time: 3/7/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes: 916 Abattoir Rd

Inspection Type: R BLDG FOUND & TEMP SVC POLE

Scheduled Date/Time: 3/8/2007

Completed Date/Time: 3/8/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:

Inspection Type: R OPEN FLOOR

Scheduled Date/Time: 3/12/2007

Completed Date/Time: 3/12/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:

Inspection Type: FOUR TRADE ROUGH IN

Scheduled Date/Time: 4/5/2007

Completed Date/Time: 4/5/2007

Inspector: Unassigned

Result: DISAPPROVED

Remarks:

Notes: VOICE MESSAGE LEFT

Roof shall be on for rough-in Front door needs to be installed Horizontal branch drain for washing machine shall be 3 inch have done for insulation inspection.

Inspection Type: R INSULATION INSPECTION

Scheduled Date/Time: 4/11/2007

Completed Date/Time: 4/11/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FOUR TRADE ROUGH IN

Scheduled Date/Time: 4/11/2007

Completed Date/Time: 4/11/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:

Inspection Type: ENVIR. OPERATIONS PERMIT

Scheduled Date/Time: 5/18/2007

Completed Date/Time: 5/18/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:

Inspection Type: FOUR TRADE FINAL

Scheduled Date/Time: 6/1/2007

Completed Date/Time: 6/1/2007

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes: