

HTE# 06-5-16241

Harris County Department of Public Health

24010

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: JOHN DEREK TRAPP PROPERTY LOCATION: Hwy 55 + SR 1563 Bill Harvey
 SUBDIVISION: James McLamb LOT # 2
 NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:
 Type of Structure: SFD
 Proposed Wastewater System Type: 2590 (conversion) System
 Projected Daily Flow: 490 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 No expiration
 Permit conditions: _____

Authorized State Agent: James E. Markantsev Date: 12-7-06 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: JOHN DEREK TRAPP PROPERTY LOCATION: Hwy 55 + SR 1563 Bill Harvey
 SUBDIVISION: James McLamb LOT # 2
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 2590 (conversion) system (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable
2590 - VITRA Station Conventional (Repair)

Installation Requirements/Conditions

Septic Tank Size 1200 gallons Exact length of each trench 4 x 90 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18" max inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +1/-1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
 Conditions: _____ 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: James E. Markantsev Date: 12-7-06 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 12-7-11

HTE# 06-5-16241

Permit # 24010

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: Hwy 55 + SR1563 Bill Avery

ISSUED TO: JOHN DEAR, Tripp

SUBDIVISION

LOT # 2

Authorized State Agent: James E. Merchant

Date: 12-7-06

