

HT# 06-5-16358

Harnett County Department of Public Health

23476

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Daryl Ward
 NEW REPAIR EXPANSION
 Type of Structure: SFD 50'x36'
 Proposed Wastewater System Type: Pump to Conventional
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit conditions: _____ Permit valid for: Five years No expiration

Authorized State Agent: Bryan McSwain, R.S. Date: 3/15/2007 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Daryl Ward PROPERTY LOCATION: Hardee Road
 SUBDIVISION Hector's Creek LOT # 2
 Facility Type: SFD 50'x36' New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Pump to Conventional (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable Pump to Accepted System (Repair))

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 4x100 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 12 inches
 *IF Needed Maximum Trench Depth of: 2420 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to $\pm 1/4"$ in all directions) B.M. 5/21/07
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
 Conditions: Final system layout + ditch depths to be determined at meeting w/ Septic Contractor prior to installing system 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Bryan McSwain, R.S. Date: 3/15/2007 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 3/15/2012

HTE# 06-5-1658

Permit # 23476

Harnett County Department of Public Health Site Sketch

ISSUED TO: Dary Wood


PROPERTY LOCATOR: SR 1425 Harder Road

SUBDIVISION Hector's Creek

LOT # 2

Authorized State Agent: Ryan McJin, R.S.

Date: 3/15/2007



Horse View Lane

* Contractor to meet on site prior to installing system to lay out system & determine MAX ditch depth

5/21/07 meet w/ Tommy Coley
Ditches to be NO DEEPER than 20 inches

* Pump may be needed

Ryan McJin, R.S.