

PREPARED 1/25/07, 13:59:54
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 39
DATE 1/26/07

ADDRESS . : 25 SANDY TINGEN CT
CONTRACTOR : JAMES JACKSON HOMEBUILDERS
OWNER . . : JAMES JACKSON HOMES BUILDERS
PARCEL . . : 03-9597- - -0033- -07-
APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TINGEN PLACE PH1 #58
27W 13MILES LEFT ONTO TINGEN RD S/D ON
LEFT CORNER OF MICRO TOWER RD RIGHT IN
S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07	TI <u>APKT</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932

----- COMMENTS AND NOTES -----

PREPARED 2/21/07, 13:59:06
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 36
DATE 2/22/07

ADDRESS . : 25 SANDY TINGEN CT SUBDIV: TINGEN PLACE
CONTRACTOR : JAMES JACKSON HOMEBUILDERS PHONE : (910) 897-5563
OWNER . . : JAMES JACKSON HOMES BUILDERS PHONE : (910) 892-6288
PARCEL . . : 03-9597- - -0033- -07-
APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TINGEN PLACE PH1 #58
27W 13MILES LEFT ONTO TINGEN RD S/D ON
LEFT CORNER OF MICRO TOWER RD RIGHT IN
S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07	KT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
	1/26/07	AP	
B103 01	2/22/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453

 AR-mr

----- COMMENTS AND NOTES -----

ADDRESS . . : 25 SANDY TINGEN CT
CONTRACTOR : JAMES JACKSON HOMEBUILDERS
OWNER . . . : JAMES JACKSON HOMES BUILDERS
PARCEL . . . : 03-9597- - -0033- -07-
APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TINGEN PLACE PH1 #58
27W 13MILES LEFT ONTO TINGEN RD S/D ON
LEFT CORNER OF MICRO TOWER RD RIGHT IN
S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07	KT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
	1/26/07	AP	
B103 01	2/22/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453
	2/22/07	AP	
A814 01	2/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358444
	2/26/07	AP	25 Sandy Tingen Ct
B105 01	3/14/07	TI	R*OPEN FLOOR VRU #: 001370509

AP MR

----- COMMENTS AND NOTES -----

ADDRESS . : 25 SANDY TINGEN CT SUBDIV: TINGEN PLACE
CONTRACTOR : JAMES JACKSON HOMEBUILDERS PHONE : (910) 897-5563
OWNER . . : JAMES JACKSON HOMES BUILDERS PHONE : (910) 892-6288
PARCEL . . : 03-9597- - -0033- -07-
APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TINGEN PLACE PH1 #58
27W 13MILES LEFT ONTO TINGEN RD S/D ON
LEFT CORNER OF MICRO TOWER RD RIGHT IN
S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07 1/26/07	KT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
B103 01	2/22/07 2/22/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453
A814 01	2/27/07 2/26/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358444 25 Sandy Tingen Ct
B105 01	3/14/07 3/14/07	MR AP	R*OPEN FLOOR VRU #: 001370509
R425 01	4/12/07	TI	FOUR TRADE ROUGH IN VRU #: 001388082

DA JH

----- COMMENTS AND NOTES -----

ADDRESS : 25 SANDY TINGEN CT SUBDIV: TINGEN PLACE
CONTRACTOR : JAMES JACKSON HOMEBUILDERS PHONE : (910) 897-5563
OWNER : JAMES JACKSON HOMES BUILDERS PHONE : (910) 892-6288
PARCEL : 03-9597- - -0033- -07-
APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TINGEN PLACE PH1 #58
27W 13MILES LEFT ONTO TINGEN RD S/D ON
LEFT CORNER OF MICRO TOWER RD RIGHT IN
S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07	KT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
	1/26/07	AP	
B103 01	2/22/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453
	2/22/07	AP	
A814 01	2/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358444
	2/26/07	AP	25 Sandy Tingen Ct
B105 01	3/14/07	MR	R*OPEN FLOOR VRU #: 001370509
	3/14/07	AP	
R425 01	4/12/07	JH	FOUR TRADE ROUGH IN VRU #: 001388082
	4/12/07	DA	<ul style="list-style-type: none"> 1) Use correct nail guards for water lines @ water heater & 2" vent pipe in master bath. 2) No vinyl duct on exhaust fans, you can use foil flex connector 25' max. 3) Nail guard on wire to right of fire box. 4) Nail guard @ bottom plate in back right bed in right corner. 5) 3" head of water on drain lines. 6) Window @ bottom of stairs needs to be tempered glass. 7) 4" min between pickets on deck. 8) Water lines under house need support every 32".
R425 02	4/16/07	TI	FOUR TRADE ROUGH IN VRU #: 001390051

AP JH

----- COMMENTS AND NOTES -----

ADDRESS . : 25 SANDY TINGEN CT SUBDIV: TINGEN PLACE
 CONTRACTOR : JAMES JACKSON HOMEBUILDERS PHONE : (910) 897-5563
 OWNER . . : JAMES JACKSON HOMES BUILDERS PHONE : (910) 892-6288
 PARCEL . . : 03-9597- - -0033- -07-
 APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TINGEN PLACE PH1 #58
 27W 13MILES LEFT ONTO TINGEN RD S/D ON
 LEFT CORNER OF MICRO TOWER RD RIGHT IN
 S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
 T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07	KT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
	1/26/07	AP	
B103 01	2/22/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453
	2/22/07	AP	
A814 01	2/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358444
	2/26/07	AP	✓ 25 Sandy Tingen Ct
B105 01	3/14/07	MR	R*OPEN FLOOR VRU #: 001370509
	3/14/07	AP	
R425 01	4/12/07	JH	FOUR TRADE ROUGH IN VRU #: 001388082
	4/12/07	DA	1)Use correct nail guards for water lines @ water heater & 2" vent pipe in master bath. 2)No vinyl duct on exhaust fans, you can use foil flex connector 25' max. 3)Nail guard on wire to right of fire box. 4)Nail guard @ bottom plate in back right bed in right corner. 5)3" head of water on drain lines. 6)Window @ bottom of stairs needs to be tempered glass. 7)4" min between pickets on deck. 8)Water lines under house need support every 32".
R425 02	4/16/07	JH	FOUR TRADE ROUGH IN VRU #: 001390051
	4/16/07	AP	1>window @ bottom of stairsneeds to tempered glass. 2)4" min between pickets on deck. These items need to be taken care of by final
I129 01	4/19/07	MR	R*INSULATION INSPECTION VRU #: 001392228
	4/19/07	AP	
H824 01	5/02/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001402916
	5/02/07	AP	
R429 01	6/14/07	TS	FOUR TRADE FINAL VRU #: 001428896

6-14-07 DA

 COMMENTS AND NOTES

House Locked
 A/C Not Wired
 DRAINAGE
 A/C DRAIN LINE

ADDRESS : 25 SANDY TINGEN CT
CONTRACTOR : JAMES JACKSON HOMEBUILDERS
OWNER : JAMES JACKSON HOMES BUILDERS
PARCEL : 03-9597- - -0033- -07-
APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : TINGEN PLACE PH1 #58
27W 13MILES LEFT ONTO TINGEN RD S/D ON
LEFT CORNER OF MICRO TOWER RD RIGHT IN
S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
T/S: 12/15/2006 02:15 PM JDAVIS ----

SUBDIV: TINGEN PLACE
PHONE : (910) 897-5563
PHONE : (910) 892-6288

STRUCTURE: 000 000 44X52 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07 1/26/07	KT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
B103 01	2/22/07 2/22/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453
A814 01	2/27/07 2/26/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358444 ✓ 25 Sandy Tingen Ct
B105 01	3/14/07 3/14/07	MR AP	R*OPEN FLOOR VRU #: 001370509
R425 01	4/12/07 4/12/07	JH DA	FOUR TRADE ROUGH IN VRU #: 001388082 1)Use correct nail guards for water lines @ water heater & 2" vent pipe in master bath. 2)No vinyl duct on exhaust fans, you can use foil flex connector 25' max. 3)Nail guard on wire to right of fire box. 4)Nail guard @ bottom plate in back right bed in right corner. 5)3" head of water on drain lines. 6)Window @ bottom of stairs needs to be tempered glass. 7)4" min between pickets on deck. 8)Water lines under house need support every 32".
R425 02	4/16/07 4/16/07	JH AP	FOUR TRADE ROUGH IN VRU #: 001390051 1)window @ bottom of stairsneeds to tempered glass. 2)4" min between pickets on deck. These items need to be taken care of by final
I129 01	4/19/07 4/19/07	MR AP	R*INSULATION INSPECTION VRU #: 001392228
H824 01	5/02/07 5/02/07	JW AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001402916
R429 01	6/14/07 6/14/07	ES DA	FOUR TRADE FINAL VRU #: 001428896 house locked need to wire heat and a/c units drain unit under house to outside of foundation drainage away from house foundation
R429 02	6/22/07	TI DA JH	FOUR TRADE FINAL VRU #: 001433700 VOICE MESSAGE LEFT

House Locked

COMMENTS AND NOTES

ADDRESS : 25 SANDY TINGEN CT SUBDIV: TINGEN PLACE
 CONTRACTOR : JAMES JACKSON HOMEBUILDERS PHONE : (910) 897-5563
 OWNER : JAMES JACKSON HOMES BUILDERS PHONE : (910) 892-6288
 PARCEL : 03-9597- - -0033- -07-
 APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TINGEN PLACE PH1 #58
 27W 13MILES LEFT ONTO TINGEN RD S/D ON
 LEFT CORNER OF MICRO TOWER RD RIGHT IN
 S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
 T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07	KT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
	1/26/07	AP	
B103 01	2/22/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453
	2/22/07	AP	
A814 01	2/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358444
	2/26/07	AP	25 Sandy Tingen Ct
B105 01	3/14/07	MR	R*OPEN FLOOR VRU #: 001370509
	3/14/07	AP	
R425 01	4/12/07	JH	FOUR TRADE ROUGH IN VRU #: 001388082
	4/12/07	DA	1)Use correct nail guards for water lines @ water heater & 2" vent pipe in master bath. 2)No vinyal duct on exhaust fans, you can use foil flex connector 25' max. 3)Nail guard on wire to right of fire box. 4)Nail guard @ bottom plate in back right bed in right corner. 5)3" head of water on drain lines. 6)Window @ bottom of stairs needs to be tempered glass. 7)4" min between pickets on deck. 8)Water lines under house need support every 32".
R425 02	4/16/07	JH	FOUR TRADE ROUGH IN VRU #: 001390051
	4/16/07	AP	1>window @ bottom of stairsneeds to tempered glass. 2)4" min between pickets on deck. These items need to be taken care of by final
I129 01	4/19/07	MR	R*INSULATION INSPECTION VRU #: 001392228
	4/19/07	AP	
H824 01	5/02/07	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001402916
	5/02/07	AP	
R429 01	6/14/07	FS	FOUR TRADE FINAL VRU #: 001428896
	6/14/07	DA	house locked need to wire heat and a/c units drain unit under house to outside of foundation drainage away from house foundation
R429 02	6/22/07	JH	FOUR TRADE FINAL VRU #: 001433700
	6/22/07	DA	VOICE MESSAGE LEFT house locked
R429 03	6/27/07	MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 001436906
	6/27/07	DA	1. outside faucets to be frost proof 2. ladder needed for attic inspection 3. water heater to be elevated 18"
R429 04	6/29/07	TI	FOUR TRADE FINAL VRU #: 001438331

DA-MR

ADDRESS : 25 SANDY TINGEN CT SUBDIV: TINGEN PLACE
 CONTRACTOR : JAMES JACKSON HOMEBUILDERS PHONE : (910) 897-5563
 OWNER : JAMES JACKSON HOMES BUILDERS PHONE : (910) 892-6288
 PARCEL : 03-9597- - -0033- -07-
 APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TINGEN PLACE PH1 #58
 27W 13MILES LEFT ONTO TINGEN RD S/D ON
 LEFT CORNER OF MICRO TOWER RD RIGHT IN
 S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
 T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07	KT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
	1/26/07	AP	
B103 01	2/22/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453
	2/22/07	AP	
A814 01	2/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358444
	2/26/07	AP	✓ 25 Sandy Tingen Ct
B105 01	3/14/07	MR	R*OPEN FLOOR VRU #: 001370509
	3/14/07	AP	
R425 01	4/12/07	JH	FOUR TRADE ROUGH IN VRU #: 001388082
	4/12/07	DA	1)Use correct nail guards for water lines @ water heater & 2" vent pipe in master bath. 2)No vinyl duct on exhaust fans, you can use foil flex connector 25' max. 3)Nail guard on wire to right of fire box. 4)Nail guard @ bottom plate in back right bed in right corner. 5)3" head of water on drain lines. 6)Window @ bottom of stairs needs to be tempered glass. 7)4" min between pickets on deck. 8)Water lines under house need support every 32".
R425 02	4/16/07	JH	FOUR TRADE ROUGH IN VRU #: 001390051
	4/16/07	AP	1>window @ bottom of stairsneeds to tempered glass. 2)4" min between pickets on deck. These items need to be taken care of by final
I129 01	4/19/07	MR	R*INSULATION INSPECTION VRU #: 001392228
	4/19/07	AP	
H824 01	5/02/07	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001402916
	5/02/07	AP	
R429 01	6/14/07	FS	FOUR TRADE FINAL VRU #: 001428896
	6/14/07	DA	house locked need to wire heat and a/c units drain unit under house to outside of foundation drainage away from house foundation
R429 02	6/22/07	JH	FOUR TRADE FINAL VRU #: 001433700
	6/22/07	DA	VOICE MESSAGE LEFT house locked
R429 03	6/27/07	MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 001436906
	6/27/07	DA	1. outside faucets to be frost proof 2. ladder needed for attic inspection 3. water heater to be elevated 18"
R429 04	6/29/07	MR	FOUR TRADE FINAL VRU #: 001438331
	6/29/07	DA	install secondary drain to pan and clean out all the blown in insulation from pan

ADDRESS : 25 SANDY TINGEN CT SUBDIV: TINGEN PLACE
CONTRACTOR : JAMES JACKSON HOMEBUILDERS PHONE : (910) 897-5563
OWNER : JAMES JACKSON HOMES BUILDERS PHONE : (910) 892-6288
PARCEL : 03-9597- - -0033- -07-
APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 05	7/03/07 7/03/07	MR DP	FOUR TRADE FINAL VRU #: 001440131 2nd notice install secondary drain to pan on attic AHU
R429 06	7/10/07	TI AP JH	FOUR TRADE FINAL VRU #: 001442987

----- COMMENTS AND NOTES -----

ADDRESS : 25 SANDY TINGEN CT SUBDIV: TINGEN PLACE
 CONTRACTOR : JAMES JACKSON HOMEBUILDERS PHONE : (910) 897-5563
 OWNER : JAMES JACKSON HOMES BUILDERS PHONE : (910) 892-6288
 PARCEL : 03-9597- - -0033- -07-
 APPL NUMBER: 06-50016407 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : TINGEN PLACE PH1 #58
 27W 13MILES LEFT ONTO TINGEN RD S/D ON
 LEFT CORNER OF MICRO TOWER RD RIGHT IN
 S/D ONTO SANDY TINGEN RD LOT 58 ON LEFT
 T/S: 12/15/2006 02:15 PM JDAVIS ----

STRUCTURE: 000 000 44X52 3BR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/26/07	KT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001343932
	1/26/07	AP	
B103 01	2/22/07	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001358453
	2/22/07	AP	
A814 01	2/27/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001358444
	2/26/07	AP	✓25 Sandy Tingen Ct
B105 01	3/14/07	MR	R*OPEN FLOOR VRU #: 001370509
	3/14/07	AP	
R425 01	4/12/07	JH	FOUR TRADE ROUGH IN VRU #: 001388082
	4/12/07	DA	1)Use correct nail guards for water lines @ water heater & 2" vent pipe in master bath. 2)No vinyl duct on exhaust fans, you can use foil flex connecter 25' max. 3)Nail guard on wire to right of fire box. 4)Nail guard @ bottom plate in back right bed in right corner. 5)3" head of water on drain lines. 6)Window @ bottom of stairs needs to be tempered glass. 7)4" min between pickets on deck. 8)Water lines under house need support every 32".
R425 02	4/16/07	JH	FOUR TRADE ROUGH IN VRU #: 001390051
	4/16/07	AP	1)window @ bottom of stairsneeds to tempered glass. 2)4" min between pickets on deck. These items need to be taken care of by final
I129 01	4/19/07	MR	R*INSULATION INSPECTION VRU #: 001392228
	4/19/07	AP	
H824 01	5/02/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001402916
	5/02/07	AP	
R429 01	6/14/07	FS	FOUR TRADE FINAL VRU #: 001428896
	6/14/07	DA	house locked need to wire heat and a/c units drain unit under house to outside of foundation drainage away from house foundation
R429 02	6/22/07	JH	FOUR TRADE FINAL VRU #: 001433700
	6/22/07	DA	VOICE MESSAGE LEFT house locked
R429 03	6/27/07	MR	FOUR TRADE FINAL TIME: 17:00 VRU #: 001436906
	6/27/07	DA	1. outside faucets to be frost proof 2. ladder needed for attic inspection 3. water heater to be elevated 18"
R429 04	6/29/07	MR	FOUR TRADE FINAL VRU #: 001438331
	6/29/07	DA	install secondary drain to pan and clean out all the blown in insulation from pan

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: 06-50016407
Owner of Building: James Jackson Harnett Electrical Permit No.: 06-50016407
Building Address: 25 Sandy Tringent Insulation Permit No.: 06-50016407
Zoning District: _____ Plumbing Permit No.: 06-50016407
Zoning Permit No.: _____ Mech. Permit No.: 06-50016407
Date: 7-10-07 Envir. C.O. No.: _____

James J. Hall
Building Official

Zoning Official