
ADDRESS . : 15 SAPPHIRE DR
 CONTRACTOR : S & D HOMEBUILDERS, LLC
 OWNER . . : S & D HOMEBUILDERS LLC #52
 PARCEL . . : 03-9589- - -1015- -50-
 APPL NUMBER: 06-50016422 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : LAUREL VALLEY LOT 52. HWY 27W PAST
 BUFFALO LAKE RD TURN LEFT ON APPLETON
 WAY LOT IS ON CORNER OF APPLETON AND
 SAPPHIRE DRIVE. DRIVEWAY IS OFF OF
 APPLETON. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
 PHONE : (919) 669-6327
 PHONE : (910) 897-2120

LAND NOTES : LXMN 12/22/06 COMBINED PART OF 51 WITH THIS TRACT OF
 LAND

STRUCTURE: 000 000 59X38 4BR SFD
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/11/07 <u>1-11-7</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001335462

COMMENTS AND NOTES

FS

ADDRESS . : 15 SAPPHIRE DR SUBDIV: LAUREL VALLEY
CONTRACTOR : S & D HOMEBUILDERS, LLC PHONE : (919) 669-6327
OWNER . . : S & D HOMEBUILDERS LLC #52 PHONE : (910) 897-2120
PARCEL . . : 03-9589- - -1015- -50-
APPL NUMBER: 06-50016422 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 52. HWY 27W PAST
BUFFALO LAKE RD TURN LEFT ON APPLETON
WAY LOT IS ON CORNER OF APPLETON AND
SAPPHIRE DRIVE. DRIVEWAY IS OFF OF
APPLETON. -A.DRIGGERS
LAND NOTES : LXMN 12/22/06 COMBINED PART OF 51 WITH THIS TRACT OF
LAND

STRUCTURE: 000 000 59X38 4BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/11/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001335462
	1/11/07	AP	
A814 01	1/29/07	TI	ADDRESS CONFIRMATION VRU #: 001344787
B103 01	<u>1/29/07</u> <u>1-29-7</u>	<u>TI</u> <u>AP</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001344795

----- COMMENTS AND NOTES -----
FS

ADDRESS . : 208 APPLETON WAY SUBDIV: LAUREL VALLEY
CONTRACTOR : S & D HOMEBUILDERS, LLC PHONE : (919) 669-6327
OWNER . . : S & D HOMEBUILDERS LLC #52 PHONE : (910) 897-2120
PARCEL . . : 03-9589- - -1015- -50-
APPL NUMBER: 06-50016422 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 52. HWY 27W PAST
BUFFALO LAKE RD TURN LEFT ON APPLETON
WAY LOT IS ON CORNER OF APPLETON AND
SAPPHIRE DRIVE. DRIVEWAY IS OFF OF
APPLETON. -A.DRIGGERS
LAND NOTES : LXMN 12/22/06 COMBINED PART OF 51 WITH THIS TRACT OF
LAND

STRUCTURE: 000 000 59X38 4BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/11/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001335462
	1/11/07	AP	
A814 01	1/29/07	FB	ADDRESS CONFIRMATION VRU #: 001344787
	1/29/07	AP	208 APPLETON WAY LOT 52
B103 01	1/29/07	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001344795
	1/29/07	AP	
B105 01	2/07/07	TL	R*OPEN FLOOR VRU #: 001349428

2-7-7 AP

----- COMMENTS AND NOTES -----

FS

ADDRESS : 208 APPLETON WAY
CONTRACTOR : S & D HOMEBUILDERS, LLC
OWNER : S & D HOMEBUILDERS LLC #52
PARCEL : 03-9589- - -1015- -50-
APPL NUMBER: 06-50016422 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LAUREL VALLEY LOT 52. HWY 27W PAST
BUFFALO LAKE RD TURN LEFT ON APPLETON
WAY LOT IS ON CORNER OF APPLETON AND
SAPPHIRE DRIVE. DRIVEWAY IS OFF OF
APPLETON. -A.DRIGGERS
LAND NOTES : LXMN 12/22/06 COMBINED PART OF 51 WITH THIS TRACT OF
LAND

SUBDIV: LAUREL VALLEY
PHONE : (919) 669-6327
PHONE : (910) 897-2120

STRUCTURE: 000 000 59X38 4BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/11/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001335462
	1/11/07	AP	
A814 01	1/29/07	FB	ADDRESS CONFIRMATION VRU #: 001344787
	1/29/07	AP	208 APPLETON WAY LOT 52
B103 01	1/29/07	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001344795
	1/29/07	AP	
B105 01	2/07/07	FS	R*OPEN FLOOR VRU #: 001349428
	2/07/07	AP	
R427 01	3/01/07	TA	FOUR TRADE ROUGH IN >2500 VRU #: 001363514

3-1-7 *MA*

COMMENTS AND NOTES

210 AS?
DRAIN TEST

DO NOT REMOVE!

Harnett County Inspection Department

102 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7527 • Fax: (910) 893-2793

Job Name: S + A Date: 3-1-7

Address: 208 APPLETON

Lot No.: 52 Permit No.: E.S. 16422

(Check Box for Violation)

- Footing
- Foundation
- Bldg.
- Elec.
- Plumb.
- Mech.
- Insul.
- Floor Fram.
- Floor Slab
- MFG. Home
- Modular
- Damp/Water Proof.
- Structural
- Wall Sheath.
- Other

Violations Found: NEED FLASHING ON FRONT PORCH

NEED TO TURN FLASHING OUT ON TOP OF BRICKS ON FRONT OF HOUSE

NEED METAL FLASHING AROUND SHOWER DRAIN

WILL CHECK ON INSULATION INSPECTION

Code Enforcement Official

Signature: [Handwritten Signature]

Date: 3-1-7

It is unlawful for any sub contractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation.

ADDRESS ..: 208 APPLETON WAY SUBDIV: LAUREL VALLEY
 CONTRACTOR : S & D HOMEBUILDERS, LLC PHONE : (919) 669-6327
 OWNER . . : S & D HOMEBUILDERS LLC #52 PHONE : (910) 897-2120
 PARCEL . . : 03-9589- - -1015- -50-
 APPL NUMBER: 06-50016422 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : LAUREL VALLEY LOT 52. HWY 27W PAST
 BUFFALO LAKE RD TURN LEFT ON APPLETON
 WAY LOT IS ON CORNER OF APPLETON AND
 SAPPHIRE DRIVE. DRIVEWAY IS OFF OF
 APPLETON. -A.DRIGGERS
 LAND NOTES : LXMN 12/22/06 COMBINED PART OF 51 WITH THIS TRACT OF
 LAND

STRUCTURE: 000 000 59X38 4BR SFD
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/11/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001335462
	1/11/07	AP	
A814 01	1/29/07	FB	ADDRESS CONFIRMATION VRU #: 001344787
	1/29/07	AP	208 APPLETON WAY LOT 52
B103 01	1/29/07	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001344795
	1/29/07	AP	
B105 01	2/07/07	FS	R*OPEN FLOOR VRU #: 001349428
	2/07/07	AP	
R427 01	3/01/07	FS	FOUR TRADE ROUGH IN >2500 VRU #: 001363514
	3/01/07	DA	flashing on front porch flashing on top of bricks flashing around shower drain
I129 01	3/06/07	TI	R*INSULATION INSPECTION VRU #: 001365926
	<u>3-6-7</u>	<u>AP</u>	
R427 02	3/06/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001365917
	<u>3-6-7</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

FS

ADDRESS . . : 208 APPLETON WAY
 CONTRACTOR : S & D HOMEBUILDERS, LLC
 OWNER . . . : S & D HOMEBUILDERS LLC #52
 PARCEL . . . : 03-9589- - -1015- -50-
 APPL NUMBER: 06-50016422 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : LAUREL VALLEY LOT 52. HWY 27W PAST
 BUFFALO LAKE RD TURN LEFT ON APPLETON
 WAY LOT IS ON CORNER OF APPLETON AND
 SAPPHIRE DRIVE. DRIVEWAY IS OFF OF
 APPLETON. -A.DRIGGERS

SUBDIV: LAUREL VALLEY
 PHONE : (919) 669-6327
 PHONE : (910) 897-2120

LAND NOTES : LXMN 12/22/06 COMBINED PART OF 51 WITH THIS TRACT OF
 LAND

STRUCTURE: 000 000 59X38 4BR SFD
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/11/07	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001335462
	1/11/07	AP	
A814 01	1/29/07	FB	ADDRESS CONFIRMATION VRU #: 001344787
	1/29/07	AP	208 APPLETON WAY LOT 52
B103 01	1/29/07	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001344795
	1/29/07	AP	
B105 01	2/07/07	FS	✓R*OPEN FLOOR VRU #: 001349428
	2/07/07	AP	
R427 01	3/01/07	FS	FOUR TRADE ROUGH IN >2500 VRU #: 001363514
	3/01/07	DA	flashing on front porch flashing on top of bricks flashing around shower drain
I129 01	3/06/07	FS	R*INSULATION INSPECTION VRU #: 001365926
	3/06/07	AP	
R427 02	3/06/07	FS	FOUR TRADE ROUGH IN >2500 VRU #: 001365917
	3/06/07	AP	
H824 01	4/02/07	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001383546
	4/02/07	AP	
R431 01	5/03/07	TI	FOUR TRADE FINAL >2500 VRU #: 001401691

5-5-7 AP

 COMMENTS AND NOTES

FS

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: D Conditional Use Permit No.: N/A
Type of Construction: Home Building Permit No.: 6-5-16422
Owner of Building: 54-A HOME BUILDER Electrical Permit No.: 6-5-16422
Building Address: 208 APPLETON WAY Insulation Permit No.: 6-5-16422
Zoning District: RA20X Plumbing Permit No.: 6-5-16422
Zoning Permit No.: 6-5-16422 Mech. Permit No.: 6-5-16422
Date: 5-3-7 Envir. C.O. No.: 6-5-16422
Tail Spence
Building Official Zoning Official