
ADDRESS . . : 70 D'ANGO CIR
 CONTRACTOR : C W W CONTRACTORS
 OWNER . . : WEAVER CHRISTOPHER & ANGELA
 PARCEL . . : 04-0662- - -0015- -16-
 APPL NUMBER: 06-50016438 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 TOWARDS ANGIER LEFT ON HARNETT
 CENTRAL RD PEAR MEADOW S/D IS 1/4 MILE
 ON RIGHT LOT 13 JB

STRUCTURE: 000 000 52X48 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/18/07 1/18/07	KS CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339340 A.M. if possible. Thanks
B101 02	1/19/07 <u>1-19</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339902 A.M. if possible. <u>KS</u> Thanks

----- COMMENTS AND NOTES -----

ADDRESS . : 70 D'ANGO CIR
CONTRACTOR : C W W CONTRACTORS
OWNER . . : WEAVER CHRISTOPHER & ANGELA
PARCEL . . : 04-0662- - -0015- -16-
APPL NUMBER: 06-50016438 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TOWARDS ANGIER LEFT ON HARNETT
CENTRAL RD PEAR MEADOW S/D IS 1/4 MILE
ON RIGHT LOT 13 JB


SUBDIV:
PHONE : (919) 639-0522
PHONE : (919) 639-0522

STRUCTURE: 000 000 52X48 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/18/07 1/18/07	KS CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339340 A.M. if possible. Thanks
B101 02	1/19/07 1/19/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339902 A.M. if possible. Thanks
A814 01	1/25/07	TI	ADDRESS CONFIRMATION VRU #: 001343524
B103 01	<u>1/25/07</u> 1-25	TI <u>KSAP</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001343540

COMMENTS AND NOTES



ADDRESS . . : 70 D'ANGO CIR SUBDIV:
CONTRACTOR : C W W CONTRACTORS PHONE : (919) 639-0522
OWNER . . : WEAVER CHRISTOPHER & ANGELA . PHONE : (919) 639-0522
PARCEL . . : 04-0662- - -0015- -16-
APPL NUMBER: 06-50016438 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TOWARDS ANGIER LEFT ON HARNETT
CENTRAL RD PEAR MEADOW S/D IS 1/4 MILE
ON RIGHT LOT 13 JB

STRUCTURE: 000 000 52X48 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/18/07 1/18/07	KS CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339340 A.M. if possible. Thanks
B101 02	1/19/07 1/19/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339902 A.M. if possible. Thanks
A814 01	1/25/07 1/25/07	TI AP	ADDRESS CONFIRMATION VRU #: 001343524 70 D'ANGO CIR LOT 13
B103 01	1/25/07 1/25/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001343540
B105 01	1/30/07 <u>1-30</u>	TI <u>AP</u>	R*OPEN FLOOR VRU #: 001345891 A.M if possible. Thanks

KS

----- COMMENTS AND NOTES -----

ADDRESS : 70 D'ANGO CIR
CONTRACTOR : C W W CONTRACTORS
OWNER : WEAVER CHRISTOPHER & ANGELA
PARCEL : 04-0662- - -0015- -16-
APPL NUMBER: 06-50016438 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TOWARDS ANGIER LEFT ON HARNETT
CENTRAL RD PEAR MEADOW S/D IS 1/4 MILE
ON RIGHT LOT 13 JB

STRUCTURE: 000 000 52X48 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/18/07 1/18/07	KS CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339340 A.M. if possible. Thanks
B101 02	1/19/07 1/19/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339902 A.M. if possible. Thanks
A814 01	1/25/07 1/25/07	TI AP	ADDRESS CONFIRMATION VRU #: 001343524 70 D'ANGO CIR LOT 13
B103 01	1/25/07 1/25/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001343540
B105 01	1/30/07 1/30/07	KS AP	R*OPEN FLOOR VRU #: 001345891 A.M if possible. Thanks
R425 01	2/26/07 2/26/07	KB DA	FOUR TRADE ROUGH IN VRU #: 001360288 Horizontal branch drain not 3 inch. One you are beyond the vent and go horizontal, it becomes the branch drain. It doesn't matter that it is only 2 feet.
R425 02	2/27/07 <u>2/27/07</u>	TI <u>APR</u>	FOUR TRADE ROUGH IN VRU #: 001361757 P.M. if possible, Thanks

----- COMMENTS AND NOTES -----

ADDRESS : 70 D'ANGO CIR
CONTRACTOR : C W W CONTRACTORS
OWNER : WEAVER CHRISTOPHER & ANGELA
PARCEL : 04-0662- - -0015- -16-
APPL NUMBER: 06-50016438 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TOWARDS ANGIER LEFT ON HARNETT
CENTRAL RD PEAR MEADOW S/D IS 1/4 MILE
ON RIGHT LOT 13 JB

STRUCTURE: 000 000 52X48 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/18/07 1/18/07	KS CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339340 A.M. if possible. Thanks
B101 02	1/19/07 1/19/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339902 A.M. if possible. Thanks
A814 01	1/25/07 1/25/07	TI AP	ADDRESS CONFIRMATION VRU #: 001343524 70 D'ANGO CIR LOT 13
B103 01	1/25/07 1/25/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001343540
B105 01	1/30/07 1/30/07	KS AP	R*OPEN FLOOR VRU #: 001345891 A.M if possible. Thanks
R425 01	2/26/07 2/26/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001360288 Horizontal branch drain not 3 inch. One you are beyond the vent and go horizontal, it becomes the branch drain. It doesn't matter that it is only 2 feet.
R425 02	2/27/07 2/27/07	BS AP	FOUR TRADE ROUGH IN VRU #: 001361757 P.M. if possible, Thanks
I129 01	3/01/07 <u>3-1</u>	TI <u>AP</u>	R*INSULATION INSPECTION VRU #: 001362920 <u>KS</u>

COMMENTS AND NOTES

ADDRESS : 70 D'ANGO CIR
CONTRACTOR : C W W CONTRACTORS
OWNER : WEAVER CHRISTOPHER & ANGELA
PARCEL : 04-0662- - -0015- -16-
APPL NUMBER: 06-50016438 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 TOWARDS ANGIER LEFT ON HARNETT
CENTRAL RD PEAR MEADOW S/D IS 1/4 MILE
ON RIGHT LOT 13 JB

SUBDIV:
PHONE : (919) 639-0522
PHONE : (919) 639-0522

STRUCTURE: 000 000 52X48 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/18/07 1/18/07	KS CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339340 A.M. if possible. Thanks
B101 02	1/19/07 1/19/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001339902 A.M. if possible. Thanks
A814 01	1/25/07 1/25/07	TI AP	ADDRESS CONFIRMATION VRU #: 001343524 ✓70 D'ANGO CIR LOT 13
B103 01	1/25/07 1/25/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001343540
B105 01	1/30/07 1/30/07	KS AP	R*OPEN FLOOR VRU #: 001345891 A.M if possible. Thanks
R425 01	2/26/07 2/26/07	KS DA	FOUR TRADE ROUGH IN VRU #: 001360288 Horizontal branch drain not 3 inch. One you are beyond the vent and go horizontal, it becomes the branch drain. It doesn't matter that it is only 2 feet.
R425 02	2/27/07 2/27/07	BS AP	FOUR TRADE ROUGH IN VRU #: 001361757 P.M. if possible, Thanks
I129 01	3/01/07 3/01/07	KS AP	R*INSULATION INSPECTION VRU #: 001362920
H824 01	3/19/07 3/19/07	JM AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001374610
R429 01	4/26/07	TI	FOUR TRADE FINAL VRU #: 001397694

4-26 AP KS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Conditional Use Permit No.: _____

Type of Construction: V

Building Permit No.: _____

Owner of Building: CW Contractors

Electrical Permit No.: _____

Building Address: 70 Dango

Insulation Permit No.: _____

Zoning District: _____

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: 06-5-16432

Date: 4-26-07

Envir. C.O. No.: _____

K. Slatts

Building Official

Zoning Official