HTE# 16-5-16438

## Harnett County Department of Public Health 24027

## **Improvement Permit**

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: SC 1403 HARVETT Contral SUBDIVISION Pean Meadow ISSUED TO: CWW Contractors EXPANSION Site Improvements required prior to Construction Authorization Issuance: Proposed Wastewater System Type: 25% REDUCTION System Projected Daily Flow: \_\_\_\_\_\_ GPD Number of bedrooms: \_\_\_\_\_\_ Number of Occupants: \_\_\_\_\_ max Basement TYes Pump Required: ☐Yes ☐ No ☐ May be required based on final location and elevations of facilities Type of Water Supply: 

Community Public Well Distance from well feet Five years Permit valid for: Permit conditions: ☐ No expiration Authorized State Agents Date: 1-16-07 SEE ATTACHED SITE SKETCH The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This Gite is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: COW CONTRACTORS PROPERTY LOCATION: 302/403 Harnest Cefral
SUBDIVISION Pero Maglow LOT # 13 SUBDIVISION <u>Pern Me</u>

New 
Expansion 
Repair Facility Type: SFD Basement? Yes No Basement Fixtures? Yes No Type of Wastewater System\*\* 25% REDUCTION System (Initial) Wastewater Flow: 360 GPD (See note below, if applicable □) Installation Requirements/Conditions Septic Tank Size 1000 gallons Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: 24 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Aggregate Depth: Z inches above pipe

| Z inches above pipe | | Z inches total Pump Requirements: ft. TDH vs. GPM \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

ames & Manhartons

Authorized State Agent:

SEE ATTACHED SITE SKETCH

Date: 1-14-07

Construction Authorization Expiration Date: 1-16-12

HTE# 06-5-1	16	4	38
-------------	----	---	----

Permit # 24027

## Harnett County Department of Public Health Site Sketch

	PROPERTY LOCATON: <u>SR 1403 HARNETT CO.</u>	ntral
ISSUED TO: CWW Contractors	SUBDIVISION Pennmander	LOT # _ <i>_/_3</i>
Authorized State Agent James & Manh	Date:	-07

