

HTE# 06-5-16444

Harrison County Department of Public Health

24037

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: RONNIE + JONI CROSS PROPERTY LOCATION: 521418 REVERD
 NEW REPAIR EXPANSION SUBDIVISION: Captains Landing LOT # 45
 Site Improvements required prior to Construction Authorization Issuance: _____
 Type of Structure: Exs Foundation
 Proposed Wastewater System Type: 25% REDUCTION SYSTEM
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: James E. Markantons Date: 2-1-07 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: RONNIE + JONI CROSS PROPERTY LOCATION: 521418 REVERD
 SUBDIVISION: Captains Landing LOT # 45
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable NONE NEEDED (Repair))

Installation Requirements/Conditions

MANHOLE 3 X
 Septic Tank Size 1000 gallons Exact length of each trench 80 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
3- 3/4 TAPS Maximum Trench Depth of: 26 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
 Conditions: Pump MAY NOT BE REQUIRED - DEMONSTRATE FIRST 2 inches above pipe
12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markantons Date: 2-1-07
 Construction Authorization Expiration Date: 2-1-12

HTE# 06-5-16444

Permit # 24037

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: 512-1418 NEWARD

ISSUED TO: RONNIE + JONI CROSS

SUBDIVISION CAPTAINS LANDING

LOT # 45

Authorized State Agent: James C. Mantelous

Date: 2-1-07

