

HTE# 0650016471

Harnett County Department of Public Health 23514

Improvement Permit

(Howell Edwards)

This permit cannot be issued with only an Improvement Permit

ISSUED TO: The Quest Development Co. Inc. PROPERTY LOCATION: SR 1125 Lemuel Black Rd. SUBDIVISION Gatewest LOT # 49

NEW REPAIR EXPANSION Type of Structure: SFD

Proposed Wastewater System Type: 25% Reduction System

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 100 feet

Permit conditions: _____ Permit valid for: Five years No expiration

Authorized State Agent: S. P. Pierce Date: 1/12/07 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: The Quest Development Co. Inc. PROPERTY LOCATION: SR 1125 Lemuel Black Rd. SUBDIVISION Gatewest LOT # 49

Facility Type: SFD New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% Reduction (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable) 25% Reduction (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 3x60 feet Trench Spacing: 9 Feet on Center
Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 12-20 inches
Maximum Trench Depth of: 24-32 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
(Trench bottoms shall be level to +/-1/4" in all directions)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
_____ inches above pipe
Conditions: _____ inches total

**If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: S. P. Pierce Date: 1/12/07 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 1/12/12

HTE# 0650016471

Permit # 23514

**Harnett County Department of Public Health
Site Sketch**

(Howell Edwards)

ISSUED TO: The Quest Development Co. Inc. PROPERTY LOCATOR: SR1125 Lemuel Black Rd.
SUBDIVISION Gatewest LOT # 49

Authorized State Agent: C. Pierce Date: 1/12/07

3x60' 25% Reducti

