
ADDRESS . : 106 TROLLY LN SUBDIV: CANE MILL ESTS
 CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
 OWNER . . : WHITTENTON BUILDERS INC #25 PHONE : (910) 894-5591
 PARCEL . . : 02-1507- - -0005- -48-
 APPL NUMBER: 07-50016507 CP GARAGE/CARPORT RESIDENTIAL DETACHED
 DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
 GO 2.5 MILES TO CANE MILL EST TURN LEFT
 INTO S/D LOT 12 JB

STRUCTURE: 000 000 30X25 GARAGE STORAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : GARAGE STORAGE
 SEPTIC - EXISTING? : NEW SEWER : UNKNOWN
 WATERSHED DISTRICT : NA

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/20/10 <u>4-20</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001912591

COMMENTS AND NOTES

ADDRESS . : 106 TROLLY LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER . . : WHITTENTON BUILDERS INC #25 PHONE : (910) 894-5591
PARCEL . . : 02-1507- - -0005- -48-
APPL NUMBER: 07-50016507 CP GARAGE/CARPORT RESIDENTIAL DETACHED
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILES TO CANE MILL EST TURN LEFT
INTO S/D LOT 12 JB

STRUCTURE: 000 000 30X25 GARAGE STORAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : GARAGE STORAGE
SEPTIC - EXISTING? : NEW SEWER : UNKNOWN
WATERSHED DISTRICT : NA

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/20/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001912591
	4/20/10	AP	
B103 01	4/29/10	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001917699
	4/29/10	AP	T/S: 04/28/2010 11:15 AM JBROCK -----
R425 01	5/21/10	TI	FOUR TRADE ROUGH IN VRU #: 001929890

5-1-10 DABJ

COMMENTS AND NOTES

ADDRESS . : 106 TROLLY LN SUBDIV: CANE MILL ESTS
CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
OWNER . . : WHITTENTON BUILDERS INC #25 PHONE : (910) 894-5591
PARCEL . . : 02-1507- - -0005- -48-
APPL NUMBER: 07-50016507 CP GARAGE/CARPORT RESIDENTIAL DETACHED
DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
GO 2.5 MILES TO CANE MILL EST TURN LEFT
INTO S/D LOT 12 JB

STRUCTURE: 000 000 30X25 GARAGE STORAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : GARAGE STORAGE
SEPTIC - EXISTING? : NEW SEWER : UNKNOWN
WATERSHED DISTRICT : NA

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/20/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001912591
	4/20/10	AP	
B103 01	4/29/10	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001917699
	4/29/10	AP	T/S: 04/28/2010 11:15 AM JBROCK -----
R425 01	5/21/10	BS	FOUR TRADE ROUGH IN VRU #: 001929890
	5/21/10	DA	1. Anchor wall supporting steel beam with min 5 inch embedment wedge type anchor. Anchor either side of stud column.or provide engineering. 2. Window instairs shall be tempered glass top and bottom sash. 3. Insulate all water lines W/ R-6 min pipe insulation 4. All plumbing nail plates shall extend 2 inches below top plate. 5. Need som type of verification that slab was thickened at beam support. No slab inspection was done on this job.
R425 02	5/26/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001932086
	<u>5-26</u>	<u>AE</u>	T/S: 05/25/2010 08:51 AM RDCONTE -----

PERMIT: CPIR 00 CP INSULATION RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	5/26/10	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001932169
	<u>5-26</u>	<u>AP</u>	T/S: 05/25/2010 10:03 AM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS : 106 TROLLY LN SUBDIV: CANE MILL ESTS
 CONTRACTOR : WHITTENTON BUILDERS ENTERPRISE PHONE : (919) 894-5591
 OWNER : WHITTENTON BUILDERS INC #25 PHONE : (910) 894-5591
 PARCEL : 02-1507- - -0005- -48-
 APPL NUMBER: 07-50016507 CP GARAGE/CARPORT RESIDENTIAL DETACHED

DIRECTIONS : HWY 27 TO RED HILL CHURCH RD TURN RIGHT
 GO 2.5 MILES TO CANE MILL EST TURN LEFT
 INTO S/D LOT 12 JB

STRUCTURE: 000 000 30X25 GARAGE STORAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : GARAGE STORAGE
 SEPTIC - EXISTING? : NEW SEWER : UNKNOWN
 WATERSHED DISTRICT : NA

PERMIT: CPBP 00 CP BUILDING PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/20/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001912591
	4/20/10	AP	
B103 01	4/29/10	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001917699
	4/29/10	AP	T/S: 04/28/2010 11:15 AM JBROCK -----
R425 01	5/21/10	BS	FOUR TRADE ROUGH IN VRU #: 001929890
	5/21/10	DA	1. Anchor wall supporting steel beam with min 5 inch embedment wedge type anchor. Anchor either side of stud column.or provide engineering. 2. Window instairs shall be tempered glass top and bottom sash. 3. Insulate all water lines W/ R-6 min pipe insulation 4. All plumbing nail plates shall extend 2 inches below top plate. 5. Need some type of verification that slab was thickened at beam support. No slab inspection was done on this job.
R425 02	5/26/10	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001932086
	5/26/10	AE	T/S: 05/25/2010 08:51 AM RDCONTE ----- Insulation OK Did not provide anything
			T/S: 05/26/2010 10:49 AM KSLATTUM -----
R131 01	7/13/10	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 001953140
	<u>7-13-10</u>	<u>APBS</u>	T/S: 07/12/2010 11:44 AM RDCONTE -----

PERMIT: CPER 00 CP ELECTRICAL RESIDENTIAL

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R131 01	7/13/10	TI	ONE TRADE FINAL TIME: 17:00 VRU #: 001953157
			T/S: 07/12/2010 11:44 AM RDCONTE -----

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Res Detached Garage

Permit Numbers

Name: Whittenton Builders

Building: 07-50016507

Address: 106 Trolley Lane

Electrical: 07-50016507

Insulation: XXXXXXXXXX

Plumbing: XXXXXXXXXX

Mechanical: XXXXXXXXXX

MFG Home: XXXXXXXXXX

Date: 07-13-10

Building Official: *BS*