

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: 1-19-87
 Proposed Facility: SFD Design Flow (.1949): 360 Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 2%	0-28	C	Frm 1 st S.P	86" 7.5yr				.35
2	L 4%	0-27	SL	FR GIL NSNP					.3
		27-48	SL-CL	Frm 1 st S.P	40" 7.5yr				
3	L 4%	0-72	SL	FR GIL NSNP					.3
		72-48	SL-CL	Frm 1 st S.P	42" 7.5yr				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25%	APP
Site LTAR	.3	.25

Other Factors (.1946): _____
 Site Classification (.1948): _____
 Evaluated By: *[Signature]*
 Others Present: _____

COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>		
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY		
S-SHOULDER SLOPE		LS-LOAMY SAND				FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY		
FS-FOOT SLOPE		L-LOAM				VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE						EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE	III	SI-SILT-	0.6 - 0.3		SP-SLIGHTLY STICKY		
CC-CONCLAVE SLOPE		SIL-SILT LOAM				P-PLASTIC	
CV-CONVEX SLOPE		CL-CLAY LOAM				VP-VERY PLASTIC	
T-TERRACE		SCL-SANDY CLAY LOAM					
FP-FLOOD PLAN		SICL-SILTY CLAY LOAM					
	IV	SIC-SILTY CLAY	0.4 - 0.1				
		C-CLAY					
		SC-SANDY CLAY					

STRUCTURE

- SG-SINGLE GRAIN
- M-MASSIVE
- CR-CRUMB
- GR-GRANULAR
- SBK-SUBANGULAR BLOCKY
- ABK-ANGULAR BLOCKY
- PL-PLATY
- PR-PRISMATIC

MINERALOGY

- SLIGHTLY EXPANSIVE
- EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).

