
ADDRESS . . : 496 FIELDSTONE DR SUBDIV: FIELDSTONE FARMS
 CONTRACTOR : PHONE :
 OWNER . . : VARINCA SERGIO & NILUFER #9 PHONE : (919) 868-6211
 PARCEL . . : 05-0635- - -0058- -11-
 APPL NUMBER: 07-50016511 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 421 NORTH TO CHRISTIAN LIGHT RD LEFT ON
 42 LEFT ON WADE STEPHENSON RIGHT ON
 FIELD STONE LOT 9 JB
 LAND NOTES : LXMN 8/02/05 SPLIT FROM THE 01 PARCEL
 NOTE: ALLOWABLE IMPERVIOUS SURFACE
 COVERAGE PER LOT IS 12%

STRUCTURE: 000 000 78X58 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	<u>2/08/07</u> <u>2807</u>	TT <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001349976

----- COMMENTS AND NOTES -----

ADDRESS . : 496 FIELDSTONE DR SUBDIV: FIELDSTONE FARMS
CONTRACTOR : PHONE :
OWNER . . : VARINCA SERGIO & NILUFER #9 PHONE : (919) 868-6211
PARCEL . . : 05-0635- - -0058- -11-
APPL NUMBER: 07-50016511 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 421 NORTH TO CHRISTIAN LIGHT RD LEFT ON
42 LEFT ON WADE STEPHENSON RIGHT ON
FIELD STONE LOT 9 JB
LAND NOTES : LXMN 8/02/05 SPLIT FROM THE 01 PARCEL
NOTE: ALLOWABLE IMPERVIOUS SURFACE
COVERAGE PER LOT IS 12%

STRUCTURE: 000 000 78X58 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/08/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001349976
	2/08/07	AP	
B103 01	2/21/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001357720
	<u>2-21-07</u>	<u>DAYS</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 496 FIELDSTONE DR SUBDIV: FIELDSTONE FARMS
CONTRACTOR : PHONE :
OWNER : VARINCA SERGIO & NILUFER #9 PHONE : (919) 868-6211
PARCEL : 05-0635- - -0058- -11-
APPL NUMBER: 07-50016511 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 421 NORTH TO CHRISTIAN LIGHT RD LEFT ON
42 LEFT ON WADE STEPHENSON RIGHT ON
FIELD STONE LOT 9 JB

LAND NOTES : LXMN 8/02/05 SPLIT FROM THE 01 PARCEL
NOTE: ALLOWABLE IMPERVIOUS SURFACE
COVERAGE PER LOT IS 12%

STRUCTURE: 000 000 78X58 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/08/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001349976
	2/08/07	AP	
B103 01	2/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001357720
	2/21/07	DA	1. Front wall on left side of house is hanging off of footing 3 inches on interior side. Dig out interior side along the entire wall length TO THE BOTTOM OF EXISTING FOOTING, drill and pin the existing footing with #4 rebar, and call to reschedule inspection.
B103 03	2/27/07 <u>2/27/07</u>	TI <u>APBS</u>	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001362789

COMMENTS AND NOTES

ADDRESS . : 496 FIELDSTONE DR SUBDIV: FIELDSTONE FARMS
 CONTRACTOR : PHONE :
 OWNER . . : VARINCA SERGIO & NILUFER #9 PHONE : (919) 868-6211
 PARCEL . . : 05-0635- - -0058- -11-
 APPL NUMBER: 07-50016511 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 421 NORTH TO CHRISTIAN LIGHT RD LEFT ON
 42 LEFT ON WADE STEPHENSON RIGHT ON
 FIELD STONE LOT 9 JB
 LAND NOTES : LXMN 8/02/05 SPLIT FROM THE 01 PARCEL
 NOTE: ALLOWABLE IMPERVIOUS SURFACE
 COVERAGE PER LOT IS 12%

STRUCTURE: 000 000 78X58 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/08/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001349976
	2/08/07	AP	
B103 01	2/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001357720
	2/21/07	DA	1. Front wall on left side of house is hanging off of footing 3 inches on interior side. Dig out interior side along the entire wall length TO THE BOTTOM OF EXISTING FOOTING, drill and pin the existing footing with #4 rebar, and call to reschedule inspection.
B103 03	2/27/07	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001362789
	2/27/07	AP	
B103 02	2/28/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001362771
	2/27/07	CA	
B105 01	2/28/07	TI	R*OPEN FLOOR VRU #: 001362763
	<u>2/28/07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

Need Engineering on change of Floor @ Garage Cover

ADDRESS . : 496 FIELDSTONE DR SUBDIV: FIELDSTONE FARMS
 CONTRACTOR : PHONE :
 OWNER . . : VARINCA SERGIO & NILUFER #9 PHONE : (919) 868-6211
 PARCEL . . : 05-0635- - -0058- -11-
 APPL NUMBER: 07-50016511 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 421 NORTH TO CHRISTIAN LIGHT RD LEFT ON
 42 LEFT ON WADE STEPHENSON RIGHT ON
 FIELD STONE LOT 9 JB
 LAND NOTES : LXMN 8/02/05 SPLIT FROM THE 01 PARCEL
 NOTE: ALLOWABLE IMPERVIOUS SURFACE
 COVERAGE PER LOT IS 12%

STRUCTURE: 000 000 78X58 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/08/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001349976
	2/08/07	AP	
B103 01	2/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001357720
	2/21/07	DA	1. Front wall on left side of house is hanging off of footing 3 inches on interior side. Dig out interior side along the entire wall length TO THE BOTTOM OF EXISTING FOOTING, drill and pin the existing footing with #4 rebar, and call to reschedule inspection.
B103 03	2/27/07	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001362789
	2/27/07	AP	
B103 02	2/28/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001362771
	2/27/07	CA	
B105 01	2/28/07	BS	R*OPEN FLOOR VRU #: 001362763
	2/28/07	AE	Have engineers letter for floor system change before rough in inspection.
A814 01	3/05/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001362750
	2/28/07	AP	496 fieldstone dr lot 9
R427 01	4/19/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001392679

4/19/07 DABS

----- COMMENTS AND NOTES -----

0

ADDRESS . : 496 FIELDSTONE DR SUBDIV: FIELDSTONE FARMS
 CONTRACTOR : PHONE :
 OWNER . . : VARINCA SERGIO & NILUFER #9 PHONE : (919) 868-6211
 PARCEL . . : 05-0635- - -0058- -11-
 APPL NUMBER: 07-50016511 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 421 NORTH TO CHRISTIAN LIGHT RD LEFT ON
 42 LEFT ON WADE STEPHENSON RIGHT ON
 FIELD STONE LOT 9 JB
 LAND NOTES : LXMN 8/02/05 SPLIT FROM THE 01 PARCEL
 NOTE: ALLOWABLE IMPERVIOUS SURFACE
 COVERAGE PER LOT IS 12%

STRUCTURE: 000 000 78X58 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/08/07 2/08/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001349976
B103 01	2/21/07 2/21/07	BS DA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001357720 1. Front wall on left side of house is hanging off of footing 3 inches on interior side. Dig out interior side along the entire wall length TO THE BOTTOM OF EXISTING FOOTING, drill and pin the existing footing with #4 rebar, and call to reschedule inspection.
B103 03	2/27/07 2/27/07	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001362789
B103 02	2/28/07 2/27/07	TI CA	R*BLDG FOUND & TEMP SVC POLE VRU #: 001362771
B105 01	2/28/07 2/28/07	BS AE	R*OPEN FLOOR VRU #: 001362763 Have engineers letter for floor system change before rough in inspection.
A814 01	3/05/07 2/28/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001362750 496 fieldstone dr lot 9
R427 01	4/19/07 4/19/07	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001392679 1. Need tempered glass both sashes either side of front door (at final) 2. Block under roof LVL at garage ceiling at I joist. 3. Bond gas line back to panel. 4. Correct service wiring. 5. Flash at garage wing wall and at deck where brick veneer is going. OK TO SIDE/INSULATE
I129 01	4/24/07 <i>4-24-07</i>	TI <i>APBS</i>	R*INSULATION INSPECTION VRU #: 001395656
R425 01	4/24/07 <i>4-24-07</i>	TI <i>TI</i>	FOUR TRADE ROUGH IN VRU #: 001395649

COMMENTS AND NOTES

ADDRESS . : 496 FIELDSTONE DR SUBDIV: FIELDSTONE FARMS
 CONTRACTOR : PHONE :
 OWNER . . : VARINCA SERGIO & NILUFER #9 PHONE : (919) 868-6211
 PARCEL . . : 05-0635- - -0058- -11-
 APPL NUMBER: 07-50016511 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 421 NORTH TO CHRISTIAN LIGHT RD LEFT ON
 42 LEFT ON WADE STEPHENSON RIGHT ON
 FIELD STONE LOT 9 JB
 LAND NOTES : LXMN 8/02/05 SPLIT FROM THE 01 PARCEL
 NOTE: ALLOWABLE IMPERVIOUS SURFACE
 COVERAGE PER LOT IS 12%

STRUCTURE: 000 000 78X58 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/08/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001349976
	2/08/07	AP	
B103 01	2/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001357720
	2/21/07	DA	1. Front wall on left side of house is hanging off of footing 3 inches on interior side. Dig out interior side along the entire wall length TO THE BOTTOM OF EXISTING FOOTING, drill and pin the existing footing with #4 rebar, and call to reschedule inspection.
B103 03	2/27/07	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001362789
	2/27/07	AP	
B103 02	2/28/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001362771
	2/27/07	CA	
B105 01	2/28/07	BS	R*OPEN FLOOR VRU #: 001362763
	2/28/07	AE	Have engineers letter for floor system change before rough in inspection.
A814 01	3/05/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001362750
	2/28/07	AP	✓496 fieldstone dr lot 9
R427 01	4/19/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001392679
	4/19/07	DA	1. Need tempered glass both sashes either side of front door (at final) 2. Block under roof LVL at garage ceiling at I joist. 3. Bond gas line back to panel. 4. Correct service wiring. 5. Flash at garage wing wall and at deck where brick veneer is going. OK TO SIDE/INSULATE
I129 01	4/24/07	BS	R*INSULATION INSPECTION VRU #: 001395656
	4/24/07	AP	
R425 01	4/24/07	BS	FOUR TRADE ROUGH IN VRU #: 001395649
	4/24/07	AP	
H824 01	5/11/07	JM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001409234
	5/11/07	AP	
R429 01	7/26/07	TI	FOUR TRADE FINAL VRU #: 001454396
	<u>7-26-07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD
Type of Construction: II
Owner of Building: Suzie D. Vainco
Building Address: 496 Fieldstone
Zoning District: _____
Zoning Permit No.: H/A

Conditional Use Permit No.: _____
Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: 015-16511
Mech. Permit No.: _____
Envir. C.O. No.: _____

Date: 7.26.07
Bruce Sutter

Building Official

Zoning Official