

PREPARED 2/26/07, 14:00:08
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 53
DATE 2/27/07

ADDRESS : 15 TOPSAIL DR
CONTRACTOR : BRADLEY BUILT INC
OWNER : IOM DEVELOPERS INC #1
PARCEL : 04-0673- - -0134- - -
APPL NUMBER: 07-50016542 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 E LEFT ON JAMES NORRIS RD S/D ON
THE RIGHT AUTUMN POINT #1 JB

SUBDIV: AUTUMN POINTE 29 LOTS
PHONE : (919) 639-2073
PHONE : (919) 639-2073

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/27/07 <u>2-27-07</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001361500

----- COMMENTS AND NOTES -----

ADDRESS : 15 TOPSAIL DR
CONTRACTOR : BRADLEY BUILT INC
OWNER : IOM DEVELOPERS INC #1
PARCEL : 04-0673- - -0134- - -
APPL NUMBER: 07-50016542 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 E LEFT ON JAMES NORRIS RD S/D ON
THE RIGHT AUTUMN POINT #1 JB

SUBDIV: AUTUMN POINTE 29 LOTS
PHONE : (919) 639-2073
PHONE : (919) 639-2073

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/27/07 2/27/07	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001361500
B103 01	3/05/07 <u>3-5</u>	TI <u>AP</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001364838 <u>KS</u>

COMMENTS AND NOTES

ADDRESS : 15 TOPSAIL DR
CONTRACTOR : BRADLEY BUILT INC
OWNER : IOM DEVELOPERS INC #1
PARCEL : 04-0673- - -0134- - -
APPL NUMBER: 07-50016542 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 E LEFT ON JAMES NORRIS RD S/D ON
THE RIGHT AUTUMN POINT #1 JB

SUBDIV: AUTUMN POINTE 29 LOTS
PHONE : (919) 639-2073
PHONE : (919) 639-2073

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/27/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001361500
	2/27/07	AP	
B103 01	3/05/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001364838
	3/05/07	AP	
B105 01	3/07/07	TI	R*OPEN FLOOR VRU #: 001366558
	<u>3-7-07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 15 TOPSAIL DR
CONTRACTOR : BRADLEY BUILT INC
OWNER : IOM DEVELOPERS INC #1
PARCEL : 04-0673- - -0134- - -
APPL NUMBER: 07-50016542 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 E LEFT ON JAMES NORRIS RD S/D ON
THE RIGHT AUTUMN POINT #1 JB

SUBDIV: AUTUMN POINTE 29 LOTS
PHONE : (919) 639-2073
PHONE : (919) 639-2073

STRUCTURE: 000 000 40X60 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/27/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001361500
	2/27/07	AP	
B103 01	3/05/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001364838
	3/05/07	AP	
B105 01	3/07/07	BS	R*OPEN FLOOR VRU #: 001366558
	3/07/07	AP	
R427 01	3/20/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001373349

3-20 ~~AA~~
DA

COMMENTS AND NOTES

ADDRESS . : 15 TOPSAIL DR
 CONTRACTOR : BRADLEY BUILT INC
 OWNER . . : IOM DEVELOPERS INC #1
 PARCEL . . : 04-0673- - -0134- - -
 APPL NUMBER: 07-50016542 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 E LEFT ON JAMES NORRIS RD S/D ON
 THE RIGHT AUTUMN POINT #1 JB

SUBDIV: AUTUMN POINTE 29 LOTS
 PHONE : (919) 639-2073
 PHONE : (919) 639-2073

STRUCTURE: 000 000 40X60 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/27/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001361500
	2/27/07	AP	
B103 01	3/05/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001364838
	3/05/07	AP	
B105 01	3/07/07	BS	R*OPEN FLOOR VRU #: 001366558
	3/07/07	AP	
R427 01	3/20/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001373349
	3/20/07	DA	1. Need receptacle at floor height on rear wall of countertop. 2. Need front, rear and garage doors installed 3. tighten nut on anchor bolt in garage T/S: 03/20/2007 02:59 PM KSLATTUM ----- OK to insulate
I129 01	3/22/07	TI	R*INSULATION INSPECTION VRU #: 001375518
	<u>3-22</u>	<u>DA</u>	
R425 01	3/22/07	TI	FOUR TRADE ROUGH IN VRU #: 001375500
	<u>3-22</u>	<u>DP</u>	

COMMENTS AND NOTES

ADDRESS : 15 TOPSAIL DR SUBDIV: AUTUMN POINTE 29 LOTS
 CONTRACTOR : BRADLEY BUILT INC PHONE : (919) 639-2073
 OWNER : IOM DEVELOPERS INC #1 PHONE : (919) 639-2073
 PARCEL : 04-0673- - -0134- - -
 APPL NUMBER: 07-50016542 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 210 E LEFT ON JAMES NORRIS RD S/D ON
 THE RIGHT AUTUMN POINT #1 JB

STRUCTURE: 000 000 40X60 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/27/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001361500
	2/27/07	AP	
B103 01	3/05/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001364838
	3/05/07	AP	
B105 01	3/07/07	BS	R*OPEN FLOOR VRU #: 001366558
	3/07/07	AP	
R427 01	3/20/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001373349
	3/20/07	DA	1. Need receptacle at floor height on rear wall of countertop. 2. Need front, rear and garage doors installed 3. tighten nut on anchor bolt in garage T/S: 03/20/2007 02:59 PM KSLATTUM ----- OK to insulate
I129 01	3/22/07	KS	R*INSULATION INSPECTION VRU #: 001375518
	3/22/07	DA	
R425 01	3/22/07	KS	FOUR TRADE ROUGH IN VRU #: 001375500
	3/22/07	DP	Rough-in violations were no completed. Do not side, do not insulate \$50 reinspection fee
I129 02	3/23/07	TI	R*INSULATION INSPECTION VRU #: 001376573
	<u>3-23</u>	<u>AP</u>	
A814 01	3/23/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001373329
	3/20/07	AP	15 topsail dr
R425 02	3/23/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001376789
	<u>3-23</u>	<u>AP</u>	

COMMENTS AND NOTES

ADDRESS : 15 TOPSAIL DR SUBDIV: AUTUMN POINTE 29 LOTS
 CONTRACTOR : BRADLEY BUILT INC PHONE : (919) 639-2073
 OWNER : IOM DEVELOPERS INC #1 PHONE : (919) 639-2073
 PARCEL : 04-0673- - -0134- - -
 APPL NUMBER: 07-50016542 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 E LEFT ON JAMES NORRIS RD S/D ON
 THE RIGHT AUTUMN POINT #1 JB

STRUCTURE: 000 000 40X60 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/27/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001361500
	2/27/07	AP	
B103 01	3/05/07	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001364838
	3/05/07	AP	
B105 01	3/07/07	BS	R*OPEN FLOOR VRU #: 001366558
	3/07/07	AP	
R427 01	3/20/07	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001373349
	3/20/07	DA	1. Need receptacle at floor height on rear wall of countertop. 2. Need front, rear and garage doors installed 3. tighten nut on anchor bolt in garage T/S: 03/20/2007 02:59 PM KSLATTUM OK to insulate
I129 01	3/22/07	KS	R*INSULATION INSPECTION VRU #: 001375518
	3/22/07	DA	
R425 01	3/22/07	KS	FOUR TRADE ROUGH IN VRU #: 001375500
	3/22/07	DP	Rough-in violations were no completed. Do not side, do not insulate \$50 reinspection fee
I129 02	3/23/07	KS	R*INSULATION INSPECTION VRU #: 001376573
	3/23/07	AP	
A814 01	3/23/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001373329
	3/20/07	AP	✓15 topsail dr
R425 02	3/23/07	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001376789
	3/23/07	AP	
H824 01	4/13/07	JM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001390640
	4/13/07	AP	
R429 01	5/29/07	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001417138
	5/29/07	CA	
R429 02	6/05/07	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001421783

G-S AP KS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use, For the following:

Use Classification: Residential
Type of Construction: _____
Owner of Building: Grady Built
Building Address: 15 Topail
Zoning District: _____
Zoning Permit No.: _____

Conditional Use Permit No.: _____
Building Permit No.: _____
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: _____
Mech. Permit No.: _____
Envir. C.O. No.: 07-5-16542

Date: 5-5-07
Ke Stahl

Building Official

Zoning Official