

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: ISRAEL LUCAS PROPERTY LOCATION: 1139
 NEW REPAIR EXPANSION SUBDIVISION: Tingen Place LOT # 63
 Type of Structure: SFD - 48x59 3BR Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: Pump to ~~25%~~ 25% Reduction SYSTEM
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: STUBOUT Plumbing shall be at ground level or higher, where shown And pump may not be required. Meet on site - maintain All 1st Back No expiration

Authorized State Agent: _____ Date: _____ SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: ISRAEL LUCAS PROPERTY LOCATION: 1139
 Facility Type: SFD - 48x59 - 3BR New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Pump to 25% Red. system (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable) 240 LF 1 LLP (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 2x75 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 ↳ ZF needed Maximum Trench Depth of: 18.24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 Conditions: _____ inches above pipe
 _____ inches total

**If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
 Authorized State Agent: Ju Lucas Date: 01-23-07 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 01-23-2012

HTE# 07-500/6580

Permit # 23616

Harnett County Department of Public Health Site Sketch

ISSUED TO: ISRAEL LUCAS


PROPERTY LOCATOR: 1139

SUBDIVISION ZINZEN PLACE

LOT # 63

Authorized State Agent: J. W. ARS

Date: 01-27-07



STUB out Plumbing shallow
where shown, At ground level
or higher, and Pump may
not be needed.

Meet onsite
MAIN TAIN ALL
Set Backs

Install 2x75 of 25% Reduction
SYSTEM