

ADDRESS . . : 565 RUTH CIR
CONTRACTOR : OAK CITY HOMES, LLC
OWNER . . . : BALLARD WOODS LLC #81
PARCEL . . . : 08-0654-01- -0292- -17-
APPL NUMBER: 07-50016595 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401N TO FUQUAY RIGHT ON BALLARD RD
RIGHT ON JOSEPH ALEXANDER LEFT ONTO
RUTH CIRCLE LOT ON RIGHT. -A.DRIGGERS

SUBDIV: BALLARD WOODS
PHONE : (919) 833-5526
PHONE :

STRUCTURE: 000 000 60X60 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/04/07 <u>5-4-07</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001403136

----- COMMENTS AND NOTES -----

836 am
Lee Johnson
919-427-0218

ADDRESS . : 565 RUTH CIR
CONTRACTOR : OAK CITY HOMES, LLC
OWNER . . : BALLARD WOODS LLC #81
PARCEL . . : 08-0654-01- -0292- -17-
APPL NUMBER: 07-50016595 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401N TO FUQUAY RIGHT ON BALLARD RD
RIGHT ON JOSEPH ALEXANDER LEFT ONTO
RUTH CIRCLE LOT ON RIGHT. -A.DRIGGERS

SUBDIV: BALLARD WOODS
PHONE : (919) 833-5526
PHONE :

STRUCTURE: 000 000 60X60 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/04/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001403136
	5/04/07	AP	
B103 01	5/21/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412705
	<u>5-21-07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 565 RUTH CIR
CONTRACTOR : OAK CITY HOMES, LLC
OWNER . . . : BALLARD WOODS LLC #81
PARCEL . . . : 08-0654-01- -0292- -17-
APPL NUMBER: 07-50016595 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401N TO FUQUAY RIGHT ON BALLARD RD
RIGHT ON JOSEPH ALEXANDER LEFT ONTO
RUTH CIRCLE LOT ON RIGHT. -A.DRIGGERS

SUBDIV: BALLARD WOODS
PHONE : (919) 833-5526
PHONE :

STRUCTURE: 000 000 60X60 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/04/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001403136
	5/04/07	AP	
B103 01	5/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412705
	5/21/07	AP	No t pole installed. Can check t pole at open floor
A814 01	5/24/07	TI	ADDRESS CONFIRMATION VRU #: 001415561
B105 01	<u>5/24/07</u> <u>5-24-07</u>	<u>TI</u> <u>APBS</u>	R*OPEN FLOOR VRU #: 001415553

COMMENTS AND NOTES

T-pole

ADDRESS : 565 RUTH CIR
CONTRACTOR : OAK CITY HOMES, LLC
OWNER : BALLARD WOODS LLC #81
PARCEL : 08-0654-01- -0292- -17-
APPL NUMBER: 07-50016595 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401N TO FUQUAY RIGHT ON BALLARD RD
RIGHT ON JOSEPH ALEXANDER LEFT ONTO
RUTH CIRCLE LOT ON RIGHT. -A.DRIGGERS

SUBDIV: BALLARD WOODS
PHONE : (919) 833-5526
PHONE :

STRUCTURE: 000 000 60X60 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/04/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001403136
	5/04/07	AP	
B103 01	5/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412705
	5/21/07	AP	No t pole installed. Can check t pole at open floor
B105 01	5/24/07	BS	R*OPEN FLOOR VRU #: 001415553
	5/24/07	AP	
A814 01	5/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001415561
	5/31/07	AP	565 RUTH CIR LOT 81
R427 01	6/21/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001433168

6-21-07 *ABS*

COMMENTS AND NOTES

ADDRESS : 565 RUTH CIR
CONTRACTOR : OAK CITY HOMES, LLC
OWNER : BALLARD WOODS LLC #81
PARCEL : 08-0654-01- -0292- -17-
APPL NUMBER: 07-50016595 CP NEW RESIDENTIAL (SFD)

SUBDIV: BALLARD WOODS
PHONE : (919) 833-5526
PHONE :

DIRECTIONS : 401N TO FUQUAY RIGHT ON BALLARD RD
RIGHT ON JOSEPH ALEXANDER LEFT ONTO
RUTH CIRCLE LOT ON RIGHT. -A.DRIGGERS

STRUCTURE: 000 000 60X60 3BR SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/04/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001403136
	5/04/07	AP	
B103 01	5/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412705
	5/21/07	AP	No t pole installed. Can check t pole at open floor
B105 01	5/24/07	BS	R*OPEN FLOOR VRU #: 001415553
	5/24/07	AP	
A814 01	5/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001415561
	5/31/07	AP	565 RUTH CIR LOT 81
R427 01	6/21/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001433168
	6/21/07	DA	Dryer vent too long. 2. Install missing window at master tub. ok to side/insulate
I129 01	6/29/07	TI	R*INSULATION INSPECTION VRU #: 001437557
R427 02	6/29/07	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001438621

COMMENTS AND NOTES

ADDRESS . : 565 RUTH CIR
CONTRACTOR : OAK CITY HOMES, LLC
OWNER . . : BALLARD WOODS LLC #81
PARCEL . . : 08-0654-01- -0292- -17-
APPL NUMBER: 07-50016595 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 401N TO FUQUAY RIGHT ON BALLARD RD
RIGHT ON JOSEPH ALEXANDER LEFT ONTO
RUTH CIRCLE LOT ON RIGHT. -A.DRIGGERS

SUBDIV: BALLARD WOODS
PHONE : (919) 833-5526
PHONE :

STRUCTURE: 000 000 60X60 3BR SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/04/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001403136
	5/04/07	AP	
B103 01	5/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412705
	5/21/07	AP	No t pole installed. Can check t pole at open floor
B105 01	5/24/07	BS	R*OPEN FLOOR VRU #: 001415553
	5/24/07	AP	
A814 01	5/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001415561
	5/31/07	AP	✓565 RUTH CIR LOT 81
R427 01	6/21/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001433168
	6/21/07	DA	Dryer vent too long. 2. Install missing window at master tub. ok to side/insulate
I129 01	6/29/07	BS	R*INSULATION INSPECTION VRU #: 001437557
	6/29/07	AP	
R427 02	6/29/07	BS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001438621
	6/29/07	AP	
H824 01	7/19/07	OT	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001451228
	7/19/07	AP	
R431 01	8/27/07	TI	FOUR TRADE FINAL >2500 VRU #: 001474746
	8/27/07	CA	
R431 02	8/28/07	TI	FOUR TRADE FINAL >2500 VRU #: 001475362

8-28-07 MBS

----- COMMENTS AND NOTES -----

ADDRESS : 565 RUTH CIR SUBDIV: BALLARD WOODS
 CONTRACTOR : OAK CITY HOMES, LLC PHONE : (919) 833-5526
 OWNER : BALLARD WOODS LLC #81 PHONE :
 PARCEL : 08-0654-01- -0292- -17-
 APPL NUMBER: 07-50016595 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 401N TO FUQUAY RIGHT ON BALLARD RD
 RIGHT ON JOSEPH ALEXANDER LEFT ONTO
 RUTH CIRCLE LOT ON RIGHT. -A.DRIGGERS

STRUCTURE: 000 000 60X60 3BR SFD
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/04/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001403136
	5/04/07	AP	
B103 01	5/21/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001412705
	5/21/07	AP	No t pole installed. Can check t pole at open floor
B105 01	5/24/07	BS	R*OPEN FLOOR VRU #: 001415553
	5/24/07	AP	
A814 01	5/24/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001415561
	5/31/07	AP	✓565 RUTH CIR LOT 81
R427 01	6/21/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001433168
	6/21/07	DA	Dryer vent too long. 2. Install missing window at master tub. ok to side/insulate
I129 01	6/29/07	BS	R*INSULATION INSPECTION VRU #: 001437557
	6/29/07	AP	
R427 02	6/29/07	BS	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001438621
	6/29/07	AP	
H824 01	7/19/07	OT	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001451228
	7/19/07	AP	
R431 01	8/27/07	TI	FOUR TRADE FINAL >2500 VRU #: 001474746
	8/27/07	CA	
R431 02	8/28/07	BS	FOUR TRADE FINAL >2500 VRU #: 001475362
	8/28/07	DA	1. Insulate water lines in garage on water heater and sink. Also sink trap 2. Strap up water service line under house. 3. Dryer vent too long. Remove elbow in wall and install dryer box. 4. Flex under house not made up.
R431 03	8/29/07	TI	FOUR TRADE FINAL >2500 VRU #: 001476472

8/29/07 APB

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Type of Construction: VI

Owner of Building: DAK CITY HOMES LLC

Building Address: 565 Ruth Circle

Zoning District: _____

Zoning Permit No.: N/A

Date: 8-29-07

Brad Smith

Building Official

Conditional Use Permit No.: _____

Building Permit No.: 07-5-16595

Electrical Permit No.: 07-5-16595

Insulation Permit No.: 07-5-16595

Plumbing Permit No.: 07-5-16595

Mech. Permit No.: 07-5-16595

Envir. C.O. No.: _____

Zoning Official