

PREPARED 6/25/07, 13:58:51  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 17  
DATE 6/26/07

-----  
ADDRESS . . : 140 WILD WINDS DR  
CONTRACTOR : TURNER MATTHEWS CONSTRUCTION  
OWNER . . . : POPE BILLY G & PEGGY #5  
PARCEL . . . : 07-0690- - -0201- -11-  
APPL NUMBER: 07-50016612 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WILD WINDS #5 27 TO COATS LEFT ON 55  
APPROX TWO MILES SUB ON LEFT WILD WINDS  
DRIVE 200 YRDS DOWN ST VACANT LOT ON  
RIGHT. -A.DRIGGERS  
-----

SUBDIV:  
PHONE : (910) 984-4028  
PHONE : (910) 897-8460

-----  
STRUCTURE: 000 000 48X56.8 3BR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07	<i>AP</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435049

-----  
COMMENTS AND NOTES  
-----

-----

ADDRESS . . : 140 WILD WINDS DR  
 CONTRACTOR : TURNER MATTHEWS CONSTRUCTION  
 OWNER . . . : POPE BILLY G & PEGGY #5  
 PARCEL . . . : 07-0690- - -0201- -11-  
 APPL NUMBER: 07-50016612 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : WILD WINDS #5 27 TO COATS LEFT ON 55  
 APPROX TWO MILES SUB ON LEFT WILD WINDS  
 DRIVE 200 YRDS DOWN ST VACANT LOT ON  
 RIGHT. -A.DRIGGERS

SUBDIV:  
 PHONE : (910) 984-4028  
 PHONE : (910) 897-8460

-----  
**STRUCTURE: 000 000 48X56.8 3BR SFD**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 3.00 PROPOSED USE . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW

-----  
**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435049
	6/26/07	AP	
B103 01	7/06/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441755

*7/6/07 AEB*

----- COMMENTS AND NOTES -----

ADDRESS : 140 WILD WINDS DR  
CONTRACTOR : TURNER MATTHEWS CONSTRUCTION  
OWNER : POPE BILLY G & PEGGY #5  
PARCEL : 07-0690- - -0201- -11-  
APPL NUMBER: 07-50016612 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WILD WINDS #5 27 TO COATS LEFT ON 55  
APPROX TWO MILES SUB ON LEFT WILD WINDS  
DRIVE 200 YRDS DOWN ST VACANT LOT ON  
RIGHT. -A.DRIGGERS

SUBDIV:  
PHONE : (910) 984-4028  
PHONE : (910) 897-8460

STRUCTURE: 000 000 48X56.8 3BR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435049
	6/26/07	AP	
B103 01	7/06/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441755
	7/06/07	AE	Ok to backfill interior, clean exterior of foundation down to footing, apply damproofing from footing to final grade height, and leave open for inspection at floor system
B105 01	7/17/07	TI	R*OPEN FLOOR VRU #: 001447330

7-17 AP KS

COMMENTS AND NOTES

-----  
ADDRESS . : 140 WILD WINDS DR  
CONTRACTOR : TURNER MATTHEWS CONSTRUCTION  
OWNER . . : POPE BILLY G & PEGGY #5  
PARCEL . . : 07-0690- - -0201- -11-  
APPL NUMBER: 07-50016612 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WILD WINDS #5 27 TO COATS LEFT ON 55  
APPROX TWO MILES SUB ON LEFT WILD WINDS  
DRIVE 200 YRDS DOWN ST VACANT LOT ON  
RIGHT. -A.DRIGGERS  
-----

STRUCTURE: 000 000 48X56.8 3BR SFD  
FLOOD ZONE . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435049
	6/26/07	AP	
B103 01	7/06/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441755
	7/06/07	AE	Ok to backfill interior, clean exterior of foundation down to footing, apply damproofing from footing to final grade height, and leave open for inspection at floor system
B105 01	7/17/07	KS	R*OPEN FLOOR VRU #: 001447330
	7/17/07	AP	
A814 01	7/18/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001448018
	7/24/07	AP	140 Wild Winds Dr
R425 01	8/31/07	KS	FOUR TRADE ROUGH IN VRU #: 001477262
	8/31/07	DP	1. Plumbers still in work. Drain and water distribution not complete nor tested. \$50.00 re-inspection fee.
R425 02	9/05/07	TI	FOUR TRADE ROUGH IN VRU #: 001479443
	<u>9/5/07</u>	<u>DA DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 140 WILD WINDS DR  
CONTRACTOR : TURNER MATTHEWS CONSTRUCTION  
OWNER : POPE BILLY G & PEGGY #5  
PARCEL : 07-0690- - -0201- -11-  
APPL NUMBER: 07-50016612 CP NEW RESIDENTIAL (SFD)

SUBDIV:  
PHONE : (910) 984-4028  
PHONE : (910) 897-8460

DIRECTIONS : WILD WINDS #5 27 TO COATS LEFT ON 55  
APPROX TWO MILES SUB ON LEFT WILD WINDS  
DRIVE 200 YRDS DOWN ST VACANT LOT ON  
RIGHT. -A.DRIGGERS

STRUCTURE: 000 000 48X56.8 3BR SFD  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435049
	6/26/07	AP	
B103 01	7/06/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441755
	7/06/07	AE	Ok to backfill interior, clean exterior of foundation down to footing, apply damproofing from footing to final grade height, and leave open for inspection at floor system
B105 01	7/17/07	KS	R*OPEN FLOOR VRU #: 001447330
	7/17/07	AP	
A814 01	7/18/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001448018
	7/24/07	AP	140 Wild Winds Dr
R425 01	8/31/07	KS	FOUR TRADE ROUGH IN VRU #: 001477262
	8/31/07	DP	1. Plumbers still in work. Drain and water distribution not complete nor tested. \$50.00 re-inspection fee.
R425 02	9/05/07	DT	FOUR TRADE ROUGH IN VRU #: 001479443
	9/05/07	DA	1. Shower and tub in master bath not rodent proofed. Okay to side and insulate.
I129 01	9/21/07	TI	R*INSULATION INSPECTION VRU #: 001491004
	9-21	AP	
R425 03	9/21/07	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001491323
	9-21	AP	

COMMENTS AND NOTES

ADDRESS : 140 WILD WINDS DR  
CONTRACTOR : TURNER MATTHEWS CONSTRUCTION  
OWNER : POPE BILLY G & PEGGY #5  
PARCEL : 07-0690- - -0201- -11-  
APPL NUMBER: 07-50016612 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WILD WINDS #5 27 TO COATS LEFT ON 55  
APPROX TWO MILES SUB ON LEFT WILD WINDS  
DRIVE 200 YRDS DOWN ST VACANT LOT ON  
RIGHT. -A.DRIGGERS

SUBDIV:  
PHONE : (910) 984-4028  
PHONE : (910) 897-8460

STRUCTURE: 000 000 48X56.8 3BR SFD

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435049
	6/26/07	AP	
B103 01	7/06/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441755
	7/06/07	AE	Ok to backfill interior, clean exterior of foundation down to footing, apply damproofing from footing to final grade height, and leave open for inspection at floor system
B105 01	7/17/07	KS	R*OPEN FLOOR VRU #: 001447330
	7/17/07	AP	
A814 01	7/18/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001448018
	7/24/07	AP	140 Wild Winds Dr
R425 01	8/31/07	TI	FOUR TRADE ROUGH IN VRU #: 001477262

8-31 NP  
KS

COMMENTS AND NOTES

*Bara 910-309-6692*  
*D-2 Elect.*

-----  
ADDRESS . . : 140 WILD WINDS DR  
CONTRACTOR : TURNER MATTHEWS CONSTRUCTION  
OWNER . . . : POPE BILLY G & PEGGY #5  
PARCEL . . . : 07-0690- - -0201- -11-  
APPL NUMBER: 07-50016612 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : WILD WINDS #5 27 TO COATS LEFT ON 55  
APPROX TWO MILES SUB ON LEFT WILD WINDS  
DRIVE 200 YRDS DOWN ST VACANT LOT ON  
RIGHT. -A.DRIGGERS  
-----

SUBDIV:  
PHONE : (910) 984-4028  
PHONE : (910) 897-8460

-----  
STRUCTURE: 000 000 48X56.8 3BR SFD  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/07	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001435049
	6/26/07	AP	
B103 01	7/06/07	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001441755
	7/06/07	AE	Ok to backfill interior, clean exterior of foundation down to footing, apply damproofing from footing to final grade height, and leave open for inspection at floor system
B105 01	7/17/07	KS	R*OPEN FLOOR VRU #: 001447330
	7/17/07	AP	
A814 01	7/18/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001448018
	7/24/07	AP	✓140 Wild Winds Dr
R425 01	8/31/07	KS	FOUR TRADE ROUGH IN VRU #: 001477262
	8/31/07	DP	1. Plumbers still in work. Drain and water distribution not complete nor tested. \$50.00 re-inspection fee.
R425 02	9/05/07	DT	FOUR TRADE ROUGH IN VRU #: 001479443
	9/05/07	DA	1. Shower and tub in master bath not rodent proofed. Okay to side and insulate.
I129 01	9/21/07	KS	R*INSULATION INSPECTION VRU #: 001491004
	9/21/07	AP	
R425 03	9/21/07	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001491323
	9/21/07	AP	
H824 01	11/08/07	JM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001518273
	11/08/07	AP	
R429 01	12/20/07	TI	FOUR TRADE FINAL VRU #: 001538438
	<u>12-20</u>	<u>AP</u>	

-----  
COMMENTS AND NOTES  
-----

27200096

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential  
Type of Construction: V  
Owner of Building: Turner Mathen  
Building Address: 140 Wilburds Drive  
Zoning District: \_\_\_\_\_  
Zoning Permit No.: \_\_\_\_\_

Conditional Use Permit No.: \_\_\_\_\_  
Building Permit No.: \_\_\_\_\_  
Electrical Permit No.: \_\_\_\_\_  
Insulation Permit No.: \_\_\_\_\_  
Plumbing Permit No.: \_\_\_\_\_  
Mech. Permit No.: \_\_\_\_\_  
Envir. C.O. No.: 07-50016612

Date: 12-20-07  
Ken Shatt

Building Official

Zoning Official