
ADDRESS . . : 58 NEW RIVER CT
 CONTRACTOR :
 OWNER . . : IOM LAND COMPANY LLC #25
 PARCEL . . : 04-0673- - -0134- -28-
 APPL NUMBER: 07-50016661 CP NEW RESIDENTIAL (SFD)

SUBDIV: AUTUMN POINTE 29 LOTS
 PHONE :
 PHONE :

DIRECTIONS : 210 E LEFT ON JAME NORRIS S/D ON RIGHT
 LOT #25 JB

STRUCTURE: 000 000 40X60 BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/10 4/22/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001913996 T pole good. Need premise number. T/S: 04/22/2010 04:01 PM KSLATTUM -----
B103 01	5/10/10 <u>5-10</u>	TI <u>AP KS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001923280

COMMENTS AND NOTES -----

ADDRESS . : 58 NEW RIVER CT SUBDIV: AUTUMN POINTE 29 LOTS
CONTRACTOR : PHONE :
OWNER . . : IOM LAND COMPANY LLC #25 PHONE :
PARCEL . . : 04-0673- - -0134- -28-
APPL NUMBER: 07-50016661 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 E LEFT ON JAME NORRIS S/D ON RIGHT
LOT #25 JB
T/S: 02/17/2011 08:06 AM RDCONTE ---
PREMISE #42286612.

STRUCTURE: 000 000 40X60 BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/10 4/22/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001913996 T pole good. Need premise number. T/S: 04/22/2010 04:01 PM KSLATTUM ----- T/S: 02/28/2011 09:29 AM NTART -----
B103 01	5/10/10 5/10/10	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001923280
A814 01	5/13/10 5/07/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001923299 58 NEW RIVER CT LOT 25 ----- ANGIER 27501 T/S: 05/07/2010 04:54 PM TWARD -----
B105 01	3/03/11 3/03/11	BS AP	R*OPEN FLOOR VRU #: 002048304 T/S: March 03, 2011 10:15 AM BSUTTON -----
R425 01	3/15/11 <u>3-15-11</u>	TJ <u>DAB</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002053460 T/S: 03/14/2011 09:10 AM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS : 58 NEW RIVER CT
CONTRACTOR :
OWNER : IOM LAND COMPANY LLC #25
PARCEL : 04-0673- - -0134- -28-
APPL NUMBER: 07-50016661 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 210 E LEFT ON JAME NORRIS S/D ON RIGHT
LOT #25 JB
T/S: 02/17/2011 08:06 AM RDCONTE ---
PREMISE #42286612.

SUBDIV: AUTUMN POINTE 29 LOTS
PHONE :
PHONE :

STRUCTURE: 000 000 40X60 BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/10 4/22/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001913996 T pole good. Need premise number. T/S: 04/22/2010 04:01 PM KSLATTUM ----- T/S: 02/28/2011 09:29 AM NTART -----
B103 01	5/10/10 5/10/10	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001923280
A814 01	5/13/10 5/07/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001923299 58 NEW RIVER CT LOT 25 ----- ANGIER 27501 T/S: 05/07/2010 04:54 PM TWARD -----
B105 01	3/03/11 3/03/11	BS AP	R*OPEN FLOOR VRU #: 002048304 T/S: March 03, 2011 10:15 AM BSUTTON -----
R425 01	3/15/11 3/15/11	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002053460 T/S: 03/14/2011 09:10 AM VBROWN ----- Need firestop done. 2.Install roof boot3. Need gauge on plumbing test. 4. Rodent proof tub drains
R425 02	3/16/11 <u>3/16/11</u>	TI <u>APBS</u>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002054443 T/S: 03/15/2011 12:07 PM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS . : 58 NEW RIVER CT SUBDIV: AUTUMN POINTE 29 LOTS
 CONTRACTOR : PHONE :
 OWNER . . : IOM LAND COMPANY LLC #25 PHONE :
 PARCEL . . : 04-0673- - -0134- -28-
 APPL NUMBER: 07-50016661 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 210 E LEFT ON JAME NORRIS S/D ON RIGHT
 LOT #25 JB
 T/S: 02/17/2011 08:06 AM RDCONTE ---
 PREMISE #42286612.

STRUCTURE: 000 000 40X60 BDR
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/10 4/22/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001913996 T pole good. Need premise number. T/S: 04/22/2010 04:01 PM KSLATTUM ----- T/S: 02/28/2011 09:29 AM NTART -----
B103 01	5/10/10 5/10/10	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001923280
A814 01	5/13/10 5/07/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001923299 58 NEW RIVER CT LOT 25 ----- ANGIER 27501 T/S: 05/07/2010 04:54 PM TWARD -----
B105 01	3/03/11 3/03/11	BS AP	R*OPEN FLOOR VRU #: 002048304 T/S: March 03, 2011 10:15 AM BSUTTON -----
R425 01	3/15/11 3/15/11	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002053460 T/S: 03/14/2011 09:10 AM VBROWN ----- Need firestop done. 2.Install roof boot3. Need gauge on plumbing test. 4. Rodent proof tub drains
R425 02	3/16/11 3/16/11	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002054443 T/S: 03/15/2011 12:07 PM VBROWN ----- T/S: March 16, 2011 11:57 AM BSUTTON -----
I129 01	3/23/11 <u>3-23</u>	TI <u>AP</u>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002057024 T/S: 03/21/2011 11:43 AM VBROWN -----

COMMENTS AND NOTES

ADDRESS . : 58 NEW RIVER CT SUBDIV: AUTUMN POINTE 29 LOTS
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER . . : IOM LAND COMPANY LLC #25 PHONE :
PARCEL . . : 04-0673- - -0134- -28-
APPL NUMBER: 07-50016661 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 210 E LEFT ON JAME NORRIS S/D ON RIGHT
LOT #25 JB
T/S: 02/17/2011 08:06 AM RDCONTE ---
PREMISE #42286612.

STRUCTURE: 000 000 40X60 BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/10 4/22/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001913996 T pole good. Need premise number. T/S: 04/22/2010 04:01 PM KSLATTUM ----- T/S: 02/28/2011 09:29 AM NTART -----
B103 01	5/10/10 5/10/10	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001923280
A814 01	5/13/10 5/07/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001923299 58 NEW RIVER CT LOT 25 ----- ANGIER 27501 T/S: 05/07/2010 04:54 PM TWARD -----
B105 01	3/03/11 3/03/11	BS AP	R*OPEN FLOOR VRU #: 002048304 T/S: March 03, 2011 10:15 AM BSUTTON -----
R425 01	3/15/11 3/15/11	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002053460 T/S: 03/14/2011 09:10 AM VBROWN ----- Need firestop done. 2.Install roof boot3. Need gauge on plumbing test. 4. Rodent proof tub drains
R425 02	3/16/11 3/16/11	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002054443 T/S: 03/15/2011 12:07 PM VBROWN ----- T/S: March 16, 2011 11:57 AM BSUTTON -----
I129 01	3/23/11 3/23/11	KS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002057024 T/S: 03/21/2011 11:43 AM VBROWN -----
H824 01	5/03/11 5/03/11	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002075927 T/S: 05/04/2011 09:46 AM SZIMMER ----- T/S: 05/04/2011 09:46 AM SZIMMER -----
R429 01	5/17/11 <u>5-17-11</u>	TI <u>DAIS</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002081131 T/S: 05/16/2011 10:44 AM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS : 58 NEW RIVER CT SUBDIV: AUTUMN POINTE 29 LOTS
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER : IOM LAND COMPANY LLC #25 PHONE :
PARCEL : 04-0673- - -0134- -28-
APPL NUMBER: 07-50016661 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : 210 E LEFT ON JAME NORRIS S/D ON RIGHT
LOT #25 JB
T/S: 02/17/2011 08:06 AM RDCONTE ---
PREMISE #42286612.

STRUCTURE: 000 000 40X60 BDR
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/22/10 4/22/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001913996 T pole good. Need premise number. T/S: 04/22/2010 04:01 PM KSLATTUM ----- T/S: 02/28/2011 09:29 AM NTART -----
B103 01	5/10/10 5/10/10	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001923280
A814 01	5/13/10 5/07/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001923299 ✓58 NEW RIVER CT LOT 25 ----- ANGIER 27501 T/S: 05/07/2010 04:54 PM TWARD -----
B105 01	3/03/11 3/03/11	BS AP	R*OPEN FLOOR VRU #: 002048304 T/S: March 03, 2011 10:15 AM BSUTTON -----
R425 01	3/15/11 3/15/11	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002053460 T/S: 03/14/2011 09:10 AM VBROWN ----- Need firestop done. 2. Install roof boot3. Need gauge on plumbing test. 4. Rodent proof tub drains
R425 02	3/16/11 3/16/11	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002054443 T/S: 03/15/2011 12:07 PM VBROWN ----- T/S: March 16, 2011 11:57 AM BSUTTON -----
I129 01	3/23/11 3/23/11	KS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002057024 T/S: 03/21/2011 11:43 AM VBROWN -----
H824 01	5/03/11 5/03/11	OT AP	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002075927 T/S: 05/04/2011 09:46 AM SZIMMER ----- T/S: 05/04/2011 09:46 AM SZIMMER -----
R429 01	5/17/11 5/17/11	BS DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002081131 T/S: 05/16/2011 10:44 AM VBROWN ----- 1. Change receptacle at microwave to 20 amp. 2. Switch for attic light must be at attic access.
R429 02	5/19/11 <u>5-19-11</u>	TI <u>APBS</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002082352 T/S: 05/18/2011 08:05 AM JBROCK -----

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Permit Numbers

Name: Stancil Builders Inc

Building: 07-50016661

Electrical: 07-50016661

Address: 58 New River Ct

Insulation: 07-50016661

Angier NC 27501

Plumbing: 07-50016661

Mechanical: 07-50016661

MFG Home: NANANANA

Date: 05-19-2011

Building Official: BSutton