

HTE# 07-50016679R **Harnett County Department of Public Health** **23661**
07-50017534 **Improvement Permit**

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Homes PROPERTY LOCATION: 1210
 NEW REPAIR 52x EXPANSION SUBDIVISION: Persimmon Hill LOT # 78
 Type of Structure: SFO ~~50x31~~ 3BR Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% Reduction System
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years
 Permit conditions: STB out Plumbing shallow where shown, Ground level or higher No expiration
Maintain All STB Back

Authorized State Agent: Joe W. Ari Date: 2-16-07 Rev. 6-5-07 9HW SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cumberland Home PROPERTY LOCATION: 1210
 Facility Type: SFO ~~56x31~~ 3BR New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction Sys (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable 480 LF y LPO (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x300 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/-1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 Aggregate Depth: _____ inches above pipe
 Conditions: _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Joe W. Ari Date: 02-16-07 Rev. 6-5-07 9HW SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 02-16-2012 Rev 6-5-2012 9HW

07-500 17534

HTE# 07-500 16679 RR

Permit # 23661

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cumberland Homes

PROPERTY LOCATOR: 1210

SUBDIVISION

Persimmon Hill

LOT # 78

Authorized State Agent:

J. Waters

Date: 02-16-07 Rev. 6-5-07 ghw

Meet onsite maintain All setBacks
Stub out Plumbing shallow, At ground level or higher where shown
If Any Lines go Past Rear of the house They are to be 12"
Deep.

Initial 1x300
of 2 1/2 Reduction system
at 18" max
Ditch Depth

