
ADDRESS . . : 60 JOHN WHITE RD SUBDIV:
CONTRACTOR : CRAIG MATTHEWS REALTY INC PHONE : (910) 897-5676
OWNER . . : MATTHEWS CRAIG & DENISE #7 PHONE : (910) 890-4330
PARCEL . . : 07-0589- - -0090- -17-
APPL NUMBER: 07-50016694 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WHITE PINES PH4 #7
421S LEFT CRAWFORD LEFT HARVELL LEFT
FRED MCLEOD LN RT JOHN WHITE RD (NO
SIGN) LOT STRAIGHT AHEAD.JDAVIS

STRUCTURE: 000 000 48X56 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/15/07 5-15-	TI DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001408596

----- COMMENTS AND NOTES -----

ADDRESS . : 60 JOHN WHITE RD
CONTRACTOR : CRAIG MATTHEWS REALTY INC
OWNER . . : MATTHEWS CRAIG & DENISE #7
PARCEL . . : 07-0589- - -0090- -17-
APPL NUMBER: 07-50016694 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WHITE PINES PH4 #7
421S LEFT CRAWFORD LEFT HARVELL LEFT
FRED MCLEOD LN RT JOHN WHITE RD (NO
SIGN) LOT STRAIGHT AHEAD.JDAVIS

SUBDIV:
PHONE : (910) 897-5676
PHONE : (910) 890-4330

STRUCTURE: 000 000 48X56 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/15/07 5/15/07	KS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001408596 parts of footing only four inches thick. Minimum is 6 inches.
B101 02	5/17/07 5-17	TI AB	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001411010

KS

COMMENTS AND NOTES

ADDRESS . : 60 JOHN WHITE RD
CONTRACTOR : CRAIG MATTHEWS REALTY INC
OWNER . . : MATTHEWS CRAIG & DENISE #7
PARCEL . . : 07-0589- - -0090- -17-
APPL NUMBER: 07-50016694 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WHITE PINES PH4 #7
421S LEFT CRAWFORD LEFT HARVELL LEFT
FRED MCLEOD LN RT JOHN WHITE RD (NO
SIGN) LOT STRAIGHT AHEAD.JDAVIS

SUBDIV:
PHONE : (910) 897-5676
PHONE : (910) 890-4330

STRUCTURE: 000 000 48X56 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/15/07 5/15/07	KS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001408596 parts of footing only four inches thick. Minimum is 6 inches.
B101 02	5/17/07 5/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001411010
B103 01	5/30/07 <u>5-30</u>	TI <u>AP</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001417924

COMMENTS AND NOTES

ADDRESS . : 60 JOHN WHITE RD SUBDIV:
CONTRACTOR : CRAIG MATTHEWS REALTY INC PHONE : (910) 897-5676
OWNER . . : MATTHEWS CRAIG & DENISE #7 PHONE : (910) 890-4330
PARCEL . . : 07-0589- - -0090- -17-
APPL NUMBER: 07-50016694 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WHITE PINES PH4 #7
421S LEFT CRAWFORD LEFT HARVELL LEFT
FRED MCLEOD LN RT JOHN WHITE RD (NO
SIGN) LOT STRAIGHT AHEAD.JDAVIS

STRUCTURE: 000 000 48X56 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/15/07 5/15/07	KS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001408596 parts of footing only four inches thick. Minimum is 6 inches.
B101 02	5/17/07 5/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001411010
B103 01	5/30/07 5/30/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001417924
B105 01	6/05/07 <u>6/5/07</u>	TI <u>AR KS</u>	R*OPEN FLOOR VRU #: 001421973

----- COMMENTS AND NOTES -----

ADDRESS . . : 60 JOHN WHITE RD SUBDIV:
CONTRACTOR : CRAIG MATTHEWS REALTY INC PHONE : (910) 897-5676
OWNER . . : MATTHEWS CRAIG & DENISE #7 PHONE : (910) 890-4330
PARCEL . . : 07-0589- - -0090- -17-
APPL NUMBER: 07-50016694 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WHITE PINES PH4 #7
421S LEFT CRAWFORD LEFT HARVELL LEFT
FRED MCLEOD LN RT JOHN WHITE RD (NO
SIGN) LOT STRAIGHT AHEAD.JDAVIS

STRUCTURE: 000 000 48X56 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/15/07 5/15/07	KS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001408596 parts of footing only four inches thick. Minimum is 6 inches.
B101 02	5/17/07 5/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001411010
B103 01	5/30/07 5/30/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001417924
B105 01	6/05/07 6/05/07	KS AP	R*OPEN FLOOR VRU #: 001421973
A814 01	6/08/07 6/07/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001421964 60 John White Rd
R425 01	6/26/07 <u>6-26</u>	TI <u>AP</u>	FOUR TRADE ROUGH IN VRU #: 001434148

----- COMMENTS AND NOTES -----

ADDRESS . : 60 JOHN WHITE RD SUBDIV:
CONTRACTOR : CRAIG MATTHEWS REALTY INC PHONE : (910) 897-5676
OWNER . . : MATTHEWS CRAIG & DENISE #7 PHONE : (910) 890-4330
PARCEL . . : 07-0589- - -0090- -17-
APPL NUMBER: 07-50016694 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WHITE PINES PH4 #7
421S LEFT CRAWFORD LEFT HARVELL LEFT
FRED MCLEOD LN RT JOHN WHITE RD (NO
SIGN) LOT STRAIGHT AHEAD.JDAVIS

STRUCTURE: 000 000 48X56 3BR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/15/07 5/15/07	KS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001408596 parts of footing only four inches thick. Minimum is 6 inches.
B101 02	5/17/07 5/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001411010
B103 01	5/30/07 5/30/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001417924
B105 01	6/05/07 6/05/07	KS AP	R*OPEN FLOOR VRU #: 001421973
A814 01	6/08/07 6/07/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001421964 60 John White Rd
R425 01	6/26/07 6/26/07	KS AP	FOUR TRADE ROUGH IN VRU #: 001434148
I129 01	7/20/07 <u>7/20/07</u>	TI <u>AP DT</u>	R*INSULATION INSPECTION VRU #: 001450101

----- COMMENTS AND NOTES -----

ADDRESS : 60 JOHN WHITE RD
CONTRACTOR : CRAIG MATTHEWS REALTY INC
OWNER : MATTHEWS CRAIG & DENISE #7
PARCEL : 07-0589- - -0090- -17-
APPL NUMBER: 07-50016694 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WHITE PINES PH4 #7
421S LEFT CRAWFORD LEFT HARVELL LEFT
FRED MCLEOD LN RT JOHN WHITE RD (NO
SIGN) LOT STRAIGHT AHEAD.JDAVIS

SUBDIV:
PHONE : (910) 897-5676
PHONE : (910) 890-4330

STRUCTURE: 000 000 48X56 3BR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/15/07 5/15/07	KS DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001408596 parts of footing only four inches thick. Minimum is 6 inches.
B101 02	5/17/07 5/17/07	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001411010
B103 01	5/30/07 5/30/07	KS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001417924
B105 01	6/05/07 6/05/07	KS AP	R*OPEN FLOOR VRU #: 001421973
A814 01	6/08/07 6/07/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001421964 ✓ 60 John White Rd
R425 01	6/26/07 6/26/07	KS AP	FOUR TRADE ROUGH IN VRU #: 001434148
I129 01	7/20/07 7/20/07	DT AP	R*INSULATION INSPECTION VRU #: 001450101
H824 01	7/27/07 7/27/07	GB AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001456771
R429 01	9/11/07 <u>9-11</u>	TI <u>AP</u>	FOUR TRADE FINAL VRU #: 001482853 <u>KS</u>

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Craig Mathews Electrical Permit No.: _____
Building Address: 60 John White Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: _____
Date: 9-11-07 Envir. C.O. No.: 07-50016694
Ken Slatten

Building Official

Zoning Official